



ANSI/NEMA C12.10-2004

American National Standard for Physical Aspects of Watthour Meters-Safety Standard



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org





ANSI C12.10-2004

American National Standard

for Physical Aspects
of Watthour Meters—
Safety Standard



ANSI C12.10-2004

Revision of
ANSI C12.10-1997

**American National Standard
for Physical Aspects of Watthour Meters—
Safety Standard**

Secretariat:

National Electrical Manufacturers Association

Approved July 1, 2004

American National Standards Institute

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgement of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Suite 1847, Rosslyn, VA 22209**

© Copyright 2004 by the National Electrical Manufacturers Association.

All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America.

This page intentionally left blank.

Contents

	Page
Foreword.....	v
1 Scope.....	1
2 References.....	1
3 Standards applicable to watthour meters	1
3.1 Mounting.....	1
3.2 Voltage and frequency	1
3.3 Current classes and test amperes (TA)	1
3.4 Typical form designations	2
3.5 Rotor (electromechanical meters only) (see Figure 2)	3
3.5.1 Direction of rotation.....	3
3.5.2 Provisions for testing.....	3
3.6 Calibration adjustments (electromechanical meters only)	4
3.7 Meter nameplate	4
3.7.1 Permissible abbreviations	4
3.7.2 Marking	5
3.7.3 Location of nameplate.....	5
3.7.4 Material	5
3.7.5 Space for utility data or company (utility) number	5
3.8 Displays.....	6
3.8.1 Pointer type register.....	6
3.8.2 Drum type cyclometer register.....	6
3.8.3 Solid state type.....	7
3.9 Requirements for solid-state registers.....	7
3.9.1 Switch points.....	7
3.9.2 Demand interval (non-thermal).....	7
3.9.3 Power outage.....	7
3.9.4 Optical communication interface.....	8
3.9.5 Security	8
3.9.6 Register nameplate information.....	8
3.9.7 Auxiliary switching outputs.....	8
4 Requirements applicable to detachable watthour meters.....	8
4.1 Dimensions.....	8
4.2 Hanger.....	8
4.3 Sealing	8
4.4 Connections	8
5 Requirements applicable to bottom-connected meters.....	9
5.1 Dimensions	9
5.2 Hanger	9
5.3 Sealing	9
5.4 Connections	9
5.5 Terminal blocks	9
5.6 Terminals	9
5.6.1 Current terminals	9
5.6.2 Voltage terminals	9
6 Procedure for assigning form designations.....	10

Tables

1	Current classes and test amperes.....	1
2	Typical form designations (socket type).....	2
2A	Typical form designations (bottom fed).....	3
4	Envelope of surfaces that project into socket for 5-terminal meters in 7-terminal sockets...	13
5	Envelope of surfaces that project into socket for 7-terminal and 8-terminal meters.....	14
6	Envelope of surfaces that project into socket for 8-terminal and 13- to 15-terminal meters.	15

Figures

1	External view of ANSI type 2 optical port.....	11
2	Markings for watt-hour meter rotors.....	12
3	Envelope of surfaces that project into socket for 4- to 6-terminal meters.....	13
4	Envelope of surfaces that project into socket for 5-terminal meters in 7-terminal sockets...	14
5	Envelope of surfaces that project into socket for 7-terminal and 8-terminal meters.....	15
6	Envelope of surfaces that project into socket for 8-terminal and 13- to 15-terminal meters.	16
7	Mounting and terminal dimensions for detachable single element and multi-element watt-hour meters with 4- to 8-terminals.....	17
7A	Suggested dimensions for bevels for terminal blades.....	18
8	Mounting and terminal dimensions for detachable multi-element watt-hour meters with 8-terminals and 13- to 15-terminals.....	19
9	Envelope of round covers for detachable single element and multi-element watt-hour meters.....	20
10	Internal connections for detachable single element watt-hour meters (front views).....	21
11	Internal connections for transformer rated detachable multi-element watt-hour meters (front views).....	22
11A	Internal connections for transformer rated detachable multi-element watt-hour meters (front views).....	23
12	Internal connections for self-contained detachable multi-element watt-hour meters (front views).....	24
12A	2-element, 4-wire (universal) form 28S.....	25
13	Socket jaw position identification (front view of socket).....	26
14	Outline and terminal dimensions for bottom-connected single element watt-hour meters....	27
15	Outline and mounting dimensions for bottom-connected multi-element watt-hour meters....	28
16	Internal connections for bottom-connected single element watt-hour meters (front views)...	29
17	Internal connections for transformers rated bottom-connected multi-element watt-hour meters (front views).....	30
18	Internal connections for self-contained bottom-connected multi-element watt-hour meters (front views).....	31
ANNEX A	32
	A.1 Foreword to the First Edition (1978).....	32
	A.2 Foreword to the Second Edition (1987).....	33
	A.3 Foreword to Third Edition (1997).....	34

Foreword (This Foreword is not part of American National Standard C12.10-2004.)

This standard was developed by the Accredited Standards Committee on Electricity Metering, C12, for full consensus approval as an American National Standard and provides recommended minimum requirements for both detachable and bottom-connected watt-hour meters. This revised edition supersedes ANSI C12.10-1997.

Suggestions for improvement to this standard are welcome. They should be sent to:

National Electrical Manufacturers Association
 Vice President of Engineering
 1300 North 17th Street
 Suite 1847
 Rosslyn, VA 22209

There were relatively few changes made to this edition to bring it up to date with modern practice and with new editions of other ANSI C12 standards. The title was modified to more accurately reflect the contents of this edition. The last of the performance specifications for solid state registers on electro-mechanical meters that were in section 6, have been moved to C12.1-2001 and thus this standard now contains physical specifications. To this edition Forms 39S and 76S were added, as was the reference to class 2 ampere meters. The drawing for figure 6 was corrected.

Dimensions and other relevant specifications given in this standard have been coordinated with the American National Standard Requirements for Watt-hour Meters Sockets, ANSI C12.7-1993. At the time the committee approved this standard, the C12 Committee had the following members:

Tom Nelson, Chairman
Carin Bernstiel, Secretary

<i>Organization Represented:</i>	<i>Name of Representative:</i>
American Public Power Association	C. Gomez
Edison Electrical Institute	L. Kotewa J. McEvoy J. Mining T. Morgan D. Y. Nguyen L. Pananen
Institute of Electrical and Electronics Engineers	H. Millican
Measurement Canada (Liaison No Vote)	V. Nguyen
National Electrical Manufacturers Association	M. Anderson E. Beraset C. Crittenden F. Marta S. Weikel
National Institute of Standards and Technology	T. Nelson
NARUC	J. Ruehl

Underwriters Laboratory

R. Breschini

Independent Members:

B. Hughes

A. Moise

A. Snyder

The members of Subcommittee ANSI C12.1 who contributed to the development of this standard are:

Organization Represented:

Name of Representative:

Arizona Public Service

B. Cook

Austin Energy

H. Millican

Baltimore Gas & Electric

J. Thurber

Central Hudson Gas & Electric Co

R. Lokys

City of L.A. Water & Power

C. Gomez

Duke Power Company

T. Morgan

Duke Power Company

W. Ray

Elster Electric Co

S. Weikel

Florida Power & Light

J. DeMars

Florida Power & Light

J. McEvoy

Ed Malemezian Consulting

E. Malemezian

General Electric

C. Crittenden

Invensys Metering Systems

N. Balko

Landis+Gyr

M. Anderson

NIST

T. Nelson

Pacific Gas & Electric

D. Y. Nguyen

Pacificorp

L. Pananen

Public Service Electric & Gas

D. Ellis

Radian Research

G. Mayfield

Schlumberger Electricity Inc

A. Snyder

Schweitzer Engineering Labs

B. Hughes

Watthour Engineering Co

C. Weimer

In addition, the following comprised the Editorial Committee for the current revision of C12.10:

D. Ellis

E. Malemezian

D. Y. Nguyen

A. Snyder

S. Weikel

For Physical Aspects of Watthour Meters

1 Scope

This standard covers the physical aspects of both detachable and bottom-connected watthour meters and associated registers. These include ratings, internal wiring arrangements, pertinent dimensions, markings, and other general specifications. Refer to the latest version of ANSI C12.1 and ANSI C12.20 for performance requirements.

2 References

The following publications shall be used in conjunction with this standard. Use the latest published version of the document if no year is specified:

ANSI C12.1, *American National Standard for Electric Meters*

ANSI MH10.8.1- 2000, *Linear Bar Code and Two Dimensional Symbols Used in Shipping, Receiving, and Transport Applications*

The Handbook for Electricity Metering, 10th edition 2002, The Edison Electric Institute

3 Standards applicable to watthour meters

3.1 Mounting

Mounting arrangements shall be either detachable (socket or type "S") or bottom-connected (type "A").

3.2 Voltage and frequency

The typical voltage and frequency ratings are 120, 240, 277, or 480 V and 60 Hz.

3.3 Current classes and test amperes (TA)

The normal current classes and test amperes shall be as listed in Table 1:

Table 1 – Current classes and test amperes

Current Class	Test Amperes
2	0.25 A
10	2.5 A
20	2.5 A
100	15 A
200	30 A
320	50 A

NOTE—Current classes 200 and 320 in "S" type only.

Other values of test amperes may be used.