



IEEE Guide for Field Testing of Laminated Dielectric, Shielded Power Cable Systems Rated 5 kV and Above with High Direct Current Voltage

IEEE Power Engineering Society

Sponsored by the
Insulated Conductors Committee

400.1TM

IEEE
3 Park Avenue
New York, NY 10016-5997, USA
21 September 2007

IEEE Std 400.1TM-2007
(Revision of
IEEE Std 400TM-1991)

IEEE Guide for Field Testing of Laminated Dielectric, Shielded Power Cable Systems Rated 5 kV and Above with High Direct Current Voltage

Sponsor

**Insulated Conductors Committee
of the
IEEE Power Engineering Society**

Approved 22 March 2007

IEEE-SA Standards Board

Abstract: The recommended practices and procedures for direct voltage acceptance and maintenance testing of shielded, laminated dielectric insulated power cable systems rated 5 kV and above are presented in this guide. It applies to all types of laminated power cable systems such as paper insulated, lead covered, pipe-type, and pressurized cables that are intended for the transmission or distribution of electric power. The tabulated test levels assume that the cable systems have an effectively grounded neutral system or a grounded metallic shield.

Keywords: cable, cable installation, cable maintenance, cable tests, field test procedures, high direct voltage tests, insulated cable, power cable systems, shielded power cable systems

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2007 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 21 September 2007. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Safety Code and NESC are registered trademarks in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

Print: ISBN 0-7381-5579-9 SH95675
PDF: ISBN 0-7381-5580-2 SS95675

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 400.1-2007, IEEE Guide for Field Testing of Laminated Dielectric, Shielded Power Cable Systems Rated 5 kV and Above with High Direct Current Voltage.

To say that there is a marked difference of opinion on the matter of cable testing would be a decided understatement. Many users, particularly utilities, while practicing acceptance testing, do not favor maintenance testing, or testing after cable systems have been in service, believing that such tests may shorten cable life. A few utility users, and many industrial users, favor both acceptance and maintenance testing, believing that such testing will contribute to improved service reliability. Others feel that either acceptance or maintenance testing can cause cable damage, resulting in premature failures and customer dissatisfaction. Annex C of this guide gives additional background and more detailed commentary on these attitudes and philosophies. There is undoubtedly much to be said both for and against all viewpoints; only the individual user can determine whether, how frequently, and at what stresses testing is to be conducted.

In short, this guide does not suggest that cable system testing be done; it simply provides guidance for such testing, developed by those who have found it useful. Additionally, it provides interpretive information based on many years of experience. Finally, pervading the entire procedure, safety has been a constant consideration in each step of the recommended practices. It is hoped that use of this guide will increase the fund of knowledge on the subject and result in more meaningful testing procedures and methods.

Suggestions for improvements to this guide are welcome. They should be sent to the Secretary, IEEE-SA Standards Board, 445 Hoes Lane, Piscataway, NJ 08854, USA.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this guide may require use of subject matter covered by patent rights. By publication of this guide, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

At the time this guide was submitted to the IEEE-SA Standards Board for approval, the Insulated Conductors Committee C-17 Working Group had the following membership:

William E. Larzelere, Jr., *Chair*
Vern L. Buchholz, *Secretary*

Torben Aabo
John R. Densley
Hans R. Gnerlich
Martin von Herrmann
Stanley V. Heyer

Fred B. Koch
Jerry L. Landers
William M. McDermid
James D. Medek

Henning H. Oetjen
Johannes G. Rickmann
Lawrence W. Salberg
William A. Thue
Joseph Zimnoch

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Torben Aabo
S. K. Aggarwal
Thomas M. Barnes
Earle C. Bascom, III
Wallace B. Binder, Jr.
Steven R. Brockschink
Kent W. Brown
Vern L. Buchholz
James S. Case
Mark S. Clark
Michael D. Clodfelder
John H. Cooper
Tommy P. Cooper
Jerry L. Corkran
Jorge E. Fernandez Daher
John R. Densley
Ernest M. Duckworth, Jr.
Gary R. Engmann
R. B. Gear, Jr.
Frank J. Gerleve
Harry D. Gianakouros
Randall C. Groves
Adrienne M. Hendrickson

Gary A. Heuston
Lauri J. Hiivala
Dennis Horwitz
David W. Jackson
A. S. Jones
James H. Jones
Lars E. Juhlin
Gael Kennedy
J. L. Koepfinger
Jim Kulchisky
William E. Larzelere, Jr.
Solomon Lee
Jody P. Levine
Albert Livshitz
William Lumpkins
G. L. Luri
Glenn J. Luzzi
Keith N. Malmedal
William M. McDermid
Mark F. McGranaghan
Nigel P. McQuin
John E. Merando, Jr.

James R. Michalec
Gary L. Michel
Rachel I. Mosier
Kyaw Myint
Shantanu Nandi
Michael S. Newman
Charles Kamithi Ngethe
Ralph E. Patterson
Serge Pelissou
Johannes G. Rickmann
Michael A. Roberts
Michael J. Smalley
Nagu N. Srinivas
James E. Timperley
Martin J. von Herrmann
Waldemar G. Von Miller
Mark D. Walton
Joe D. Watson
Ernesto Jorge Wiedenbrug
William D. Wilkens
James W. Wilson, Jr.
Donald W. Zipse
Ahmed F. Zobaa

When the IEEE-SA Standards Board approved this guide on 22 March 2007, it had the following membership:

Steve M. Mills, *Chair*
Robert M. Grow, *Vice Chair*
Don F. Wright, *Past Chair*
Judith Gorman, *Secretary*

Richard DeBlasio
Alexander D. Gelman
William R. Goldbach
Arnold M. Greenspan
Joanna N. Guenin
Julian Forster*
Kenneth S. Hanus
William B. Hopf

Richard H. Hulett
Hermann Koch
Joseph L. Koepfinger*
John D. Kulick
David J. Law
Glenn Parsons
Ronald C. Petersen
Tom A. Prevost

Narayanan Ramachandran
Greg Ratta
Robby Robson
Anne-Marie Sahazizian
Virginia C. Sulzberger
Malcolm V. Thaden
Richard L. Townsend
Howard L. Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Alan H. Cookson, *NIST Representative*

Lorraine Patsco
IEEE Standards Program Manager, Document Development

Matthew J. Ceglia
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
2. Normative references.....	1
3. General	2
3.1 Environmental influences	2
3.2 Test equipment	3
4. Test procedure	4
4.1 Test precautions	4
4.2 Safety practices	5
4.3 Testing procedure	5
4.4 Recording of test results	8
5. Evaluation of results	8
5.1 Current-time relationships	8
5.2 Resistance values	9
Annex A (informative) Reasons for testing.....	11
A.1 Acceptance tests.....	11
A.2 Maintenance tests.....	11
A.3 Corrective actions	11
Annex B (informative) Protection against possible severe voltage conditions due to flashover	12
B.1 Possible surge voltage conditions	12
B.2 Surge protection requirements	12
Annex C (informative) Discussion of differences of opinions regarding dc testing.....	13
Annex D (informative) Bibliography	14

IEEE Guide for Field Testing of Laminated Dielectric, Shielded Power Cable Systems Rated 5 kV and Above with High Direct Current Voltage

1. Overview

This guide provides a description of the methods and practices to be used when field-testing laminated dielectric power cable systems. There is no requirement that any testing be performed either at the time of installation or periodically thereafter. However, it is well known that direct current (dc) testing of laminated dielectric shielded power cables has been performed for many years, especially for new installations or after repairs. If the user decides to have a direct voltage test made on the system, the following information is intended to provide a guide to the methodology, voltages, and concerns to be considered during the testing.

1.1 Scope

This guide presents the recommended practices and procedures for direct voltage acceptance and maintenance testing of shielded, laminated dielectric insulated power cable systems rated 5 kV and above. It applies to all types of laminated power cable systems such as paper-insulated lead covered, pipe-type, and pressurized cables that are intended for the transmission or distribution of electric power. The tabulated test levels assume that the cable systems have an effectively grounded neutral system or a grounded metallic shield.

1.2 Purpose

The purpose of this guide is to provide uniform practices and procedures for performing direct voltage acceptance and maintenance tests on shielded, laminated power cable systems in the field and to provide guidelines for evaluation of the test results.

2. Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.