



ANSI/NEMA C12.22-2008

American National Standard for Protocol Specification for Interfacing to Data Communication Networks



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org





ANSI C12.22-2008

American National Standard

Protocol Specification

For

Interfacing to Data

Communication Networks



ANSI C12.22-2008

American National Standard

**Protocol Specification
For
Interfacing to Data Communication Networks**

Secretariat:

National Electrical Manufacturers Association

Approved January 9, 2009

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no warranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Rosslyn, VA 22209**

© Copyright 2008 by National Electrical Manufacturers Association

All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

This page intentionally left blank.

Contents

	Page
1 SCOPE.....	1
2 REFERENCES	2
2.1 NORMATIVE	2
2.2 OTHERS	4
3 DEFINITIONS AND SYNTAX.....	4
3.1 DEFINITIONS.....	4
3.1.1 <i>Absolute UID</i>	4
3.1.2 <i>ACSE</i>	4
3.1.3 <i>APDU Segment</i>	5
3.1.4 <i>Application Association</i>	5
3.1.5 <i>Application Context</i>	5
3.1.6 <i>Application Entity</i>	5
3.1.7 <i>Application Process</i>	5
3.1.8 <i>Application Protocol Data Unit (APDU)</i>	5
3.1.9 <i>ApTitle</i>	5
3.1.10 <i>Association</i>	5
3.1.11 <i>BER</i>	5
3.1.12 <i>Bit</i>	5
3.1.13 <i>Byte</i>	6
3.1.14 <i>C12.19 Device</i>	6
3.1.15 <i>C12.19 Device Class</i>	6
3.1.16 <i>C12.22 Application</i>	6
3.1.17 <i>C12.22 Authentication Host</i>	6
3.1.18 <i>C12.22 Client</i>	6
3.1.19 <i>C12.22 Communication Module</i>	6
3.1.20 <i>C12.22 Datagram Segmentation and Reassembly</i>	6
3.1.21 <i>C12.22 Device</i>	6
3.1.22 <i>C12.22 Gateway</i>	6
3.1.23 <i>C12.22 Host</i>	7
3.1.24 <i>C12.22 Master Relay</i>	7
3.1.25 <i>C12.22 Message</i>	7
3.1.26 <i>C12.22 Network</i>	7
3.1.27 <i>C12.22 Network Segment</i>	7
3.1.28 <i>C12.22 Node</i>	7
3.1.29 <i>C12.22 Notification Host</i>	7
3.1.30 <i>C12.22 Relay</i>	7
3.1.31 <i>C12.22 Server</i>	7
3.1.32 <i>Called ApTitle</i>	7
3.1.33 <i>Calling ApTitle</i>	7
3.1.34 <i>Channel</i>	7
3.1.35 <i>Cipher</i>	8
3.1.36 <i>Cipher, Inverse</i>	8
3.1.37 <i>Ciphertext</i>	8
3.1.38 <i>Cleartext</i>	8
3.1.39 <i>Connection</i>	8
3.1.40 <i>Datagram</i>	8
3.1.41 <i>EPSEM</i>	8
3.1.42 <i>Fragment</i>	8

3.1.43	<i>Interface</i>	8
3.1.44	<i>Local Port</i>	8
3.1.45	<i>Octet</i>	8
3.1.46	<i>Other Device</i>	8
3.1.47	<i>Plaintext</i>	8
3.1.48	<i>PSEM</i>	8
3.1.49	<i>Relative UID</i>	9
3.1.50	<i>Segment</i>	9
3.1.51	<i>Segmentation</i>	9
3.1.52	<i>Session</i>	9
3.1.53	<i>Transaction</i>	9
3.1.54	<i>UID</i>	9
3.2	DOCUMENT SYNTAX.....	9
3.3	TABLE SYNTAX.....	10
4	REFERENCE TOPOLOGY	10
5	C12.22 NODE TO C12.22 NETWORK SEGMENT DETAILS	12
5.1	C12.22 NODE TO C12.22 NETWORK SEGMENT REFERENCE.....	12
5.2	DATA ENCODING RULES.....	12
5.2.1	<i>Data order</i>	12
5.2.2	<i>Length Fields Encoding</i>	13
5.2.3	<i>Universal Identifiers Encoding</i>	13
5.2.4	<i>Universal Identifiers Canonical Encoding</i>	15
5.3	LAYER 7—APPLICATION LAYER.....	15
5.3.1	<i>Data Structure—Utility Industry Data Tables</i>	15
5.3.2	<i>EPSEM</i>	15
5.3.2.1	Request Codes.....	16
5.3.2.2	Response Codes.....	16
5.3.2.3	Time-out.....	19
5.3.2.3.1	Session Time-out.....	19
5.3.2.3.2	Application Layer Response Time-out.....	20
5.3.2.4	Services.....	20
5.3.2.4.1	Identification Service.....	20
5.3.2.4.2	Read Service.....	23
5.3.2.4.3	Write Service.....	25
5.3.2.4.4	Logon Service.....	26
5.3.2.4.5	Security Service.....	27
5.3.2.4.6	Logoff Service.....	28
5.3.2.4.7	Terminate Service.....	28
5.3.2.4.8	Disconnect Service.....	29
5.3.2.4.9	Wait Service.....	30
5.3.2.4.10	Registration Service.....	30
5.3.2.4.11	Deregistration Service.....	37
5.3.2.4.12	Resolve Service.....	37
5.3.2.4.13	Trace Service.....	38
5.3.2.5	Service sequence state control.....	39
5.3.2.6	Partial Table access using index/element-count Method.....	41
5.3.2.7	Partial Table access using offset/octet-count method.....	43
5.3.3	<i>EPSEM Envelope Structure</i>	44
5.3.4	<i>Association Control—Association Control Service Element (ACSE)</i>	45
5.3.4.1	Application Context Element (A1 _H).....	46
5.3.4.2	Called AP Title Element (A2 _H).....	47
5.3.4.3	Calling AP Title Element (A6 _H).....	47
5.3.4.4	Universal Identifier of Called and Calling AP Title Element (06 _H).....	47
5.3.4.5	Relative Universal Identifier of Called and Calling AP Title Element (80 _H).....	48
5.3.4.6	Calling Application Entity Qualifier Element (A7 _H).....	48
5.3.4.7	Mechanism Name Element (8B _H).....	49

5.3.4.8	Calling Authentication Value Element (AC _H)	49
5.3.4.8.1	C12.22 Security Mechanism (<application-context-oid>.2.1)	51
5.3.4.8.2	C12.21 Security Mechanism (<application-context-oid>.2.0)	53
5.3.4.8.3	C12.22 Other Security Mechanisms	55
5.3.4.9	Called AP Invocation ID Element (A4 _H)	56
5.3.4.10	Calling AP Invocation ID Element (A8 _H)	56
5.3.4.11	User Information Element (BE _H)	58
5.3.4.12	Use of Subbranches of a Registered ApTitle	59
5.3.4.13	C12.22 Security Mechanism	63
5.3.4.13.1	C12.22 Security Mechanism (<application-context-oid>.2.1)	64
5.3.5	<i>Application Segmentation Sub-layer</i>	70
5.3.5.1	APDU Segmentation	71
5.3.5.2	APDU Segment	71
5.3.5.2.1	Called AE Qualifier Element (A3 _H)	71
5.3.5.2.2	Segment User Information Element (BE _H)	72
5.3.5.2.2.1	Segment Association Information Element	72
5.3.5.2.2.2	Segment Data Elements	72
5.3.5.3	The Segmentation and Reassembly	73
5.3.5.3.1	The Segmentation Algorithm	73
5.3.5.3.2	The Reassembly Algorithm	74
5.4	LAYER 6—PRESENTATION LAYER	75
5.5	LAYER 5—SESSION LAYER	75
5.6	LAYER 4—TRANSPORT LAYER	76
5.7	LAYER 3—NETWORK LAYER	76
5.8	LAYER 2—DATA LINK LAYER	76
5.9	LAYER 1—PHYSICAL LAYER	76
6	PROTOCOL DETAILS: C12.22 DEVICE TO C12.22 COMMUNICATION MODULE INTERFACE 77	
6.1	INTERFACE ARCHITECTURE	77
6.2	INTERFACE DIAGRAM	77
6.3	IMPLEMENTATION GUIDELINES	78
6.3.1	<i>C12.22 Communication Module</i>	78
6.3.2	<i>C12.22 Device</i>	79
6.4	LAYER 7—APPLICATION LAYER	79
6.5	LAYER 6—PRESENTATION LAYER	80
6.6	LAYER 5—SESSION LAYER	80
6.7	LAYER 4—TRANSPORT LAYER	80
6.7.1	<i>Negotiate Service</i>	80
6.7.2	<i>Get Configuration Service</i>	82
6.7.3	<i>Link Control Service</i>	85
6.7.4	<i>Send Message Service</i>	87
6.7.5	<i>Get Status Service</i>	88
6.7.6	<i>Get Registration Status Service</i>	89
6.7.7	<i>Service Time Sequence Diagrams</i>	91
6.7.8	<i>Service Sequence States</i>	94
6.8	LAYER 3—NETWORK LAYER	96
6.9	LAYER 2—DATA LINK LAYER	96
6.9.1	<i>Basic Data Information</i>	97
6.9.1.1	Fixed Settings	97
6.9.1.2	Variable Settings	97
6.9.2	<i>Packet Definition</i>	97
6.9.3	<i>CRC Selection</i>	99
6.9.4	<i>Acknowledgment</i>	99
6.9.5	<i>Retry Attempts</i>	100
6.9.6	<i>Timeouts</i>	100
6.9.6.1	Traffic Time-out	100
6.9.6.2	Inter-character Time-out	100

6.9.6.3	Response Time-out	100
6.9.7	<i>Turn Around Delay</i>	100
6.9.8	<i>Collision</i>	100
6.9.9	<i>Duplicate Packets</i>	101
6.9.10	<i>Transparency</i>	101
6.9.11	<i>Supervision of the Communications Link</i>	101
6.9.12	<i>Local Routing</i>	101
6.9.13	<i>Service Sequence States</i>	103
6.10	LAYER 1—PHYSICAL LAYER	104
6.10.1	<i>Signal Definition</i>	104
6.10.2	<i>Electrical Properties of Connection</i>	104
6.10.3	<i>Mechanical and Environmental Properties</i>	105
6.10.4	<i>Supervision of the Communications Link</i>	106
7	LOCAL PORT COMMUNICATION PROTOCOL DETAILS.....	107
7.1	PROTOCOL DEFINITION.....	107
7.1.1	<i>Layer 7—Application Layer</i>	107
7.1.2	<i>Layer 6—Presentation Layer</i>	107
7.1.3	<i>Layer 5—Session Layer</i>	107
7.1.4	<i>Layer 4—Transport Layer</i>	107
7.1.5	<i>Layer 3—Network Layer</i>	108
7.1.6	<i>Layer 2—Data Link Layer</i>	108
7.1.7	<i>Layer 1—Physical Layer</i>	108
7.2	C12.22 LOCAL PORT COMMUNICATION USING A C12.18 OPTICAL PORT.....	108
7.2.1	<i>Establishment of ANSI C12.18 Protocol Compatibility Mode</i>	109
7.2.2	<i>Establishment of ANSI C12.22 Protocol Compatibility Mode</i>	109
8	BACKWARD COMPATIBILITY.....	110
9	COMPLIANCE	111
ANNEX A—RELAYS.....		112
A.1	HIERARCHICAL TOPOLOGY.....	112
A.2	C12.22 MASTER RELAYS	112
A.3	REGISTRATION NOTIFICATION.....	113
A.4	REGISTRATION ALGORITHM DETAILS.....	113
A.5	C12.22 NODE AP TITLE AUTO-ASSIGNMENT.....	113
A.6	C12.22 MASTER RELAY AP TITLE AUTO-ASSIGNMENT.....	114
A.7	OBSOLETE ROUTES.....	114
A.8	MULTIPLE ROUTES	114
A.9	APPLICATION LAYER SUPERVISION	114
A.10	ROUTING	115
ANNEX B—ROUTING EXAMPLES.....		116
B.1	C12.22 RELAYS WITH A SINGLE SERVICE PROVIDER	116
B.2	C12.22 RELAYS SHARED BY MULTIPLE SERVICE PROVIDERS	116
ANNEX C—MODIFICATIONS AND EXTENSIONS TO C12.19-1997		118
C.1	DECADE 12: NODE NETWORK CONTROL TABLES.....	119
TABLE 120	<i>Dimension Network Table</i>	119
TABLE 121	<i>Actual Network Table</i>	123
TABLE 122	<i>Interface Control Table</i>	126
TABLE 123	<i>Exception Report Configuration Table</i>	129
TABLE 124	<i>Filtering Rules Table</i>	131
TABLE 125	<i>Interface Status Table</i>	133

TABLE 126 Registration Status Table.....	138
TABLE 128 Network Statistics Table	141
C.2 DECADE 130—RELAY CONTROL TABLES	143
TABLE 130 Dimension Relay Table	143
TABLE 131 Actual Relay Table.....	145
TABLE 132 Registration List Table.....	146
TABLE 133 Static Routing Table.....	149
TABLE 134 Host Notification Table.....	151
TABLE 135 Master Relay Assignment Table.....	154
TABLE 136 Dynamic Routing Report Table	155
C.3 UNIVERSAL ID PATTERN DESCRIPTION OF AP TITLES	156
C.4 ADDITIONS TO TABLE 07—PROCEDURE INITIATE TABLE.....	157
PROCEDURE 23 Register	157
PROCEDURE 24 Deregister.....	157
PROCEDURE 25 Network Interface Control	157
PROCEDURE 26 Exception Report.....	158
C.5 TABLE 46: EXTENDED KEY TABLE	160
C.6 TABLE 47 HOST ACCESS SECURITY TABLE	162
ANNEX D—UNIVERSAL IDENTIFIER.....	166
ANNEX E—ONE-WAY DEVICES.....	168
ANNEX F—APDU RESPONSE TIMEOUT ALGORITHM	170
ANNEX G—COMMUNICATION EXAMPLE	172
EXAMPLE #1: UNSECURED SESSION	172
EXAMPLE #2: UNSECURED SESSIONLESS	173
EXAMPLE #3: UNSECURED NOTIFICATION	174
EXAMPLE #4: AUTHENTICATED SESSION	174
EXAMPLE #5: AUTHENTICATED SESSIONLESS	176
EXAMPLE #6: AUTHENTICATED NOTIFICATION.....	178
EXAMPLE #7: ENCRYPTED SESSION	178
EXAMPLE #8: ENCRYPTED SESSIONLESS.....	182
EXAMPLE #9: ENCRYPTED NOTIFICATION.....	183
ANNEX H—CRC EXAMPLES.....	185
H.1 TRACE	185
H.2 CRC CODE EXAMPLE	186
ANNEX I—THE EAX' CRYPTOGRAPHIC MODE	187
I.1 EAX' DESCRIPTION	187
I.2 JUSTIFICATIONS FOR SELECTION OF EAX RATHER THAN CCM (INFORMATIVE)	191
I.3 JUSTIFICATIONS FOR THE EAX' OPTIMIZATIONS.....	192
I.4 EAX' C CODE EXAMPLE (INFORMATIVE)	195
I.5 AES C CODE EXAMPLE (INFORMATIVE)	199
ANNEX J – CONNECTIONLESS-ACSE-1 EQUIVALENT REDUCED SYNTAX FOR C12.22 MESSAGE TRANSMISSION	204

Foreword (This Foreword is not part of American National Standard C12.22-2008.)

This Standard is another in the series of communications protocols that describe how to transport Tables (defined in ANSI C12.19, "Utility Industry End Device Data Tables"). Because this Standard describes a protocol that operates over networks, it is necessarily more complex than the simple point-to-point protocols defined in ANSI C12.18 and ANSI C12.21, but the committee has done as much as practical to smooth the transition from those earlier standards.

This Standard describes three different but related uses. One is the operation of the protocol over the network that all C12.22 Nodes implement. The second is an optionally exposed point-to-point interface between a C12.22 Device, e.g., a meter, and, a C12.22 Communications Module, e.g., a network adaptor. The third is the capture, translation and transmission of one way device messages (blurts).

This division was chosen to foster interoperability among communications modules and meters. Suggestions for improvement to this Standard are welcome. They should be sent to:

National Electrical Manufacturers Association
Vice President, Technical Services
1300 North 17th Street
Suite 1752
Rosslyn, VA 22209

This Standard was processed and approved for submittal to ANSI by Accredited Standards Committee for Electricity Metering C12. At the time the committee approved this Standard, the C12 Committee had the following members:

Tom Nelson, Chairman
Paul Orr, Secretary—NEMA Staff

Name of Representative:

Larry Barto
Ron Breschini
Brent Cain
Curt Crittenden
Jim DeMars
David Ellis
Tim Everidge
Shawn Glasgow
Bill Hardy
Bob Hughes
Brad Johnson
Lawrence Kotewa
Herman Millican
Avygdor Moise
Tim Morgan
Tom Nelson
D. Young Nguyen
Dan Nordell
Dave Scott
Aaron Snyder
George Steiner
Jim Thurber
Richard Tucker
Michel Veillette
John Voisine
H.A. Wall

Organization Represented:

Georgia Power
Underwriters Laboratories, Inc.
Itron, Inc.
GE Energy
Florida Power & Light Co.
Public Service Electric & Gas
Radian Research, Inc.
Milbank Manufacturing
Technology for Energy Corporation
Schweitzer Engineering Labs, Inc.
Oncor Group
Center for Neighborhood Technology
Austin Energy
Future DOS R&D Inc.
Duke Energy Company
Natl Inst. of Standards & Technology
Pacific Gas & Electric Company
Xcel Energy EMC
Plexus
EnerNex Corporation
Sensus Metering
Baltimore Gas & Electric Company
Tucker Engineering
Trilliant Networks, Inc.
Landis+Gyr
Watthour Engineering Co.

Scott Weikel
James West

Elster Electricity
Ameren

Working Group 1 of Subcommittee 17 that developed the Standard consisted of:

Ed Beroset, Chairman
Richard Tucker, Vice Chairman
Michel Veillette, Editor
Paul Orr, Secretary—NEMA Staff

Name of Representative:

Michael Anderson
Norbert Balko
Ed Beroset
Bill Beverly
William Buckley
Martin Burns
Brent Cain
Richard Coblens
Raymond Gaudreault
Derek Gibbs
Ken Gilmer
Greg Gomez
David Haynes
Mark Iacoviello
Janice Jennings
Jean Joly
Brad Johnson
Lawrence Kotewa
Jacques Ledoux
Keith Martin
Peter Martin
Ed May
Bill Mazza
Robert McMichael
Avygdor Moise
John Newbury
Dan Nordell
Vuong Nguyen
James Pace
Terry Penn
Marc Purc
Bin Qiu
Wesley Ray
Jeff Richardson
Bill Rush
Ruben Salazar
Chris Schafer
Robby Simpson
Kendall Smith
Aaron Snyder
John Taylor
Richard Tucker
Michel Veillette
Ted York
Virginia Zinkowski

Organization Represented:

Landis+Gyr
Invensys Metering Systems
Elster Electricity
Austin International Inc.
Consultant for Itron, Inc
Hypertek Inc. for EPRI
Itron, Inc.
Schlumberger Electricity
C-MAC
Smartsynch
Itron, Inc.
Badger Meter
Aclara
Distribution Control Systems
Schlumberger Electricity
Hydro-Quebec
Oncor
Center for Neighborhood Technology
Trilliant Networks, Inc.
Tantalus Systems Corp.
Distribution Control Systems, Inc.
Itron, Inc.
Invensys Metering Systems
Itron, Inc.
Future DOS R&D Inc.
Open University
Northern States Power Co.
Measurement Canada
Silver Springs Networks
Southern Company
Schlumberger
Landis+Gyr, Inc
Duke Energy Corp.
Elster Metering
IGT
Landis+Gyr
Itron Inc.
GE Energy
Hexagram
EnerNex Corporation
American Innovations
Tucker Engineering
Trilliant Networks, Inc.
THY Consulting
GE Energy

This page intentionally left blank.

Protocol Specification For Interfacing To Data Communication Networks**1 Scope**

Initially, communications with electronic devices consisted of transporting memory data via proprietary protocols that were unique to each manufacturer. The desire for interoperability and support for multiple manufacturers by reading and programming systems created a need for standardization of data formats and transport protocols.

The first step was to standardize data formats. Internal data was abstracted as a set of Tables. A set of standard Table contents and formats were defined in ANSI C12.19, "Utility Industry End Device Data Tables."

In the "Protocol Specification for ANSI Type 2 Optical Port" (ANSI C12.18) Standard, a point-to-point protocol was developed to transport table data over an optical connection. The ANSI C12.18 protocol included an application language called Protocol Specification for Electric Metering (PSEM) that allowed applications to read and write Tables. The "Protocol Specification for Telephone Modem Communication" (ANSI C12.21) was then developed to allow devices to use PSEM to transport Tables over telephone modems.

This Standard extends on the concepts of the ANSI C12.18, ANSI C12.19 and the ANSI C12.21 standards to allow transport of Table data over any reliable networking communications system. Note that in this use of the word, "reliable" means that for every message sent, the sender receives a response at its option: either a positive acknowledgement or an error message. That is, messages cannot fail silently in a reliable network (see discussion of Reliable Stream Transport Service in [IPPA : 1995]).

In addition, this Standard describes an optionally exposed point-to-point interface between a C12.22 Device and a C12.22 Communications Module designed to attach to "any" network.

Furthermore, this Standard defines a methodology to capture, translate and transmit one way device messages (blurts).

This Standard defines interfaces between ANSI C12.19 Devices and network protocols.

Specific goals identified by the committee in the creation of this Standard were:

1. Defining a Datagram that may convey ANSI C12.19 data Tables through any network

This was accomplished by:

- Assuming that the data source is ANSI C12.19 data Tables
- Defining the Application Layer services (language)

2. Providing a full stack definition for interfacing a C12.22 Device to a C12.22 Communication Module

This was accomplished by:

- Defining the physical interface requirements between the C12.22 Device and the C12.22 Communication Module
- Defining the interface lower layers; 4 (transport), 3 (network), 2 (data link) and 1 (physical)