

**Design Guide for the Use of
ASTM A1035/A1035M Grade 100 (690)
Steel Bars for Structural Concrete**

Reported by ACI Innovation Task Group 6



American Concrete Institute®



First Printing
August 2010

American Concrete Institute®
Advancing concrete knowledge

Design Guide for the Use of ASTM A1035/A1035M Grade 100 (690) Steel Bars for Structural Concrete

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI. Proper use of this document includes periodically checking for errata at www.concrete.org/committees/errata.asp for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Order information: ACI documents are available in print, by download, on CD-ROM, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised *ACI Manual of Concrete Practice* (MCP).

**American Concrete Institute
38800 Country Club Drive
Farmington Hills, MI 48331
U.S.A.**

**Phone: 248-848-3700
Fax: 248-848-3701**

www.concrete.org

Design Guide for the Use of ASTM A1035/A1035M Grade 100 (690) Steel Bars for Structural Concrete

Reported by ACI Innovation Task Group 6

Paul Zia
Chair

Adam S. Lubell
Secretary

S. K. Ghosh
Andres Lepage
Kenneth A. Luttrell
Robert F. Mast

Conrad Paulson
Henry G. Russell
Joseph C. Sanders

The committee members of ITG-6 would like to thank Wiss, Janey, Elstner Associates, Inc. (WJE) and M. Dawood for their contributions to this document.

This guide provides recommendations on design provisions for the use of ASTM A1035/ASTM1035M Grade 100 (690) deformed steel bars for reinforced concrete members. The recommendations address only those requirements of ACI 318-08 that limit efficient use of such steel bars. Other code requirements are not affected.

This guide includes a discussion of the material characteristics of Grade 100 (690) ASTM A1035/A1035M deformed steel bars and recommends design criteria for beams, columns, slab systems, walls, and footings for Seismic Design Category (SDC) A, B, or C, and also for structural components not designated as part of the seismic-force-resisting system for SDC D, E, or F.

Keywords: bar; concrete; design; guide; high-strength steel; structural.

CONTENTS

Chapter 1—Introduction, p. 2

- 1.1—Objective
- 1.2—Scope
- 1.3—Historical perspective and background
- 1.4—Availability

Chapter 2—Notation and definitions, p. 4

- 2.1—Notation
- 2.2—Definitions

Chapter 3—Material properties, p. 5

- 3.1—Introduction
- 3.2—Weights, dimensions, and deformations
- 3.3—Specified tensile properties
- 3.4—Actual tensile properties
- 3.5—Actual compressive properties
- 3.6—Chemical composition

Chapter 4—Beams, p. 9

- 4.1—Introduction
- 4.2—Flexural strength
- 4.3—Tension- and compression-controlled limits
- 4.4—Strength reduction factor ϕ
- 4.5—Stress in steel due to flexure
- 4.6—Compression stress limit
- 4.7—Moment redistribution
- 4.8—Deflection
- 4.9—Crack control
- 4.10—Minimum reinforcement
- 4.11—Strength design for shear

Chapter 5—Columns, p. 14

- 5.1—Introduction
- 5.2—Specified yield strength for longitudinal reinforcement
- 5.3—Specified yield strength for transverse reinforcement
- 5.4—Slenderness effect

Chapter 6—Slab systems, p. 15

- 6.1—One-way slabs
- 6.2—Shear design of one-way slabs
- 6.3—Two-way slabs

ACI Committee Reports, Guides, Manuals, and Commentaries are intended for guidance in planning, designing, executing, and inspecting construction. This document is intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. The American Concrete Institute disclaims any and all responsibility for the stated principles. The Institute shall not be liable for any loss or damage arising therefrom.

Reference to this document shall not be made in contract documents. If items found in this document are desired by the Architect/Engineer to be a part of the contract documents, they shall be restated in mandatory language for incorporation by the Architect/Engineer.

ACI ITG-6R-10 was adopted and published August 2010.
Copyright © 2010, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

Chapter 7—Walls, p. 15

- 7.1—Introduction
- 7.2—Vertical reinforcement
- 7.3—Horizontal reinforcement
- 7.4—Shear reinforcement
- 7.5—Minimum reinforcement

Chapter 8—Footings and pile caps, p. 16

- 8.1—Design

Chapter 9—Mat foundations, p. 16

- 9.1—Design

Chapter 10—Other design considerations, p. 16

- 10.1—Seismic design limitations
- 10.2—Development and lap splice length
- 10.3—Mechanically spliced bars and headed bars
- 10.4—Bending and welding of bars
- 10.5—Use of ASTM A1035/A1035M bars with ASTM A615/A615M bars

Chapter 11—Summary, p. 18**Chapter 12—References, p. 19**

- 12.1—Referenced standards and reports
- 12.2—Cited references

Appendix A—Design examples, p. 22

- A.1—Introduction
- A.2—Design examples

Appendix B—Flexural analysis using nonlinear stress-strain curve of ASTM A1035/A1035M Grade 100 (690) reinforcement, p. 80

- B.1—Introduction
- B.2—Design assumptions
- B.3—Spreadsheet implementation
- B.4—Design examples

Appendix C—Flexural behavior of beams reinforced with ASTM A1035/A1035M bars, p. 88**CHAPTER 1—INTRODUCTION****1.1—Objective**

This guide provides design provisions for the use of ASTM A1035/A1035M Grade 100 (690) deformed steel bars for reinforced concrete structural members. This guide addresses only those requirements in ACI 318-08 that limit the more efficient use of such steel bars, and should not affect the application of other code requirements.

1.2—Scope

This guide includes a discussion of the material characteristics of ASTM A1035/A1035M steel bars and recommends design criteria for beams, columns, slab systems, walls, and footings for Seismic Design Category (SDC) A, B, or C. For a lack of adequate data, the application of this guide for SDC D, E, or F is limited to slab systems, foundations, and structural components not designated as part of the seismic-force-resisting system but explicitly checked for the induced

effects of the design displacements. The only exception is the use of transverse reinforcement for concrete confinement with a specified yield strength, f_y , up to 100,000 psi (690 MPa) for special moment frames, special structural walls, and coupling beams as permitted by Section 21.1.5.4 of ACI 318-08. Refer to Section 10.1 of this guide for more information on seismic design considerations. Shells and folded plate members and prestressed concrete are beyond the scope of this guide. Design examples are included to illustrate design procedures and proper application of the design criteria. Modifications to these design criteria may be justified where the design adequacy within the scope of this guide is demonstrated by successful use, analysis, or test.

1.3—Historical perspective and background

For several decades, the design of structural concrete was restricted to using specified yield strength, f_y , of 60,000 psi (410 MPa) or less for reinforcing bars. Section A603(e) of ACI 318-56 specified that “Stress in tensile and compressive reinforcement at ultimate load shall not be assumed greater than the yield point or 60,000 psi, whichever is smaller.”

Section 1505 of ACI 318-63, specified two requirements:

“(a) When reinforcement is used that has a yield strength, f_y , in excess of 60,000 psi, the yield strength to be used in design shall be reduced to $0.85f_y$ or 60,000 psi, whichever is greater, unless it is shown by tension tests that at a proof stress equal to the specified yield strength, f_y , the strain does not exceed 0.003;

(b) Designs shall not be based on a yield strength, f_y , in excess of 75,000 psi. Design of tension reinforcement shall not be based on a yield strength, f_y , in excess of 60,000 psi unless tests are made in compliance with Section 1508(b).”

The Commentary on Section 1505 of ACI 318-63 states that “This section provides limitations on the use of high strength steels to assure safety and satisfactory performance. High strength steels frequently have a strain at yield strength or yield point in excess of the 0.003 assumed for the concrete at ultimate. The requirements of Section 1505(a) are to adjust to this condition.

The maximum stress in tension of 60,000 psi without test is to control cracking. The absolute maximum is specified as 75,000 psi to agree with present ASTM specifications and as a safeguard until there is adequate experience with the high stresses.”

Then the Commentary on Section 1508 of ACI 318-63 states that

“When the design yield point of tension reinforcement exceeds 60,000 psi, detailing for crack control becomes even more important. Entirely acceptable structures have been built, particularly in Sweden, with a design yield strength approaching 100,000 psi but more design criteria for crack control and considerable American practical experience with 60,000 psi yield strength tension reinforcement are needed before higher yield strengths are approved