

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**High-voltage test techniques –  
Part 1: General definitions and test requirements**

**Technique des essais à haute tension –  
Partie 1: Définitions et exigences générales**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00

---

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tél.: +41 22 919 02 11  
Fax: +41 22 919 03 00



IEC 60060-1

Edition 3.0 2010-09

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**High-voltage test techniques –  
Part 1: General definitions and test requirements**

**Technique des essais à haute tension –  
Partie 1: Définitions et exigences générales**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE **XB**  
CODE PRIX

---

ICS 17.220.20

ISBN 978-2-88912-185-4

## CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	7
3.1 Definitions related to characteristics of discharges .....	8
3.2 Definitions relating to characteristics of the test voltage .....	8
3.3 Definitions relating to tolerance and uncertainty .....	9
3.4 Definitions relating to statistical characteristics of disruptive-discharge voltage values .....	9
3.5 Definitions relating to classification of insulation in test objects .....	10
4 General requirements .....	11
4.1 General requirements for test procedures.....	11
4.2 Arrangement of the test object in dry tests .....	11
4.3 Atmospheric corrections in dry tests .....	12
4.3.1 Standard reference atmosphere.....	12
4.3.2 Atmospheric correction factors for air gaps .....	12
4.3.3 Application of correction factors.....	13
4.3.4 Correction factor components .....	13
4.3.5 Measurement of atmospheric parameters .....	16
4.3.6 Conflicting requirements for testing internal and external insulation.....	17
4.4 Wet tests .....	18
4.4.1 Wet test procedure .....	18
4.4.2 Atmospheric corrections for wet tests .....	19
4.5 Artificial pollution tests .....	19
5 Tests with direct voltage .....	19
5.1 Definitions for direct voltage tests.....	19
5.2 Test voltage .....	20
5.2.1 Requirements for the test voltage .....	20
5.2.2 Generation of the test voltage.....	20
5.2.3 Measurement of the test voltage.....	20
5.2.4 Measurement of the test current .....	21
5.3 Test procedures .....	21
5.3.1 Withstand voltage tests .....	21
5.3.2 Disruptive-discharge voltage tests .....	22
5.3.3 Assured disruptive-discharge voltage tests .....	22
6 Tests with alternating voltage .....	22
6.1 Definitions for alternating voltage tests.....	22
6.2 Test Voltage.....	22
6.2.1 Requirements for the test voltage .....	22
6.2.2 Generation of the test voltage.....	23
6.2.3 Measurement of the test voltage.....	24
6.2.4 Measurement of the test current .....	25
6.3 Test procedures .....	25
6.3.1 Withstand voltage tests .....	25
6.3.2 Disruptive-discharge voltage tests .....	25
6.3.3 Assured disruptive-discharge voltage tests .....	25

7	Tests with lightning-impulse voltage .....	26
7.1	Definitions for lightning-impulse voltage tests .....	26
7.2	Test Voltage .....	33
7.2.1	Standard lightning-impulse voltage .....	33
7.2.2	Tolerances .....	34
7.2.3	Standard chopped lightning-impulse voltage .....	34
7.2.4	Special lightning-impulse voltages .....	34
7.2.5	Generation of the test voltage .....	34
7.2.6	Measurement of the test voltage and determination of impulse shape .....	34
7.2.7	Measurement of current during tests with impulse voltages .....	35
7.3	Test Procedures .....	35
7.3.1	Withstand voltage tests .....	35
7.3.2	Procedures for assured disruptive-discharge voltage tests .....	36
8	Tests with switching-impulse voltage .....	36
8.1	Definitions for switching-impulse voltage tests .....	36
8.2	Test voltage .....	38
8.2.1	Standard switching-impulse voltage .....	38
8.2.2	Tolerances .....	38
8.2.3	Time-to-peak evaluation .....	38
8.2.4	Special switching-impulse voltages .....	38
8.2.5	Generation of the test voltage .....	38
8.2.6	Measurement of test voltage and determination of impulse shape .....	39
8.2.7	Measurement of current during tests with impulse voltages .....	39
8.3	Test procedures .....	39
9	Tests with combined and composite voltages .....	39
9.1	Definitions for combined- and composite-voltage tests .....	39
9.2.4	Tolerances .....	42
9.2.5	Generation .....	42
9.2.6	Measurement .....	42
9.3	Composite test voltages .....	43
9.3.1	Parameters .....	43
9.3.2	Tolerances .....	43
9.3.3	Generation .....	43
9.3.4	Measurement .....	43
9.4	Test procedures .....	43
	Annex A (informative) Statistical treatment of test results .....	45
	Annex B (normative) Procedures for calculation of parameters of standard lightning-impulse voltages with superimposed overshoot or oscillations .....	54
	Annex C (informative) Guidance for implementing software for evaluation of lightning-impulse voltage parameters .....	59
	Annex D (informative) Background to the introduction of the test voltage factor for evaluation of impulses with overshoot .....	62
	Annex E (informative) The iterative calculation method in the converse procedure for the determination of atmospheric correction factor .....	68
	Bibliography .....	73

Figure 1 – Recommended minimum clearance  $D$  of extraneous live or earthed objects to the energized electrode of a test object, during an a.c. or positive switching impulse test at the maximum voltage  $U$  applied during test .....

Figure 2 – $k$ as a function of the ratio of the absolute humidity $h$ to the relative air density $\rho$ (see 4.3.4.2 for limits of applicability) .....	14
Figure 3 – Values of exponents $m$ and $w$ .....	16
Figure 4 – Absolute humidity of air as a function of dry- and wet-bulb thermometer readings .....	17
Figure 5 – Full lightning-impulse voltage .....	26
Figure 6 – Test voltage function.....	28
Figure 7 – Full impulse voltage time parameters .....	29
Figure 8 – Voltage time interval .....	30
Figure 9 – Voltage integral.....	30
Figure 10 – Lightning-impulse voltage chopped on the front.....	31
Figure 11 – Lightning-impulse voltage chopped on the tail .....	32
Figure 12 – Linearly rising front chopped impulse .....	32
Figure 13 – Voltage/time curve for impulses of constant prospective shape .....	33
Figure 14 – Switching-impulse voltage .....	37
Figure 15 – Circuit for a combined voltage test .....	40
Figure 16 – Schematic example for combined and composite voltage .....	41
Figure 17 – Circuit for a composite voltage test .....	42
Figure 18 – Definition of time delay $\Delta t$ .....	43
Figure A.1 – Example of a multiple-level (Class 1) test .....	48
Figure A.2 – Examples of decreasing and increasing up-and-down (Class 2) tests for determination of 10 % and 90 % disruptive-discharge probabilities respectively.....	49
Figure A.3 – Examples of progressive stress (Class 3) tests .....	50
Figure B.1 – Recorded and base curve showing overshoot and residual curve.....	55
Figure B.2 – Test voltage curve (addition of base curve and filtered residual curve).....	55
Figure B.3 – Recorded and test voltage curves .....	56
Figure D.1 – “Effective” test voltage function in IEC 60060-1:1989.....	63
Figure D.2 – Representative experimental points from European experiments and test voltage function .....	65
Figure E.1 – Atmospheric pressure as a function of altitude.....	69
Table 1 – Values of exponents, $m$ for air density correction and $w$ for humidity correction, as a function of the parameter $g$ .....	15
Table 2 – Precipitation conditions for standard procedure .....	19
Table A.1– Discharge probabilities in up-and-down testing .....	52
Table E.1 – Altitudes and air pressure of some locations .....	69
Table E.2 – Initial $K_t$ and its sensitivity coefficients with respect to $U_{50}$ for the example of the standard phase-to-earth a.c. test voltage of 395 kV .....	70
Table E.3 – Initial and converged $K_t$ values for the example of the standard phase-to-earth a.c. test voltage of 395 kV .....	72

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**HIGH-VOLTAGE TEST TECHNIQUES –****Part 1: General definitions and test requirements**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60060-1 has been prepared by IEC technical committee 42: High-voltage test techniques.

This third edition of IEC 60060-1 cancels and replaces the second edition, published in 1989, and constitutes a technical revision.

The significant technical changes with respect to the previous edition are as follows:

- a) The general layout and text was updated and improved to make the standard easier to use.
- b) Artificial pollution test procedures were removed as they are now described in IEC 60507.
- c) Measurement of impulse current has been transferred to a new standard on current measurement (IEC 62475).
- d) The atmospheric correction factors are now presented as formulas.

- e) A new method has been introduced for the calculation of the time parameters of lightning impulse waveforms. This improves the measurement of the time parameters of lightning impulses with oscillations or overshoot.

The text of this standard is based on the following documents:

FDIS	Report on voting
42/277/FDIS	42/282/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2

A list of all the parts in the IEC 60060 series, under the general title *High-voltage test techniques*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to this specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition or
- amended.

## HIGH-VOLTAGE TEST TECHNIQUES –

### Part 1: General definitions and test requirements

#### 1 Scope

This part of IEC 60060 is applicable to:

- dielectric tests with direct voltage;
- dielectric tests with alternating voltage;
- dielectric tests with impulse voltage;
- dielectric tests with combinations of the above.

This part is applicable to tests on equipment having its highest voltage for equipment  $U_m$  above 1 kV.

NOTE 1 Alternative test procedures may be required to obtain reproducible and significant results. The choice of a suitable test procedure should be made by the relevant Technical Committee.

NOTE 2 For voltages  $U_m$  above 800 kV meeting some specified procedures, tolerances and uncertainties may not be achievable.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60507:1991, *Artificial pollution tests on high-voltage insulators to be used on a.c. systems*

IEC 61083-1, *Instruments and software used for measurement in high-voltage impulse tests – Part 1: Requirements for instruments*

IEC 61083-2, *Digital recorders for measurements in high-voltage impulse tests – Part 2: Evaluation of software used for the determination of the parameters of impulse waveforms*

IEC 62475, *High-current test techniques: Definitions and requirements for test currents and measuring systems*

#### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.