

ACI 117.1R-14

Guide for Tolerance Compatibility in Concrete Construction

Reported by ACI Committee 117



American Concrete Institute
Always advancing



Guide for Tolerance Compatibility in Concrete Construction

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, on CD-ROM, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised ACI Manual of Concrete Practice (MCP).

American Concrete Institute
38800 Country Club Drive
Farmington Hills, MI 48331
Phone: +1.248.848.3700
Fax: +1.248.848.3701

www.concrete.org

Guide for Tolerance Compatibility in Concrete Construction

Reported by ACI Committee 117

Scott M. Anderson, Chair

Bryan M. Birdwell, Secretary

Scott Anderson
Karl J. Bakke
David K. Ballast*
Gregory P. Birley
David W. Buzzelli
Darrell L. Darrow
Thomas J. Downs
Ron Eldridge*
Allen Face
Mark G. Josten*

Geoffrey R. Kinney
Richard L. Knox*
Kevin R. Koogle
Michael W. Lee
Ross S. Martin
Arthur W. McKinney
Colin T. Milberg*
William R. Nash*
Eric S. Peterson
William S. Phelan

Peter J. Ruttura
Michael J. Schneider
Bruce A. Suprenant
Brett A. Szabo
Eldon G. Tipping
Michael A. West*
Scott C. Winkler

Richard A. Kaden
W. Calvin McCall
Steven R. Raupp

*Task group members.

Special acknowledgment to Ward Malisch for his contribution to this guide.

Consulting Members
Charles J. Carter

This guide lists industry-standard tolerances and presents recommendations for mitigating tolerance conflicts related to embedded items, elevator cores and hoistways, openings in slabs and walls, manufactured couplers and splicing systems for reinforcing bars, stairs, cladding systems, infill wall systems, surface accessibility components, finish floor coverings, and expansion joints. Evaluating tolerance compatibility can be challenging due to the variety of materials, products, and elements that interface with, or connect to, concrete construction. Failure to accommodate these varying tolerances could have a significant impact on construction quality, cost, and schedules. Architects and engineers can use these guide recommendations to accommodate individual material, product, and element tolerances at their interface with concrete construction. Contractors can use these guide recommendations to mitigate tolerance conflicts during the construction phase.

The materials, processes, quality control measures, and inspections described in this document should be tested, monitored, or performed as applicable only by individuals holding the appropriate ACI Certifications or equivalent.

Keywords: construction; embedded items; foundation; reinforced concrete; specification; tolerance; tolerance compatibility.

ACI Committee Reports, Guides, and Commentaries are intended for guidance in planning, designing, executing, and inspecting construction. This document is intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. The American Concrete Institute disclaims any and all responsibility for the stated principles. The Institute shall not be liable for any loss or damage arising therefrom.

Reference to this document shall not be made in contract documents. If items found in this document are desired by the Architect/Engineer to be a part of the contract documents, they shall be restated in mandatory language for incorporation by the Architect/Engineer.

CONTENTS

CHAPTER 1—INTRODUCTION AND SCOPE, p. 2

- 1.1—Introduction, p. 2
- 1.2—Scope, p. 2
- 1.3—Unit conversions, p. 2

CHAPTER 2—DEFINITIONS, p. 2

- 2.1—Definitions, p. 2

CHAPTER 3—TOLERANCE COORDINATION AND RESPONSIBILITY, p. 3

- 3.1—Tolerance coordination meetings, p. 3
- 3.2—Responsibilities, p. 3
- 3.3—Review and approval, p. 4
- 3.4—Measurements, p. 4

CHAPTER 4—CREATING TOLERANCE COMPATIBILITY, p. 5

- 4.1—Steps toward tolerance compatibility, p. 5
- 4.2—More restrictive tolerances, p. 5
- 4.3—Tolerance limit considerations, p. 6
- 4.4—Coordinating architectural layouts with structural framing, p. 8
- 4.5—Communicating information, p. 11

ACI 117.1R-14 was adopted and published August 2014.

Copyright © 2014, American Concrete Institute

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

CHAPTER 5—TOLERANCES AND METHODS OF ACCOMMODATING TOLERANCES, p. 11

- 5.2—Elevator cores and hoistways, p. 16
- 5.3—Openings in slabs and walls, p. 17
- 5.4—Manufactured couplers and splicing systems for reinforcing bars, p. 22
- 5.5—Cast-in-place stairs, p. 23
- 5.6—Cladding systems, p. 24
- 5.7—Infill wall systems, p. 37
- 5.8—Surface accessibility, p. 41
- 5.9—Finish floor coverings, p. 43
- 5.10—Expansion joints, p. 44

CHAPTER 6—REFERENCES, p. 45

Cited references, p. 46

CHAPTER 1—INTRODUCTION AND SCOPE

1.1—Introduction

Evaluating tolerance compatibility at the interface between concrete and other building systems is challenging because materials, products, and elements that connect to the concrete often have tolerances that differ from those for concrete. Coordinating these different tolerances early in the project reduces problems that can impact quality, cost, and schedule during construction.

Architects and engineers can use the recommendations in this guide to accommodate individual material, product, and element tolerances at their interface with concrete construction. Contractors can use the recommendations in this guide to mitigate tolerance conflicts during the construction phase. To assist the architect, engineer, and contractor, this guide lists industry-standard tolerances and presents recommendations for mitigating tolerance conflicts related to embedded items, elevator cores and hoistways, openings in slabs and walls, manufactured couplers and splicing systems for reinforcing bars, stairs, cladding systems, infill wall systems, surface accessibility components, finish floor coverings, and expansion joints. This guide does not list all concrete or industry tolerances or all potential tolerance conflicts.

1.2—Scope

Tolerances for concrete construction from ACI 117 and other industry standards developed by trade and standards-writing organizations are discussed. Tolerances and suggested methods of mitigating tolerance conflicts for common concrete construction procedures and typical construction materials that interface with or connect to concrete elements are described. This guide is not intended to apply to special structures, such as nuclear reactors and containment vessels, bins, prestressed circular structures, thin shell structures, and single-family residential construction. Construction projects may require tolerances that are less or more stringent than contained in this guide.

1.3—Unit conversions

Hard conversions are used throughout this guide. Where individual trade or standards-writing organizations have




Fig. 2.1—Flatness and levelness.

established a specific SI equivalent to inch-pound units, the value determined by the organization is used. The equivalent SI units for the same inch-pound unit from different sources could be different. Use the units and tolerances specified in the construction documents. If the drawings are in one system of measurement and the tolerances are in another, a soft conversion is acceptable but should not exceed the published tolerance.

CHAPTER 2—DEFINITIONS

2.1—Definitions

ACI provides a comprehensive list of definitions through an online resource, “ACI Concrete Terminology,” <http://www.concrete.org/Tools/ConcreteTerminology.aspx>. Definitions provided herein complement that resource.

anchor bolt—Refer to ACI Concrete Terminology. See **rod, anchor**.

assembly tolerance—overall tolerance for the assembly of components.

bearing devices—shop-attached base and bearing plates; loose base and bearing plates; and leveling devices, such as leveling plates, leveling nuts and washers, and leveling screws.

component tolerance—permitted deviation for a single component.

curtain wall—cladding system installed on the exterior of the primary building structure and carrying no loads other than its self-weight, wind, or seismic loads.

datum—ideal geometric point, line, or plane used to define the location or orientation of a constructed work.

envelope tolerance—boundary defining the permitted deviation for any accumulation of tolerances on a feature, component, or assembly.

erection tolerance—permitted deviation in the orientation or location of a component resulting from its erection or installation.

fabrication tolerance—permitted deviation from the specified dimensions or shape for a manufactured product.

feature—geometric aspect of an element, such as a surface, edge, line, centerline, median plane, corner, or center point.

flatness—deviation of a surface from a plane. (Fig. 2.1)

levelness—deviation of a line or surface from a horizontal line or surface. (Fig. 2.1)

location tolerance—permitted deviation in position relative to a datum.