

IEEE Guide for Dry-Type Transformer Through-Fault Current Duration

IEEE Power and Energy Society

Sponsored by the
Transformers Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std C57.12.59™-2015
(Revision of
IEEE Std C57.12.59-2001)

IEEE Guide for Dry-Type Transformer Through-Fault Current Duration

Sponsor

Transformers Committee

IEEE Power and Energy Society

Approved 3 September 2015

IEEE-SA Standards Board

Abstract: Recommendations believed essential for the application of overcurrent protective devices that limit the exposure time of dry-type transformers to short-circuit currents are set forth in this guide. This guide is not intended to imply overload capability.

Keywords: dry-type transformers, fault current, IEEE C57.12.59™, mechanical damage, mechanical duty, normal base current, short-circuit current, short-circuit impedance, thermal damage

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2015 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 6 November 2015. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-9867-5 STD20338
Print: ISBN 978-0-7381-9868-2 STDPD20338

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be *considered* or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE guide was completed, the DC Circuit Breaker Working Group had the following membership:

Paulette Payne Powell, *Chair*
Bipin Patel, *Vice Chair*

Timothy Holdway

Charles Johnson

Richard Marek

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Samuel Aguirre
I. Antweiler
Donald Ayers
Robert Ballard
Barry Beaster
Steven Bezner
Wallace Binder
Thomas Bishop
Thomas Blackburn
William Bloethe
Carl Bush
Thomas Callsen
Paul Cardinal
Suresh Channarasappa
John Crouse
Ray Davis
Dieter Dohnal
Gary Donner
Donald Dunn
Jorge Fernandez Daher
Joseph Foldi
Marcel Fortin
Derek Foster
Robert Ganser
Carlos Gaytan
Frank Gerleve

David Gilmer
Jalal Gohari
Edwin Goodwin
Randall Groves
Ajit Gwal
Michael Haas
Timothy Holdway
Jill Holmes
Philip Hopkinson
Mohammad Iman
Richard Jackson
Charles Johnson
Laszlo Kadar
Sheldon Kennedy
Yuri Khersonsky
Jim Kulchisky
Marc Lacroix
Chung-Yiu Lam
Aleksandr Levin
Richard Marek
John Miller
Daniel Mulkey
Jerry Murphy
K. R. M. Nair
Martin Navarro
Michael Newman

Raymond Nicholas
Mirko Palazzo
Klaus Papp
Bansi Patel
Wesley Patterson
Paulette Payne Powell
Branimir Petosic
Christopher Petrola
Alvaro Portillo
Lewis Powell
Iulian Profir
Michael Roberts
Charles Rogers
Joseph Rostron
Thomas Rozek
Bartien Sayogo
Jerry Smith
David Stankes
Kerwin Stretch
David Tepen
James Thompson
John Vergis
Kenneth White
Jennifer Yu
Jian Yu

When the IEEE-SA Standards Board approved this guide on 3 September 2015, it had the following membership:

John D. Kulick, *Chair*
Jon Walter Rosdahl, *Vice Chair*
Richard H. Hulett, *Past Chair*
Konstantinos Karachalios, *Secretary*

Masayuki Ariyoshi
Ted Burse
Stephen Dukes
Jean-Philippe Faure
J. Travis Griffith
Gary Hoffman
Michael Janezic

Joseph L. Keopfinger*
David Law
Hung Ling
Andrew Myles
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Annette D. Reilly

Stephen J. Shellhammer
Adrian P. Stephens
Yatin Trivedi
Philip Winston
Don Wright
Yu Yuan
Daidi Zhong

*Member Emeritus

Introduction

This introduction is not part of IEEE Std C57.12.59™-2015, IEEE Guide for Dry-Type Transformer Through-Fault Current Duration.

This guide provides recommendations for the application of overcurrent protection devices to limit the exposure time of dry-type transformers to short circuits. It shall not be confused with IEEE Std C57.109™, IEEE Guide for Liquid-Immersed Transformer Through-Fault Current Duration, which applies only to liquid-immersed transformers.

Dry-type transformers differ significantly from liquid-immersed types in several respects:

- a) There are significant variations in dry-type winding constructions, including conventional varnish impregnated layered windings, vertically stacked varnish-impregnated disk windings, solid cast windings, and combinations thereof, all of which have different transient heating characteristics during time intervals greater than about 100 s.
- b) The transient heating of liquid-immersed transformer windings is considerably buffered by the insulating medium in which the windings are immersed, providing a relatively long thermal time constant as compared to dry-type transformers.

Because of the foregoing, the through-fault protection curves for dry-type transformers are limited to overload time intervals of 100 s or less. No one curve for longer time intervals would characterize the thermal performance of all the different dry-type transformer constructions and temperature ratings. Moreover, such curves are not known or, at least, not available. Consequently, the curves in this guide pertain to the temperature rise of the windings during time intervals less than 100 s, wherein nearly all the heat generated is stored in the conductors. For longer time intervals, it is recommended that reference be made to IEEE Std C57.96™ [B1], IEEE Guide for Loading Dry-Type Distribution and Power Transformers.

As short-circuit time intervals become progressively less than 100 s, mechanical considerations become more important than thermal characteristics.

Short-circuit performance characteristics are contained in IEEE Std C57.12.01™. This guide supplements that information, but in no way supersedes it.

The substantive revisions of this guide include expansion of the scope to include Category III transformers. The basis for the equations and the thermal and mechanical damage curves of [Figure 1](#), [Figure 2](#), and [Figure 3](#) were developed and are detailed in [Annex A](#). [Figure 2a](#) was corrected for consistency with the details of [Annex A](#).

Contents

1. Overview.....	10
1.1 Scope.....	10
1.2 Purpose.....	10
1.3 General.....	10
2. Normative references	11
3. Definitions.....	11
4. Transformer coordination.....	11
4.1 General transformer coordination.....	11
4.2 Category I transformers	13
4.3 Category III transformers	14
Annex A (informative) Basis for through-fault protection.....	16
Annex B (informative) Bibliography.....	19

IEEE Guide for Dry-Type Transformer Through-Fault Current Duration

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This guide for dry-type transformer through-fault current duration applies to dry-type distribution and power transformers built in accordance with IEEE Std C57.12.01™.¹

1.2 Purpose

This guide sets forth recommendations believed essential for the application of overcurrent protective devices that limit the exposure time of dry-type transformers to short-circuit currents. This guide is not intended to imply overload capability.

1.3 General

Protective devices, such as relays and fuses, have well-defined operating characteristics that relate fault magnitude to clearing time. It is desirable that these characteristic curves be coordinated with comparable curves applicable to dry-type transformers that relate duration and fault magnitude to withstand capability.

The magnitude and duration of fault currents are of utmost importance in establishing a coordinated protection practice for transformers, as both mechanical and thermal effects of fault currents shall be considered. For fault-current magnitudes near the maximum short-circuit current rating of the transformer, mechanical effects are more significant than thermal effects. The maximum symmetrical short-circuit current should not exceed

¹Information on references can be found in [Clause 2](#).