

IEEE Guide for Differential and Polarizing Relay Circuit Testing

IEEE Power and Energy Society

Sponsored by the
Power System Relaying Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std C37.103™-2015
(Revision of
IEEE Std C37.103-2004)

IEEE Std C37.103™-2015

(Revision of
IEEE Std C37.103-2004)

IEEE Guide for Differential and Polarizing Relay Circuit Testing

Sponsor

Power System Relaying Committee
of the
IEEE Power and Energy Society

Approved 3 September 2015

IEEE-SA Standards Board

Abstract: The issues concerning testing and verification of the correctness of differential and polarizing circuits are described and discussed in this guide. The intention of this guide is to help the reader to detect errors in the wiring of protective relays that might cause erroneous operations of protection systems. It is essential to follow systematic testing procedures and record the observations in a proper organized manner. The records should include documentation of all measurements and a comparison with the desired results.

Keywords: differential protection, generator protection, IEEE C37.103™, line protection, polarized ground fault relays, polarized line protection relays, relay testing, transformer protection

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2015 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 17 December 2015. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-0090-9 STD20507
Print: ISBN 978-1-5044-0091-6 STDPD20507

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE guide was completed, the Differential and Polarizing Relay Circuit Testing Working Group had the following membership:

Gary Kobet, Chair
Alex Lee, Vice Chair

Rene Aguilar
Jason Buneo
Kernie Houser*
Cara Hutcherson

Gerald Johnson
Meyer Kao
Larry Oxford*
Cristian Padararu
Ryland Revelle

Mark Schroeder
Renee Stoll*
Jian-Cheng Tan*
Rene Tuballa*

*Corresponding member

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Ali Al Awazi
Jay Anderson
Thomas Barnes
Jeffrey Barsch
Robert Beresh
Martin Best
Wallace Binder
Chris Brooks
Gustavo Brunello
Paul Cardinal
Stephen Conrad
Randall Crellin
Randall Cunico
Alla Deronja
Gary Donner
Michael Dood
Frank Gerleve
Jalal Gohari

Stephen Grier
Randall Groves
Ajit Gwal
Roger Hedding
Jerry Hohn
James Kinney
Gary Kobet
Boris Kogan
Jim Kulchisky
Saumen Kundu
Chung-Yiu Lam
Albert Livshitz
Omar Mazzoni
William McBride
Jerry Murphy
R. Murphy
Edrin Murzaku
Rhonda Netzel

Michael Newman
James O'Brien
Subhash Patel
Farnoosh Rahmatian
Michael Roberts
Charles Rogers
Mohindar S. Sachdev
Bartien Sayogo
Thomas Schossig
Jerry Smith
Paul Sullivan
Michael Swearingen
Joe Uchiyama
Eric Udren
John Vergis
John Wang
Kenneth White
Philip Winston

When the IEEE-SA Standards Board approved this guide on 3 September 2015, it had the following membership:

John D. Kulick, Chair
Jon Walter Rosdahl, Vice Chair
Richard H. Hulett, Past Chair
Konstantinos Karachalios, Secretary

Masayuki Ariyoshi
Ted Burse
Stephen Dukes
Jean-Philippe Faure
J. Travis Griffith
Gary Hoffman
Michael Janezic

Joseph L. Koepfing*
David J. Law
Hung Ling
Andrew Myles
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Annette D. Reilly

Stephen J. Shellhamer
Adrian P. Stephens
Yatin Trivedi
Phillip Winston
Don Wright
Yu Yuan
Daidi Zhong

^Member Emeritus

Introduction

This introduction is not part of IEEE Std C37.103™-2015, IEEE Guide for Differential and Polarizing Relay Circuit Testing.

Errors in the wiring of connections to protective relays have caused erroneous operations of the associated protective schemes resulting in many serious power interruptions. In most cases, thorough testing would have discovered those incorrect connections. Ground relay polarizing and differential relay connections are the most troublesome and difficult to locate; therefore, this guide describes and discusses the issues concerning testing and verification of the correctness of these circuits.

This guide describes tests for helping to ensure correct differential and polarizing circuit connections. Relay calibration, setting, insulation, instrument transformer tests, etc., are also referred to in this guide, but it is assumed that the individual users have developed these tests, and therefore they are not discussed in detail. Methods for testing differential and polarizing circuits have never really been defined by the manufacturers because a large variety of ways in which differential and polarized circuits are applied in relay systems. Consequently, utilities develop their own testing techniques, which can vary widely depending on factors such as the availability of test switches, test gear, test philosophy, problems discovered in the past, and manpower. Good systematic testing should include systematic documentation of the tests and the test procedures. This should include documentation of all measurements and a comparison with the desired results.

Comments on the advantages and disadvantages of the different techniques are presented, and operating considerations for personnel and equipment are included. Since most of the circuit verification tests include passing current through either the current transformer primaries or secondaries, the voltage source to accomplish these tests varies. For primary testing that may include power transformer windings, the required source voltage will be substantial. For secondary testing, the source voltage may be relatively low. For some of these circuit tests, variable voltages are needed. In each case, the source is identified and noted on the figure involved.

Traditional electromechanical and solid-state differential relays made no provision for phase shifts in the transformers; the connections and wiring had to be arranged so that the normal load currents flowing into the respective primary and secondary “restraint” windings were 180° out of phase. Further, some current transformer (CT) connections were not possible without the use of wye-delta auxiliary CTs or a zero-sequence trap (see IEEE Std C57.13.1™)^{a, b, c}. Electromechanical and solid-state relays usually did not provide direct readout of the currents in the relays.

In contrast, present microprocessor relays compensate for the transformer/CT connections and provide readouts from a front panel human-machine interface (HMI) and/or via the relay communications port. This provision simplifies testing in three ways:

- The installation may be designed such that the CT secondary circuits are all connected in wye, making wiring checkout easier.
- Amplitude and phase of primary/secondary injection and load currents can be checked by interrogation of the relay via the HMI or from a portable computer via the relay communications port. The processing of the signals in the relay automatically takes into account the relationship between the restraint and operating currents that can be ascertained.
- The manufacturer usually provides a worksheet for entry of all the current and phase angle readings, which simplifies interpretation of the results.

^a Information on references can be found in Clause 2.

^b The IEEE standards or products referred to in this clause are trademarks of The Institute of Electrical and Electronics Engineers, Inc.

^c IEEE publications are available from The Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854.

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
2. Normative references.....	1
3. Definitions	2
4. Operating considerations for personnel and equipment.....	2
4.1 Primary testing.....	2
4.2 Secondary testing.....	3
4.3 Alternative to primary and secondary testing	3
4.4 Effect of opening CT circuits	3
4.5 CT short-circuiting devices.....	3
5. Preparatory tests	4
5.1 Protective relays	4
5.2 CTs	4
5.3 Wiring checks	4
5.4 Test switches	5
5.5 Test equipment	6
6. Power sources for tests	7
6.1 AC sources for primary current injection tests	7
6.2 AC sources for secondary current injection tests.....	7
6.3 DC current sources for primary and secondary injection tests	8
6.4 Test set capacity considerations.....	8
7. Generator, motor, and reactor differential relaying	8
7.1 Primary current injection tests	13
7.2 Secondary current injection tests	14
7.3 In-service tests	14
8. Bus differential relaying	15
8.1 Primary current injection tests	15
8.2 Secondary current injection tests	17
8.3 In-service tests	18
9. Transformer differential relaying	19
9.1 Primary current injection tests	20
9.2 Secondary current injection tests	24
9.3 In-service tests	26
10. Potential-polarized phase relays	27
10.1 Primary current injection tests	27
10.2 Secondary injection tests	28
10.3 In-service tests	32
11. Potential-polarized ground relays	33
11.1 Voltage-circuit secondary voltage injection test.....	33
11.2 In-service tests	35

12. Neutral-current-polarized ground relays.....	37
12.1 Primary current injection tests—primary of all CTs accessible.....	38
12.2 Primary current injection tests—primary of neutral CT not accessible	39
12.3 In-service tests for current-polarized relays.....	41
13. Tertiary current-polarized ground relays	43
13.1 Primary current injection tests—tertiary CTs not accessible, breaker CTs accessible	43
13.2 In-service tests	46
14. Transformer ground differential (restricted earth fault) relays	46
14.1 DC primary and secondary injection test.....	47
14.2 AC primary current injection test	48
14.3 In-service tests for transformer ground differential relays.....	52
14.4 Precautions for testing transformer ground differential relays	53
14.5 Initial installation of transformer ground differential relays.....	54
15. Conclusion.....	54
Annex A (informative) Aids to differential relay load checks.....	55
A.1 Numerical relay metering aid to injection and load tests	55
A.2 Differential relay load checks	55
A.3 Differential relay load check worksheet	56
A.4 Computing secondary injection test quantities for verification of numerical relays	57
Annex B (informative) Bibliography.....	64

IEEE Guide for Differential and Polarizing Relay Circuit Testing

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/TPR/disclaimers.html>.

1. Overview

1.1 Scope

This guide covers tests to help ensure correct connections of differential relays and polarizing circuits of phase and ground relays. Although other preparatory tests are mentioned in this guide, these tests are not discussed in detail.

1.2 Purpose

This guide provides a methodology to establish a systematic series of tests to verify the integrity and accuracy of connections of differential and polarizing circuits.

2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.