

An ACI Standard

# Specification for Installation of Cementitious Grouting between Foundations and Equipment Bases

Reported by ACI Committee 351

ACI 351.4M-14



American Concrete Institute  
*Always advancing*



## **Specification for Installation of Cementitious Grouting between Foundations and Equipment Bases**

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, on CD-ROM, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised ACI Manual of Concrete Practice (MCP).

**American Concrete Institute**  
**38800 Country Club Drive**  
**Farmington Hills, MI 48331**  
**Phone: +1.248.848.3700**  
**Fax: +1.248.848.3701**

# Specification for Installation of Cementitious Grouting between Foundations and Equipment Bases

An ACI Standard

Reported by ACI Committee 351

David Kerins\*, Chair

Mukti L. Das, Secretary

Omesh B. Abhat  
Richard P. Bohan†  
William L. Bounds  
William D. Brant  
Michael M. Chehab  
Shu-Jin Fang  
Fred R. Goodwin

Shraddhakar Harsh  
Erick N. Larson  
Robert R. McGlohn  
Carl A. Nelson  
Richard O'Malley  
Michael A. Paipal†  
Ira W. Pearce

Charlie L. Rowan  
William E. Rushing Jr.  
Yasser Salem  
Larry W. Schulze  
Philip A. Smith†  
Widianto  
F. Alan Wiley

Sheng-Chi Wu

*Consulting Members*  
Navin N. Pandya  
Shamsher Prakash  
Robert L. Rowan Jr.

\*Chair of Task Force 351.TG1.

†Members of Task Force 351.TG1 who prepared this specification.

*This specification covers minimum requirements for cementitious grouting between foundations and equipment bases. Included are requirements for materials and placing.*

**Keywords:** cement grout; cementitious grout; equipment grout; foundations; grout; hydraulic cement grout; machinery grout.

## CONTENTS

(mandatory portion follows)

### PART 1—GENERAL, p. 1

- 1.1—Scope, p. 1
- 1.2—Interpretation, p. 2
- 1.3—Definitions, p. 2
- 1.4—Referenced standards, p. 2
- 1.5—Submittals, p. 2
- 1.6—Delivery, storage, and handling, p. 2
- 1.7—Quality control procedures, p. 2
- 1.8—Acceptance of work, p. 3

### PART 2—PRODUCTS, p. 4

- 2.1—Grouts, p. 4
- 2.2—Joint and sealant material, p. 4
- 2.3—Formwork, p. 4
- 2.4—Water, p. 4

### PART 3—EXECUTION, p. 4

- 3.1—Preparation, p. 4
- 3.2—Installation, p. 5

3.3—Testing and inspection, p. 6

3.4—Repair, p. 6

3.5—Cleaning, p. 6

(nonmandatory portion follows)

### NOTES TO SPECIFIERS, p. 6

General notes, p. 6

Foreword to checklists, p. 6

### MANDATORY REQUIREMENTS CHECKLIST, p. 7

### OPTIONAL REQUIREMENTS CHECKLIST, p. 7

(mandatory portion follows)

## PART 1—GENERAL

### 1.1—Scope

**1.1.1** This specification covers minimum requirements for cementitious grouting between foundations and equipment and machinery bases.

ACI 351.4M-14 was adopted December 1, 2015, and was published December 2015. Copyright © 2015, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

**1.1.2** This specification supplements the Contract Documents and provides requirements for the Contractor.

**1.1.3** This specification governs for construction within its scope, except the Contract Documents govern if there is a conflict.

**1.1.4** This specification governs if there is a conflict with referenced material and testing standards.

**1.1.5** The Contractor is permitted to submit written alternatives to any provision in this specification.

**1.1.6** Do not use this specification in conjunction with ACI 301, ACI 350.5, or ACI 530.1 unless Contract Documents state that this specification governs for Work covered by 1.1.1.

**1.1.7** Ignore provisions of this specification that are not applicable to the Work.

**1.1.8** Values in this specification are stated in SI units. A companion specification in inch-pound units is also available.

**1.1.9** The “Notes to specifiers” are not part of this specification.

## 1.2—Interpretation

Unless otherwise explicitly stated, this specification shall be interpreted using the following principles:

(a) Interpret this specification consistent with the plain meaning of the words and terms used.

(b) Definitions provided in this specification govern. Unless otherwise explicitly stated, this specification shall be interpreted using the following principles:

i. Its provisions are in harmony and do not conflict.

ii. Headings are part of this specification and are intended to identify the scope of the provisions or sections that follow. If there is a difference in meaning or implication between the text of a provision and a heading, the meaning of the text governs.

iii. Where a provision of this specification involves two or more items, conditions, requirements, or events connected by the conjunctions “and” or “or,” interpret the conjunction as follows:

“and” indicates that all of the connected items, conditions, requirements, or events apply.

“or” indicates that the connected items, conditions, requirements, or events apply singularly.

iv. The use of the verbs “may” or “will” indicates that the specification provision is for information to the Contractor.

## 1.3—Definitions

**1.3.1** The following definitions govern in this specification. For definitions not given herein, refer to “ACI Concrete Technology.”

**headbox**—device for controlling the gravity flow of grout into the formwork.

**unrestrained areas of grout**—areas of grout that are not under or within 100 mm of the baseplate.

## 1.4—Referenced standards

Standards of ACI Specified in this specification are listed by name and designation, including year.

### 1.4.1 ACI standards

ACI 117M-10—Specification for Tolerances for Concrete Construction and Materials and Commentary

ACI 301M-10—Specifications for Structural Concrete

## 1.5—Submittals

**1.5.1 General**—Provide to Architect/Engineer submittals required by this specification in accordance with Contract Documents.

**1.5.2 Quality control plan**—If required, submit a quality control plan showing means and methods to control the purchase, use, and placement of grout. Provide information related to quality control in accordance with 1.7.4.

**1.5.2.1** Submit data on qualifications of proposed testing agency for acceptance. Use of testing services will not relieve Contractor of the responsibility to furnish materials and construction in compliance with Contract Documents

### 1.5.3 Quality control procedures

**1.5.3.1** Submit the following to Architect/Engineer before the start of the work:

- a) Experience record of supervisory personnel
- b) List of equipment and procedures
- c) Detailed procedures for grouting, including anchoring unrestrained area of grout if required in Contract Documents

**1.5.3.2** Submit the following to the Architect/Engineer during construction:

- a) Notification to Architect/Engineer in time to permit in-place inspection of the foundation and formwork prior to placement of grout
- b) Test results for samples taken in accordance with 1.7.4
- c) Record set markup of drawings
- d) Formwork and formwork accessories data

## 1.6—Delivery, storage, and handling

**1.6.1** Grout shall be stored and handled in accordance with the manufacturer’s written instructions and material safety data sheets.

## 1.7—Quality control procedures

**1.7.1 General**—Grout materials and operations may be tested and inspected by Owner as Work progresses. Failure to detect defective Work or material shall not prevent rejection for defects discovered later nor shall it obligate Architect/Engineer for final acceptance.

**1.7.1.1** Testing agencies shall be accepted by Architect/Engineer before performing any Work. Field tests of grout required in 1.7.2 and 1.7.3 shall be performed by personnel trained in testing grouts.

**1.7.2 Testing responsibilities of Contractor**—Unless otherwise specified in Contract Documents, Contractor shall assume the following duties and responsibilities:

- a) Qualify proposed materials
- b) Allow access to the project site or to the source of materials and assist Owner’s testing agency in obtaining