



American National Standard for

Sealless Rotodynamic Pumps

for Nomenclature, Definitions,
Design, Application, Operation, and
Test

ANSI/HI 5.1-5.6-2016



6 Campus Drive
First Floor North
Parsippany, New Jersey
07054-4406
www.Pumps.org

This page intentionally blank.

American National Standard for

Sealless Rotodynamic Pumps

for Nomenclature, Definitions,
Design, Application, Operation, and Test

Sponsor
Hydraulic Institute
www.Pumps.org

Approved March 24, 2016
American National Standards Institute, Inc.

American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgement of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published By

Hydraulic Institute
6 Campus Drive, First Floor North
Parsippany, NJ 07054-4406

www.Pumps.org

Copyright © 2016 Hydraulic Institute
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission of the publisher.

Printed in the United States of America

ISBN 978-1-935762-41-6



Recycled
paper

Contents

Page

Foreword	v
5 Sealless rotodynamic pumps	1
5.1 Types and nomenclature	1
5.1.0 Disclaimer	1
5.1.1 Scope	1
5.1.2 Canned motor pump (CMP)	1
5.1.3 Magnetic drive pump (MDP)	2
5.1.4 Sealless pump part names	3
5.2 Definitions	14
5.2.1 Sealless pumps — general	14
5.2.2 Canned motor pump (CMP)	16
5.2.3 Magnetic drive pump (MDP)	16
5.2.4 Containment	18
5.2.5 Monitoring equipment	19
5.3 Design and application	19
5.3.1 Scope	19
5.3.2 Basic design	20
5.3.3 Guidelines for applications	33
5.4 Installation, operation, and maintenance	39
5.4.1 Unit location and foundation	39
5.4.2 Installation	40
5.4.3 Starting	41
5.4.4 Vibration	42
5.4.5 Maintenance	42
5.4.6 Troubleshooting	43
5.5 Reference and source material	46
5.5.1 Bearings	46
5.5.2 Sealless pumps	46
5.5.3 ANSI/ASME — American Society of Mechanical Engineers	46
5.5.4 AMT — The Association For Manufacturing Technology	47
5.5.5 ANSI/HI — Hydraulic Institute	47
5.5.6 ANSI/IEEE — Institute of Electrical and Electronic Engineers	47
5.5.7 ASTM — American Society for Testing and Materials	48
5.5.8 ISO — International Organization for Standards	48
5.5.9 UN Economic Commission for Europe Information Service	48

5.6	Test	48
5.6.1	Scope	48
5.6.2	Types of tests	48
5.6.3	Hermetic integrity test (standard test)	49
5.6.4	Motor winding integrity test (standard test)	50
5.6.5	Secondary containment test	50
5.6.6	Motor winding temperature rise test	51
5.6.7	Report of test	53
Appendix A	Additional rotodynamic sealless designs	54
A.1	CMP - reverse circulation end suction (circulation plan 113)	54
A.2	CMP - separated pump and motor end suction (circulation plan 123)	54
A.3	CMP - retrofit end suction	54
A.4	CMP - multistage end suction	54
A.5	CMP - self-priming end suction	54
A.6	MDP - multistage end suction	54
A.7	MDP - cover-mounted magnetic drive housing submersible	54
A.8	MDP - self-priming end suction	55
Appendix B	Index	61
Figures		
5.1.1.2	— Types of sealless rotodynamic pumps	2
5.1.2.1	— Canned motor pump: end suction, overhung impeller	4
5.1.2.2	— Canned motor pump: vertical in-line	5
5.1.2.3	— Canned motor pump: vertical submerged	6
5.1.3.1	— Magnetic drive pump: flexibly coupled, rotating shaft	7
5.1.3.2	— Magnetic drive pump: close couple, cantilevered stationary shaft	8
5.1.3.3	— Magnetic drive pump: vertical submerged, submersed magnetic coupling housing	9
5.1.3.4	— Magnetic drive pump: close couple, in-line, fully supported stationary shaft	10
5.3.2.12.1	— Typical circulation piping plans for canned motor and magnetic drive pumps	26
A.1	— Canned motor pump: reverse circulation (plan 113)	55
A.2	— Canned motor pump: motor and pump separated by thermal barrier (plan 123)	55
A.3	— Canned motor pump: retrofit with external circulation	56
A.4	— Canned motor pump: multistage	57
A.5	— Canned motor pump: self-priming	57
A.6	— Magnetic drive pump: multistage	58
A.7	— Magnetic drive pump: vertical submerged, cover-mounted magnetic coupling housing	59
A.8	— Magnetic drive pump: self-priming	60
Tables		
Table 5.1.4	— Sealless pump parts names	11

Foreword (Not part of Standard)

Purpose and aims of the Hydraulic Institute

The purpose and aims of the Hydraulic Institute are to promote the advancement of the pump manufacturing industry and further the interests of the public and to this end, among other things:

- a) Develop and publish standards.
- b) Address pump systems.
- c) Expand knowledge and resources.
- d) Educate the marketplace.
- e) Advocate for the industry.

Purpose of Standards and Guidelines

- a) Hydraulic Institute Standards and Guidelines are adopted in the public interest and are designed to help eliminate misunderstandings between the manufacturer, the purchaser, and/or the user and to assist the purchaser in selecting and obtaining the proper product for a particular need.
- b) Use of Hydraulic Institute Standards and Guidelines is completely voluntary. Existence of Hydraulic Institute Standards does not in any respect preclude a member from manufacturing or selling products not conforming to the standards.

Definition of a Standard of the Hydraulic Institute

Quoting from Article XV, Standards, of the By-Laws of the Institute, Section B:

“An Institute Standard defines the product, material, process or procedure with reference to one or more of the following: nomenclature, composition, construction, dimensions, tolerances, safety, operating characteristics, performance, quality, rating, testing and service for which designed.”

Definition of a Hydraulic Institute Guideline

A Hydraulic Institute Guideline is not normative. The guideline is tutorial in nature, to help the reader better understand the subject matter.

Comments from users

Comments from users of this standard will be appreciated, to help the Hydraulic Institute prepare even more useful future editions. Questions arising from the content of this standard may be directed to the Technical Director of the Hydraulic Institute. If appropriate, the inquiry will then be directed to the appropriate technical committee for provision of a suitable answer.

Revisions

American National Standards of the Hydraulic Institute are subject to constant review, and revisions are undertaken whenever it is found necessary because of new developments and progress in the art. If no revisions are made for five years, the standards are reaffirmed using the ANSI canvass procedure.

Disclaimer

This document was prepared by a committee of the Hydraulic Institute and approved by following ANSI essential requirements. Neither the Hydraulic Institute, Hydraulic Institute committees, nor any person acting on behalf of the Hydraulic Institute: 1) makes any warranty, expressed or implied, with respect to the use of any information, apparatus, method, or process disclosed in this document or guarantees that such may not infringe privately owned rights; 2) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this guideline. The Hydraulic Institute is in no way responsible for

any consequences to an owner, operator, user, or anyone else resulting from reference to the content of this document, its application, or use.

This document does not contain a complete statement of all requirements, analyses, and procedures necessary to ensure safe or appropriate selection, installation, testing, inspection, and operation of any pump or associated products. Each application, service, and selection is unique with process requirements that shall be determined by the owner, operator, or its designated representative.

Units of measurement

Metric units of measurement are used, and corresponding US customary units appear in parentheses. Charts, graphs, and sample calculations are also shown in both metric and US customary units. Because values given in metric units are not exact equivalents to values given in US customary units, it is important that the selected units of measure to be applied be stated in reference to this standard. If no such statement is provided, metric units shall govern.

Consensus

Consensus for this American National Standard was achieved by use of the canvass method. The following organizations, recognized as having an interest in the standardization of pumps, were contacted prior to the approval of this revision of the standard. Inclusion in this list does not necessarily imply that the organization concurred with the submittal of the proposed standard to ANSI.

Albemarle	Las Vegas Valley Water District
Bechtel Oil, Gas and Chemicals Inc.	Leistritz Advanced Technologies Corp
Black & Veatch	Patterson Pump
Colfax Fluid handling	Pentair
DuPont	Rotating Equipment Repair, Inc.
ekwestrel corp	Sulzer
Exponent, Inc.	Weir Floway, Inc
Fluid Sealing Association	Weir Minerals North America
Healy Engineering, Inc.	Xylem Inc
ITT Corporation	
Kemet Inc.	

Special Acknowledgement

William Taylor, PeopleFlo Manufacturing, Inc., for providing a thorough review of the standard in preparation for publication.

Committee list

Although this standard was processed and approved for submittal to ANSI by the canvass method, a working committee met many times to facilitate its development. At the time it was developed, the committee had the following members:

Chair – Jared Wageman, Sundyne LLC

Vice-chair – John Maloney, Chempump, a Division of Teikoku USA Inc.

Committee members

Ravindra Birajdar
Kenneth Deddo (Alternate)
Lucian Dobrot
Robert Fleming (Alternate)
Benjamin Hardy
Scott Judge
Peter Koegl
Suzanne Smyth
Peter Timpanelli
Kees van der Sluijs (Alternate)

Company

Kirloskar Brothers Ltd.
HERMETIC-Pumps Inc.
ITT - Industrial Process
Hayward Tyler, Inc.
Hayward Tyler, Inc.
Flowserve Corporation
HERMETIC-Pumps Inc.
Exponent Inc.
LEWA-Nikkiso America, Inc.
Flowserve Corporation

5 Sealless rotodynamic pumps

5.1 Types and nomenclature

5.1.0 Disclaimer

The term *sealless* is a generic, industrial word used for pumps not employing dynamic seals such as mechanical shaft seals, centrifugal seals, or packing as the primary method of sealing liquid or vapor from the atmosphere. *Hermetic* would accurately describe the construction of these types of pumps. It is understood that static seals may be used in pumps that are designated sealless.

Use of the term *sealless* herein should not be construed as any type of warranty or guarantee against pump leaks.

5.1.1 Scope

This standard covers types and nomenclature, definitions, design and application, installation, operation and maintenance, and test of sealless rotodynamic pumps driven by canned motors or magnetic couplings.

Not included are submersible wastewater pumps that do not have external shaft seals and are therefore not susceptible to external shaft leakage. Deep well submersible pumps and circulator pumps are also excluded.

5.1.1.1 Objective

To clearly outline the information necessary to define and describe the construction and use of sealless pumps.

5.1.1.2 Introduction

The sealless pump is used when there is a need to contain toxic, dangerous, high suction pressure, and/or valuable fluids or where dynamic seals are undesirable due to utility (seal flush/buffer) requirements or due to high system reliability standards. Application may be dictated by space, noise, environment, or safety regulations. This section outlines types, nomenclatures, and components of sealless rotodynamic type pumps.

Sealless pump design is founded on eliminating the dynamic shaft seal between the liquid end of a rotodynamic (centrifugal) pump and the atmosphere. This is achieved by enclosing the pump and its rotor assembly inside a pressure vessel with the pumped fluid. The pressure vessel or “primary containment” is sealed by static seals, such as gaskets or O-rings. The inner rotor assembly is driven by a rotating magnetic or electromagnetic field that is transmitted through a containment barrier.

The two primary sealless pump designs are the canned motor pump (CMP) and magnetic drive pump (MDP). See Figure 5.1.1.2 for a diagrammatic breakdown of the types of sealless rotodynamic pumps.

5.1.2 Canned motor pump (CMP)

The CMP combines a rotodynamic (centrifugal) pump and induction motor into one hermetically sealed unit. The impeller is mounted directly on the rotor assembly, which is driven by the rotating electromagnetic field of the stator. The rotor is typically supported by hydrodynamic bearings at each end of the motor. The motor components are protected from the process liquid by a nonmagnetic stator liner that is placed between the stator and rotor.

During operation, the motor section and bearings are cooled and lubricated by the process liquid. This fluid is either a flush introduced from an external source or, more commonly, taken from the pump discharge.

Below are typical examples of canned motor pumps, but additional variations and circulation plans can be found in Appendix A.