

ASSE International

Performance Requirements for

**Atmospheric Type
Vacuum Breakers**

General Information

Neither this standard, nor any portion thereof, may be reproduced without the written consent of ASSE International.

No product may be said to be listed by ASSE unless the manufacturer has applied to ASSE International, had its product tested by an official ASSE recognized independent laboratory according to the applicable standard, passed the tests, and had its documentation reviewed and approved by the consensus ASSE Seal Control Board. Having completed the aforementioned, the manufacturer may display the ASSE Seal on the product.

Instructions for receiving the authorization to display the seal are available from the ASSE International office. Organizations wishing to adopt or list any ASSE standard should print the ASSE standard number on the cover page first in equal or larger type to that of the adopting or listing organization.

ASSE International
Mokena, Illinois
Copyright © 2017, 2008, 2002, 1993, 1990, 1988, 1980, 1970, 1962
All rights reserved.

Foreword

This foreword shall not be considered a part of the standard; however, it is offered to provide background information.

ASSE standards are developed in the interest of consumer safety. ASSE considers product performance standards to be of great value in the development of improved plumbing systems.

To accomplish this, ASSE, through its Product Standards Committee, encourages manufacturers to assist in the development of performance and testing procedures. Realizing the need for a uniform standard that manufacturers and laboratory personnel could use in testing and evaluating the performance of anti-siphon vacuum breakers installed in potable water supply systems, ASSE formed a committee to develop such a standard in 1958. The committee consisted of directors and personnel of plumbing testing laboratories in Chicago, Detroit and Los Angeles, as well as a representative of the Bureau of Water Register of the New York City Department of Water Supply. Through the Product Standards Committee, with the cooperation of interested manufacturers, a standard was developed – Performance Requirements and Test Methods for Atmospheric Type, Anti-Siphon Devices.

At the 1962 ASSE Annual Meeting in Little Rock, Ark., the work of the committee culminated in the acceptance of the standard, which was assigned the official number ASSE 1001.

This 2017 revision of the standard has added performance criteria specific to vacuum breakers intended specifically for flushometer applications and for those intended to be integral to other plumbing devices. In those cases, flushometers and integral-type devices shall have standards associated with their function covering certain sections in ASSE 1001, e.g. ASSE 1037/ASME A112.19.1037/CSA B125.37-2015 covers flushometers, ASME A112.18.1/CSA B125.1 covers plumbing supply fittings, and ASME A112.4.2/CSA B45.16 covers personal hygiene devices.

The working group that developed this standard revision was set up within the framework of the ASSE International Product Standards Committee. Recognition is made of the time volunteered by members of this working group and of the support of manufacturers, who also participated in the meetings for this standard.

This standard does not imply ASSE's endorsement of a product that conforms to these requirements.

Compliance with this standard does not imply acceptance by any code body.

It is recommended that these devices be installed consistent with local codes by qualified and trained professionals.

This standard was promulgated in accordance with procedures developed by the American National Standards Institute (ANSI).

ASSE Vacuum Breaker Standards

| ASSE Standard Number | Standard Name | Typical Use | Highlights |
|----------------------|-------------------------------------|--|---|
| 1001 | Atmospheric Type Vacuum Breakers | <ul style="list-style-type: none"> Faucet with hose thread spout Water closet fill valve | Prevents Backsiphonage: <ul style="list-style-type: none"> Outlet is open to atmosphere Not subjected to backpressure Not be subjected to more than twelve (12) hours of continuous water pressure |
| 1011 | Hose Connection Vacuum Breakers | <ul style="list-style-type: none"> Hose connections, such as hose bib, wall hydrant, yard hydrant | <ul style="list-style-type: none"> Prevents backflow by use of a SINGLE CHECK valve Prevents backsiphonage by use of AIR PORTS Prevents backpressure by use of check valve and relief of backpressure through air ports. i.e. relieves pressure in the hose. Non-removable and non-testable |
| 1020 | Pressure Vacuum Breakers | <ul style="list-style-type: none"> Irrigation systems Industrial processes | Prevents Backsiphonage: <ul style="list-style-type: none"> Uses a SINGLE CHECK Not subjected to backpressure Can be subjected to continuous water pressure in excess of twelve (12) hours |
| 1052 | Hose Connection Backflow Preventers | <ul style="list-style-type: none"> Hose connections, such as hose bib, wall hydrant, yard hydrant | Same as a 1011 device except there are two check valves. One check valve holds the pressure in the hose. The Intermediate chamber between check vales becomes atmospheric. Device is non-removable but is testable. |
| 1056 | Spill Resistant Vacuum Breakers | <ul style="list-style-type: none"> Indoor plumbing assemblies Medical equipment | Same as 1020 but does not spill water when pressurized. |

| Standard No. | Dual Check | Air Ports | Backflow | Backsiphonage | Backpressure | Frost Free | Removable | Testable | High Hazard |
|--------------|------------|-----------|----------|---------------|--------------|------------|-----------|----------|-------------|
| 1001 | N | Y | N | Y | N | N | Y | N | Y |
| 1011 | N | Y | Y | Y | Y | N | N | N | Y |
| 1020 | N | Y | N | Y | N | N | Y | Y | Y |
| 1052 | Y | Y | Y | Y | Y | N | N | Y | Y |
| 1056 | N | Y | N | Y | N | N | Y | Y | Y |

2017 Product Standards Committee

Edward J. Lyczko, Chairperson

*Cleveland Clinic – Retiree
Cleveland, OH*

William Briggs, Jr.

*MGJ Associates
New York, NY*

Terry Burger

*NSF International
Ypsilanti, MI*

William Chapin

*Professional Code Consulting, LLC
Cullman, AL*

Mark Fish

*Zurn Industries, LLC
Cary, NC*

Ron George

*Plumb-Tech Design & Consulting
Services, LLC
Newport, MI*

Daniel Gleiberman

*Sloan
Los Angeles, CA*

John F. Higdon, P.E.

*Apollo Valves / Conbraco Industries, Inc.
Matthews, NC*

Gary Howard

*Illinois Plumbing Inspector – Retiree
LaGrange, IL*

Conrad L. Jahrling (non-voting)

*ASSE International
Chicago, IL*

Chuck Lott

*Precision Plumbing Products
Portland, OR*

Peter Marzec

*United Association of Plumbers
and Pipefitters
Pearl River, NY*

Thomas Pitcherello

*State of New Jersey
Bordentown, NJ*

Daniel Rademacher

*Plumbing Code and Design Consulting
Butte, MT*

Shabbir Rawalpindiwala

*Kohler Company
Kohler, WI*

Billy Smith

*American Society of Plumbing
Engineers (ASPE)
Montgomery, AL*

Tsan-Liang Su, PhD

*Stevens Institute of Technology
Hoboken, NJ*

Vacuum Breaker Working Group

William Chapin, Chairperson
Professional Code Consulting, LLC
Cullman, AL

Joel Hipp
Hobart - ITW
Troy, OH

Mike Boehk
Legend Valve
Shelby Township, MI

Herb Hoeptner
Hoeptner Preferred Products
Gilroy, CA

Matt Brizzee
Conbraco Industries, Inc.
Matthews, NC

Conrad L. Jahrling (non-voting)
ASSE International
Chicago, IL

Robert Burnham
Zurn Industries
Erie, PA

Jerry McDanal
J.R. Smith
Montgomery, AL

Fernando Fernandez
TOTO
Ontario, CA

Brad Noll
Zurn Industries
Paso Robles, CA

Daniel Gleiberman
Sloan
Los Angeles, CA

Shabbir Rawalpindiwala
Kohler Company
Kohler, WI

Larry Himmelblau
Chicago Faucet Co.
Lisle, IL

Table of Contents

| | |
|---|-----------|
| Section I | 1 |
| 1.0 General | 1 |
| 1.1 Application | 1 |
| 1.2 Scope | 1 |
| 1.3 Limitations on Design | 2 |
| 1.3 Referenced Standards | 2 |
| Section II | 3 |
| 2.0 Test Specimens | 3 |
| 2.1 Samples Submitted for Test | 3 |
| 2.2 Samples Tested | 3 |
| 2.3 Drawings | 3 |
| 2.4 Rejection | 3 |
| Section III | 4 |
| 3.0 Performance Requirements and Compliance Testing | 4 |
| 3.1 Deterioration at Extremes of Manufacturer's Temperature and Pressure Range Test | 4 |
| Figure 1 | 5 |
| Table 1 | 5 |
| 3.2 Allowable Pressure Loss at Rated Flow Test | 6 |
| Table 2 | 6 |
| 3.3 Examination of Air Inlet Shield | 6 |
| 3.4 Air Flow Test | 7 |
| Figure 2 | 7 |
| Figure 3A | 8 |
| Figure 3B | 8 |
| 3.5 Backsiphonage Test | 8 |
| Table 3 | 9 |
| Figure 4 | 9 |
| Figure 5 | 9 |
| Figure 6 | 9 |
| Figure 7 | 10 |
| 3.6 Evaluation of Female Threaded Connections | 11 |
| 3.7 Hydrostatic Test of the Complete Device | 11 |
| Section IV | 12 |
| 4.0 Detailed Requirements | 12 |
| 4.1 Materials | 12 |
| 4.2 Pipe Threads | 12 |
| 4.3 Markings | 12 |
| 4.4 Installation and Maintenance Instructions | 13 |
| Section V | 14 |
| 5.0 Definitions | 14 |

Performance Requirements for Atmospheric Type Vacuum Breakers

Section I

1.0 General

1.1 Application

This standard applies to atmospheric type vacuum breakers (herein referred to as the "device") that are single pipe-applied, flushometer-applied, or integrally-applied (does not apply to water closet tank ballcocks or similar devices that depend on float-operated valves to control flow). The purpose of these devices is to provide protection of the potable water supply against pollutants or contaminants that enter the system due to backsiphonage through the outlet. Under backsiphonage conditions, a small amount of water is permitted to exit through the air ports.

The device shall:

- 1) Have its outlet open to atmosphere;
- 2) Not be subjected to backpressure;
- 3) Not be subjected to more than twelve (12) hours of continuous water pressure; and
- 4) Be installed with its critical level (CL) not less than 6.0 inches (152.4 mm) above the flood level rim of the fixture or appliances served; or deck mounted/equipment mounted atmospheric vacuum breakers shall be installed in accordance with the manufacturer's instructions, with its critical level (CL) not less than 1.0 inch (25.4 mm) above the flood level rim of the fixture or appliance served.

1.2 Scope

1.2.1 Description

Vacuum breakers shall be classified in two general types:

- Atmospheric type, as described herein
- Pressure type (See ASSE Standard 1020, Performance Requirements for Pressure Vacuum Breaker Assembly, and ASSE Standard 1056, Spill Resistant Vacuum Breakers)

The atmospheric type design shall consist of:

- a) A check valve member
- b) An air inlet valve that is closed when the check valve member is open, and normally open when the check valve member is normally closed.

The atmospheric type design can be further classified into three categories, depending on use:

- 1) Pipe-applied
- 2) Flushometer-applied
- 3) Integrally-applied

Devices shall include an air inlet shield.