

ACI 369.1M-17

An ACI Standard

Standard Requirements for Seismic Evaluation and Retrofit of Existing Concrete Buildings (ACI 369.1M-17) and Commentary

Reported by ACI Committee 369



American Concrete Institute
Always advancing



**Standard Requirements for Seismic Evaluation and Retrofit of Existing Concrete Buildings
(ACI 369.1M-17) and Commentary**

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, on CD-ROM, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised ACI Collection of Concrete Codes, Specifications, and Practices.

American Concrete Institute
38800 Country Club Drive
Farmington Hills, MI 48331
Phone: +1.248.848.3700
Fax: +1.248.848.3701

Standard Requirements for Seismic Evaluation and Retrofit of Existing Concrete Buildings (ACI 369.1M-17) and Commentary

An ACI Standard

Reported by Committee 369

Wassim M. Ghannoum, Chair

Siamak Sattar, Secretary

Anna C. Birely
Sergio F. Brena
Casey Champion
Jeffrey J. Dragovich
Kenneth J. Elwood
Una M. Gilmartin
Arne Halterman
Wael Mohammed Hassan

Mohammad Iqbal
Jose M. Izquierdo-Encarnacion
Afshar Jalalian
Thomas Kang
Dominic J. Kelly
Insung Kim
Laura N. Lowes
Kenneth A. Luttrell

Adolfo B. Matamoros
Steven L. McCabe
Murat Melek
Jack P. Moehle
Arif M. Ozkan
Robert G. Pekelnicky
Jose A. Pincheira
Mario E. Rodriguez

Murat Saatcioglu
Halil Sezen
Roberto Stark
Andreas Stavridis
John W. Wallace
Tom C. Xia

The committee would like to thank G. Hagen for his contribution.

Consulting Members

Sergio M. Alcocer
David Bonowitz

Charles J. Hookham
Shyh-Jiann Hwang

Regan Milam
Andrew D. Mitchell

Raj Valluvan

PREFACE

This standard provides retrofit and rehabilitation criteria for reinforced concrete buildings based on results from the most recent research on the seismic performance of existing concrete buildings. The intent of this standard is to provide a continuously updated resource document for modifications to Chapter 10 of ASCE 41-17, similar to how the National Earthquake Hazards Reduction Program (NEHRP) Recommended Seismic Provisions produced by the Federal Emergency Management Agency (FEMA) (FEMA 450) have served as source documents for the International Building Code (IBC) and its predecessor building codes. Specifically, this version of ACI 369.1M serves as the basis for Chapter 10, "Concrete," of ASCE 41-17.

This standard should be used in conjunction with Chapters 1 through 7 of ASCE 41-17. Chapter 1 of ASCE 41-17 provides general requirements for evaluation and retrofit, including the selection of performance objectives and retrofit strategies. Chapter 2 of ASCE 41-17 defines performance objectives and seismic

hazards. Chapter 3 of ASCE 41-17 provides the requirements for evaluation and retrofit, including treating as-built information and selecting the appropriate screening procedures. Chapter 4 of ASCE 41-17 summarizes Tier 1 screening procedures, while Chapters 5 and 6 summarize Tier 2 deficiency-based procedures and Tier 3 systematic procedures for evaluation and retrofit, respectively. Chapter 7 of ASCE 41-17 details analysis procedures referenced in ACI 369.1M, including linear and nonlinear analysis procedures, acceptance criteria, and alternative methods for determining modeling parameters and acceptance criteria. Chapter 8 of ASCE 41-17 provides geotechnical engineering provisions for building foundations and assessment of seismic-geologic site hazards. References to these chapters can be found throughout the standard. The design professional is referred to FEMA 547 for detailed information on seismic rehabilitation measures for concrete buildings. Repair techniques for earthquake-damaged concrete components are not included in ACI 369.1M. The design professional is referred to FEMA 306, FEMA 307, and FEMA 308 for information on evaluation and repair of damaged concrete wall components.

This standard does not provide modeling procedures, acceptance criteria, and rehabilitation measures for concrete-encased steel composite components. Future versions will provide provision updates for concrete moment frames and will add provisions for concrete components and systems omitted in the present version of the standard.

ACI Committee Reports, Guides, and Commentaries are intended for guidance in planning, designing, executing, and inspecting construction. This document is intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. The American Concrete Institute disclaims any and all responsibility for the stated principles. The Institute shall not be liable for any loss or damage arising therefrom.

Reference to this document shall not be made in contract documents. If items found in this document are desired by the Architect/Engineer to be a part of the contract documents, they shall be restated in mandatory language for incorporation by the Architect/Engineer.

ACI 369.1M-17 was adopted September 22, 2017, and published February 2018. Copyright © 2018, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

CONTENTS

PREFACE, p. 1

INTRODUCTION, p. 3

CHAPTER 1—GENERAL, p. 5

1.1—Scope, p.5

CHAPTER 2—MATERIAL PROPERTIES AND CONDITION ASSESSMENT, p. 6

2.1—General, p.6
 2.2—Properties of in-place materials and components, p.6
 2.3—Condition assessment, p.15
 2.4—Knowledge factor, p.17

CHAPTER 3—GENERAL ASSUMPTIONS AND REQUIREMENTS, p. 18

3.1—Modeling and design, p.18
 3.2—Strength and deformability, p.21
 3.3—Flexure and axial loads, p.22
 3.4—Shear and torsion, p.24
 3.5—Development and splices of reinforcement, p.25
 3.6—Connections to existing concrete, p.29
 3.7—Retrofit measures, p.31

CHAPTER 4—CONCRETE MOMENT FRAMES, p. 32

4.1—Types of concrete moment frames, p.32
 4.2—Reinforced concrete beam-column moment frames, p.33
 4.3—Post-tensioned concrete beam-column moment frames, p.43
 4.4—Slab-column moment frames, p.46

CHAPTER 5—PRECAST CONCRETE FRAMES, p. 53

5.1—Types of precast concrete frames, p.53
 5.2—Precast concrete frames expected to resist seismic forces, p.53
 5.3—Precast concrete frames not expected to resist seismic forces directly, p.54

CHAPTER 6—CONCRETE FRAMES WITH INFILLS, p. 56

6.1—Types of concrete frames with infills, p.56
 6.2—Concrete frames with masonry infills, p.56
 6.3—Concrete frames with concrete infills, p.60

CHAPTER 7—CONCRETE STRUCTURAL WALLS, p. 63

7.1—Types of concrete structural walls and associated components, p.63

7.2—Reinforced concrete structural walls, wall segments, and coupling beams, p.65

CHAPTER 8—PRECAST CONCRETE STRUCTURAL WALLS, p. 77

8.1—Types of precast structural walls, p.77
 8.2—Precast concrete structural walls and wall segments, p.78

CHAPTER 9—CONCRETE BRACED FRAMES, p. 83

9.1—Types of concrete-braced frames, p.83
 9.2—General, p.83
 9.3—Stiffness of concrete braced frames, p.83
 9.4—Strength of concrete-braced frames, p.84
 9.5—Acceptance criteria for concrete-braced frames, p.84
 9.6—Retrofit measures for concrete-braced frames, p.85

CHAPTER 10—CAST-IN-PLACE CONCRETE DIAPHRAGMS, p. 86

10.1—Components of cast-in-place concrete diaphragms, p.86
 10.2—Analysis, modeling, and acceptance criteria for cast-in-place concrete diaphragms, p.86
 10.3—Retrofit measures for cast-in-place concrete diaphragms, p.87

CHAPTER 11—PRECAST CONCRETE DIAPHRAGMS, p. 88

11.1—Components of precast concrete diaphragms, p.88
 11.2—Analysis, modeling, and acceptance criteria for precast concrete diaphragms, p.88
 11.3—Retrofit measures for precast concrete diaphragms, p.88

CHAPTER 12—CONCRETE FOUNDATIONS, p. 89

12.1—Types of concrete foundations, p.89
 12.2—Analysis of existing concrete foundations, p.90
 12.3—Evaluation of existing condition, p.90
 12.4—Retrofit measures for concrete foundations, p.91

CHAPTER 13—NOTATION AND DEFINITIONS, p. 93

13.1—Notation, p.93
 13.2—Definitions, p.98

REFERENCES, p. 104

Authored references, p.106

INTRODUCTION

Earthquake reconnaissance has clearly demonstrated that existing concrete buildings designed before the introduction of seismic design codes in the 1980s are more vulnerable to severe damage or collapse when subjected to strong ground motion than concrete buildings built after that period. Seismic rehabilitation of existing buildings where new components are added or existing components are modified or retrofitted with new materials, or both, can be used to mitigate the risk to damage in future earthquakes. Seismic rehabilitation is encouraged not only to reduce the risk of damage and injury in future earthquakes, but also to extend the life of existing buildings and reduce using new materials in the promotion of sustainability objectives.

It is not possible to codify all problems encountered in the process of performing the seismic evaluation and retrofit of reinforced concrete buildings, nor is the intent of the standard to do so. The standard provides a basic framework for modeling and evaluation of structures that reflects the latest information available from researchers and practicing engineers, so that seismic evaluation and retrofit can be performed with a consistent set of criteria. Many provisions in the standard rely on the use of sound engineering judgement for their implementation. The commentary of the standard provides references that describe in detail the implementation of methodologies adopted in the standard.

Keywords: acceptance criteria; building; deformation-controlled; dynamic analysis; earthquake; force-controlled; modeling parameters; nonlinear analysis; retrofit; seismic evaluation.



THIS PAGE INTENTIONALLY LEFT BLANK.



STANDARD

COMMENTARY

CHAPTER 1—GENERAL

1.1—Scope

This standard sets forth requirements for the seismic evaluation and retrofit of concrete components of the seismic-force-resisting system of an existing building. These building standard requirements apply to existing concrete components, retrofitted concrete components, and new concrete components. Provisions of this standard do not apply to concrete-encased steel composite components.

Chapter 2 specifies data collection procedures for obtaining material properties and performing condition assessments. **Chapter 3** provides general analysis and design requirements for concrete components. **Chapters 4 through 9** provide modeling procedures; component strengths; acceptance criteria and retrofit measures for cast-in-place and precast concrete moment frames; concrete frames with masonry infills; cast-in-place and precast concrete structural walls; and concrete braced frames. **Chapters 10 through 12** provide modeling procedures, strengths, acceptance criteria, and retrofit measures for concrete diaphragms and concrete foundation systems.

C1.1—Scope

These standard requirements were developed based on the best knowledge of the seismic performance of existing concrete buildings at the time of publication. These requirements are not intended to restrict the licensed design professional from using new information that becomes available before the issuance of the next edition of this standard. Such new information can include tests conducted to address specific building conditions.

This standard provides short descriptions of potential seismic retrofit measures for each concrete building system. The licensed design professional, however, is referred to **FEMA 547** for detailed information on seismic retrofit measures for concrete buildings. Repair techniques for earthquake-damaged concrete components are not included in this standard. The licensed design professional is referred to **FEMA 306**, **FEMA 307**, and **FEMA 308** for information on evaluation and repair of damaged concrete wall components.

Concrete-encased steel composite components behave differently from concrete sections reinforced with steel reinforcement. Concrete-encased steel composite components frequently behave as over-reinforced sections. This type of component behavior was not represented in the data sets used to develop the force-deformation modeling relationships and acceptance criteria in this standard, and is not covered in this standard. Concrete encasement is often provided for fire protection rather than for strength or stiffness and typically lacks transverse reinforcement. In some cases, the transverse reinforcement does not meet detailing requirements in **AISC 360**. Lack of adequate confinement can result in lateral expansion of the core concrete, which exacerbates bond slip and undermines the fundamental principle that plane sections remain plane.

Testing and analysis used to determine acceptance criteria for concrete-encased steel composite components should include the effect of bond slip between steel and concrete, confinement ratio, confinement reinforcement detailing, kinematics, and appropriate strain limits.

To preserve historic buildings, exercise care in selecting the appropriate retrofit approaches and techniques for application.

STANDARD

COMMENTARY

CHAPTER 2—MATERIAL PROPERTIES AND
CONDITION ASSESSMENT**2.1—General**

Mechanical properties of materials shall be obtained from available drawings, specifications, and other documents for the existing building in accordance with the requirements of **ASCE 41-17**, 3.2. Where these documents fail to provide adequate information to quantify material properties, such information shall be supplemented by materials testing based on requirements of Chapter 2. Material properties of existing concrete components shall be determined in accordance with 2.2. The use of default material properties based on historical information is permitted in accordance with 2.2.5. A condition assessment shall be conducted in accordance with 2.3. The extent of materials testing and condition assessment performed shall be used to determine the knowledge factor as specified in 2.4.

2.2—Properties of in-place materials and components*2.2.1 Material properties***C2.1—General**

Chapter 2 identifies properties requiring consideration and provides requirements for determining building properties. Also described is the need for a thorough condition assessment and use of knowledge gained in analyzing component and system behavior. Personnel involved in material property quantification and condition assessment should be experienced in the proper implementation of testing practices and the interpretation of results.

When modeling a concrete building, it is important to investigate local practices relative to seismic design. Specific benchmark years can be determined for the implementation of earthquake-resistant design in most locations, but caution should be exercised in assuming optimistic characteristics for any specific building. Particularly with concrete materials, the date of original building construction significantly influences seismic performance. Without deleterious conditions or materials, concrete gains compressive strength from the time it is originally cast and in place. Strengths typically exceed specified design values (28-day or similar). In older construction, concrete strength was often very low (less than 21 MPa) and it was rarely specified in the drawings. Early adoptions of concrete in buildings often used steel reinforcement with relatively low strength and ductility, limited continuity, and reduced bond development. Continuity between specific existing components and elements, such as beams, columns, diaphragms, and shear walls, can be particularly difficult to assess because of concrete cover and other barriers to inspection.

Properties of welded wire reinforcement for various periods of construction can be obtained from the **Wire Reinforcement Institute (2009)**.

Documentation of the material properties and grades used in component and connection construction is invaluable and can be effectively used to reduce the amount of in-place testing required. The licensed design professional is encouraged to research and acquire all available records from original construction, including photographs, to confirm reinforcement details shown on the plans.

Further guidance on the condition assessment of existing concrete buildings can be found in the following:

- a) **ACI 201.1R**, which provides guidance on conducting a condition survey of existing concrete structures
- b) **ACI 364.1R**, which describes the general procedures used for the evaluation of concrete structures before retrofit
- c) **ACI 437R**, which describes methods for strength evaluation of existing concrete buildings, including analytical and load test methods

C2.2—Properties of in-place materials and components*C2.2.1 Material properties*