

ANSI/ICEA S-121-733-2016

STANDARD FOR

Tree Wire and Messenger Supported Spacer Cable

Standard

ANSI/ICEA Publication S-121-733-2016

Developed and Published By

Insulated Cable Engineers Association, Inc.

www.icea.net

Approved by Insulated Cable Engineers Association, Inc.: June 2016

Approved by ANSI: September 23, 2016

© Copyright 2016 by the Insulated Cable Engineers Association, Incorporated. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The Insulated Cable Engineers Association, Inc. (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While ICEA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgements contained in its standards and guideline publications.

ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. ICEA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, ICEA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgement or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

ICEA has no power, nor does it undertake to police or enforce compliance with the contents of this document. ICEA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to ICEA and is solely the responsibility of the certifier or maker of the statement.

FOREWORD

ICEA standards and guides are adopted in the public interest and are designed to eliminate misunderstanding between the manufacturer and user and to assist the user in selecting and obtaining proper products for his particular need. Existence of an ICEA standard or guide does not in any respect preclude the manufacture or use of products not conforming to the standard or guide.

The user of this Standard is cautioned to observe any applicable health or safety regulations and rules relative to the manufacture and use of cable made in conformity with this Standard. This Standard hereafter assumes that manufacture, testing, installation and maintenance of cables defined by this publication will be performed only by properly trained personnel using suitable equipment.

Requests for interpretation of this ICEA Standard must be submitted in writing (hard copy, email, or fax) to the Insulated Cable Engineers Association to the ICEA Secretary. The mailing address of Headquarters and a contact link are shown on the ICEA web site – www.icea.net. An official written interpretation will be provided.

The members of the ICEA working group contributing to the writing of this Standard consisted of the following:

K. Nuckles, Chairman

J. Armstrong
F. Clark
F. Kuchta
J. Maximo
R. Szilagyi
M. Zedack

M. Bodziony
A. Davila
P. Leblanc
H. Soleski
J. Weitzel
D. Zhao

R. Bristol
B. Fleming
M. Levitre
C. Spradlin
R. Young

Table of Contents

		<u>Page</u>
Section 1	General	
1.1	Scope	1
1.2	Design Options	1
1.3	Operating Conditions	1
1.4	Testing and Test Frequency	2
1.5	Test Methods	2
1.6	Definitions	2
Section 2	Conductors	
2.0	General	4
2.1	Physical and Electrical Properties	4
	2.1.1 Copper Conductors	4
	2.1.2 Aluminum Conductors	4
	2.1.3 Aluminum Conductor, Coated-Steel Reinforced (ACSR)	4
	2.1.4 Aluminum Conductor, Aluminum - Alloy Reinforced (ACAR)	5
2.2	Conductor Size Units	5
2.3	Conductor dc Resistance Per Unit Length	5
	2.3.1 Direct Measurement of dc Resistance Per Unit Length	5
	2.3.2 Calculation of dc Resistance Per Unit Length	6
2.4	Conductor Diameter	6
2.5	Water Blocking Components for Stranded Conductors (Optional)	6
Section 3	Conductor Shield (Stress Control Layer) – If Required	
3.0	General	13
3.1	Material	13
3.2	Extruded Shield Thickness	13
3.3	Voids	14
3.4	Physical Requirements	14
3.5	Electrical Requirements	14
	3.5.1 Extruded Semiconducting Material	14
	3.5.2 Semiconducting Tape	14
3.6	Crosslinked (thermoset) Requirements	14
3.7	Covering Removal Test	14
Section 4	Covering	
4.0	General	15
4.1	Material	15
	4.1.1 Requirements for 75°C Covering for Normal Service Operation	15
	4.1.2 Requirements for 90°C Covering for Normal Service Operation	16
4.2	Covering Thickness Requirements	16
4.3	Covering Diameter Requirements	16
4.4	Covering Physical Requirements	16
4.5	Covering Electrical Requirements	17
4.6	Concentricity	17
Section 5	Identification	
5.1	Cable Identification (Optional)	20
	5.1.1 Center Strand Identification (Optional)	20
	5.1.2 Sequential Length Markings (Optional)	20

Section 6	Production Tests and Test Methods	
6.1	General	21
	6.1.1 Testing and Test Frequency	21
	6.1.2 Test Method	21
6.2	Conductor Test Methods	21
	6.2.1 Method for DC Resistance Determination	21
	6.2.1.1 Retests for DC Resistance	22
6.3	Method for Measuring Physical and Air Oven Aging Properties	22
6.4	Method for Measuring Heat Deformation	22
6.5	Method for Measuring Hot Creep	22
6.6	Volume Resistivity	22
	6.6.1 Conductor Shield (Stress Control)	22
	6.6.2 Test Equipment	23
	6.6.3 Test Procedure	23
	6.6.3.1 Two-electrode Method	23
	6.6.3.2 Measurement	23
6.7	Wafer Boil Test for Thermoset Conductor Shields	23
6.8	Covering Removal Test	23
6.9	Concentricity	24
Section 7	Qualification Tests	
7.1	General	26
7.2	Method for Determining Resistance to Environmental Stress Cracking of 75°C Outer Layer Wall Material	26
	7.2.1 Test Specimens	
	7.2.2 Test Procedure	
7.3	Sunlight Resistance of Covering Materials	26
	7.3.1 Qualification	26
	7.3.2 Sunlight Resistance	27
	7.3.2.1 Carbon-Arc Weather-O-Meter	27
	7.3.2.2 Xenon-Arc Weather-O-Meter	27
7.4	Method for Determining Track Resistance of Outer Layer Wall Material	27
7.5	Dielectric Constant	27
7.6	Method for Measuring the Absorption Coefficient of Black 75°C Outer Wall Covering Material	27
Section 8	Appendices	
A	Titles and Dates of Industry Standards Referenced in this Document	29

LIST OF TABLES

2-1	Aluminum 1350 Compact Round Conductor Constructions	7
2-2	Aluminum Conductors, Coated-Steel Reinforced (ACSR), and Aluminum- Clad Steel Reinforced (ACSR/AW) Constructions	8
2-3	Aluminum-Alloy 6201-T81 Conductor Constructions	9
2-4	Nominal DC Resistance at 25°C Stranded Copper Conductor	10
2-5	Nominal Diameters for Copper and Aluminum Conductors	11
2-5 (Metric)	Nominal Diameters for Copper and Aluminum Conductors	12
3-1	Extruded Conductor Shield Thickness (When Used)	13
3-2	Extruded Conductor Shield Requirements	14
4-1	Conductor Sizes, Covering Thicknesses and Test Voltages	18
4-2	Covering Physical Requirements	19
6-1	Summary of Production Tests and Sampling Frequency Requirements	24
6-2	Plan C	25
7-1	Qualification Test Requirements	28

< This page intentionally left blank >

Section 1 GENERAL

1.1 SCOPE

This standard applies to the materials, constructions, and testing of tree wire and messenger supported spacer cable. These conductors are intended primarily for the distribution of electrical energy under normal conditions of overhead (aerial) installations. This standard covers both thermoplastic and crosslinked polyethylene constructions, rated for 75°C or 90°C normal service temperature. They are considered as covered conductors therefore the cables carry no voltage rating. The conductors must be installed on insulators and/or spacers adequate for the service voltage. The user may want to give consideration to the dielectric compatibility of the covering, insulator, spacer and tie wire.

Line wire constructions are covered in ANSI/ICEA S-70-547 – Standard for Weather-Resistant Polyethylene Covered Conductors.

Messenger wires are covered in ANSI/ICEA P-79-561 - Guide for Selecting Aerial Cable Messengers and Lashing Wires.