

Australian Standard™

Cement mortar lining of steel pipes and fittings



S t a n d a r d s Australia

This Australian Standard was prepared by Committee WS-009, Rolled and Welded Steel Pipes. It was approved on behalf of the Council of Standards Australia on 16 March 2001 and published on 21 March 2001.

The following interests are represented on Committee WS-009:

Australian Chamber of Commerce and Industry
Australian Industry Group
New Zealand Manufacturers Federation
Water Services Association of Australia
Department of Land and Water Conservation

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 1281–2001

Cement mortar lining of steel pipes and fittings

RECONFIRMATION NOTICE

Major stakeholders of this publication have reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 29 August 2018.

NOTES

Australian Standard™

Cement mortar lining of steel pipes and fittings

Originated as AS CA41—1965.
Previous edition AS 1281—1993.
Fourth edition 2001.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 3820 6

PREFACE

This Standard was prepared by the Standards Australia Committee WS-009, Rolled and Welded Steel Pipes, to supersede AS 1281—1993.

This edition differs from the 1993 edition in the following respects:

- (a) The specification for aggregates has been changed to take account of changes made to AS 2758.1.
- (b) The specification for cement has been changed to take account of changes made to AS 3972.
- (c) Requirements for recycled water quality have been detailed within this Standard.
- (d) Requirements for admixtures specified for use in hand lining application has been changed.
- (e) Changes have been made to the specification of defects.
- (f) The minimum curing temperature has been reduced to 0°C.
- (g) Set back lengths have been updated.
- (h) The methods for demonstrating compliance with the Standard have been updated. Test frequencies have been included.

The objective of this Standard is to provide the purchasers, suppliers and manufacturers of cement-lined steel pipe with a specification for minimum requirements, and means for demonstrating compliance with this Standard.

This Standard does not apply to the in situ cement mortar lining of pipelines and details of admixtures are not provided.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendices to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is for information and guidance only.

CONTENTS

	<i>Page</i>
1 SCOPE	4
2 REFERENCED DOCUMENTS	4
3 DEFINITIONS	5
4 MATERIALS	6
5 PROPORTIONING OF MATERIALS	7
6 PREPARATION OF STEEL SURFACE	7
7 APPLICATION OF MORTAR	7
8 THICKNESS OF LINING.....	9
9 SURFACE QUALITY/WORKMANSHIP	9
10 CEMENT MORTAR ENDS.....	10
11 CURING OF LINING	11
12 APPLICATION OF CURING COMPOUNDS AND SEAL COATS	13
13 EFFECT OF CEMENT MORTAR LINING ON WATER QUALITY	13
14 HANDLING AND STORING OF PIPES.....	13
 APPENDICES	
A PURCHASING GUIDELINES	14
B MEANS OF DEMONSTRATING COMPLIANCE WITH THIS STANDARD	15
C TABLE OF NOMINAL SIZE AND CORRESPONDING OUTSIDE DIAMETER ..	18

STANDARDS AUSTRALIA

Australian Standard**Cement mortar lining of steel pipes and fittings****1 SCOPE**

This Standard specifies requirements for the cement mortar lining of steel pipes and fittings of 100 mm diameter and greater, by centrifugal, spray or hand application methods, prior to their installation in pipelines. These pipelines are used for the conveyance of water intended for human consumption or for the conveyance of wastewater or process water.

NOTES:

- 1 Guidelines to purchasers on information that should be supplied by the purchaser and those variables that should or may be agreed upon at the time of enquiry or order are given in Appendix A.
- 2 Alternative methods for demonstrating compliance with this Standard are given in Appendix B.

2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

- | | |
|----------|---|
| 1012 | Methods of testing concrete |
| 1012.3.1 | Method 3.1: Determination of the properties related to the consistency of concrete — Slump test |
| 1012.20 | Method 20: Determination of chloride and sulfate in hardened concrete and concrete aggregates |
| 1141 | Methods for sampling and testing aggregates |
| 1141.5 | Part 5: Bulk density and water absorption of fine aggregate |
| 1199 | Sampling procedures and tables for inspection by attributes |
| 1379 | The specification and manufacture of concrete |
| 1627 | Metal finishing — Preparation and pre-treatment of surfaces |
| 1627.9 | Part 9: Pictorial surface preparation standards for painting steel surfaces |
| 2758 | Aggregates and rock for engineering purposes |
| 2758.1 | Part 1: Concrete aggregates |
| 3799 | Liquid membrane-forming curing compounds for concrete |
| 3855 | Suitability of plumbing and water distribution products for contact with potable water |
| 3972 | Portland and blended cements |
| AS/NZS | |
| 3500 | National Plumbing and Drainage Code |
| 3500.0 | Part 0: Glossary of Terms |
| 4020 | Products for use in contact with drinking water |