

AS 1033.2—1988

Reconfirmed 2018

Australian Standard[®]

**HIGH VOLTAGE FUSES (FOR
RATED VOLTAGES EXCEEDING
1000 V)**

**Part 2—CURRENT-LIMITING
(POWDER-FILLED) TYPE**

This Australian Standard was prepared by Committee EL/7, Power Switchgear. It was approved on behalf of the Council of the Standards Association of Australia on 25 November 1987 and published on 5 February 1988.

The following interests are represented on Committee EL/7:

Australian British Chamber of Commerce
Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Electricity Supply Association of Australia
Institution of Engineers Australia
Railways of Australia Committee
Testing authorities

Representative of the following interests also participated in the preparation of this Standard:

Electricity Supply Engineers Association of New South Wales

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 86019.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 1033.2-1988

**High voltage fuses (for rated voltages exceeding 1000 V)
Part 2-Current-limiting (powder-filled) type**

RECONFIRMATION NOTICE

Technical Committee EL-007 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 1 August 2018.

The following are represented on Technical Committee EL-007:

Australian Industry Group
Energy Networks Australia
Engineers Australia
The University of New South Wales

NOTES

AS 1033.2—1988

Australian Standard[®]

**HIGH VOLTAGE FUSES (FOR
RATED VOLTAGES EXCEEDING
1000 V)**

**Part 2—CURRENT-LIMITING
(POWDER-FILLED) TYPE**

First published as AS 1034—1971.
Second edition 1978.
Revised and redesignated as AS 1033.2—1988.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 4862 2

PREFACE

This Standard was prepared by the Association's Committee on Power Switchgear, to supersede AS 1034—1978, *High voltage current-limiting fuses*.

Its publication marks the beginning of the rationalization of the Standards for high voltage fuses into a new series of Standards with the generic designation AS 1033, *High voltage fuses (for rated voltages exceeding 1000 V)*.

The other two Standards in this new series are in course of preparation and when published will be as follows:

AS

1033.1 *Expulsion and similar type*

1033.3 *Application guide*

When published, AS 1033.1 will supersede AS 1033—1971, *High-voltage expulsion and similar fuses*.

This Standard is based on the third edition of IEC 282-1* and also the performance and test requirements of fuse-links for motor circuit and transformer circuit applications in IEC 644† and IEC 787‡ respectively. Acknowledgement is made of the assistance received from these IEC Standards.

Its editorial format is different from that of IEC 282-1.

Appendix D of this Standard is based on Appendix D of IEC 282-1, but shows only the dimensions of current-limiting fuse-links that are commonly used in Australia.

Where this Standard deviates from the technical requirements of the above IEC Standards, by way of amended or additional requirements, this is indicated by a rule in the margin against the clause or part thereof affected. These deviations are summarized in Appendix F.

* IEC 282-1 High-voltage fuses
Part 1: Current-limiting fuses.

† IEC 644 Specification for high-voltage fuse-links for motor circuit applications.

‡ IEC 787 Application guide for the selection of fuse-links of high-voltage fuses for transformer circuit applications.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 REFERENCED DOCUMENTS	5
1.3 SERVICE CONDITIONS	5
SECTION 2. DEFINITIONS	
2.1 GENERAL	6
2.2 ELECTRICAL CHARACTERISTICS	6
2.3 FUSES AND THEIR COMPONENT PARTS	6
2.4 ADDITIONAL TERMS	6
SECTION 3. RATINGS AND STANDARD CONDITIONS OF USE AND BEHAVIOUR	
3.1 RATINGS	8
3.2 STANDARD CONDITIONS OF USE AND BEHAVIOUR	10
SECTION 4. TYPE TESTS	
4.1 CONDITIONS FOR TYPE TESTS	11
4.2 LIST OF TYPE TESTS	11
4.3 TEST PRACTICES COMMON TO ALL TYPE TESTS	11
4.4 DIELECTRIC TESTS	11
4.5 TEMPERATURE-RISE AND POWER-DISSIPATION TESTS	12
4.6 BREAKING TESTS	13
4.7 TESTS FOR TIME/CURRENT CHARACTERISTICS	23
4.8 OIL-TIGHTNESS TEST	23
4.9 TEST OF STRIKERS	23
SECTION 5. SPECIAL TESTS	
5.1 CONDITIONS FOR MAKING THE TESTS	27
5.2 LIST OF SPECIAL TESTS	27
5.3 THERMAL SHOCK TESTS	27
5.4 WEATHERPROOF TEST	27
5.5 POWER DISSIPATION TESTS	27
5.6 RADIO-INTERFERENCE VOLTAGE (RIV) TEST	27
SECTION 6. SPECIFICATIONS FOR CURRENT-LIMITING (POWDER- FILLED) FUSES	
6.1 TEMPERATURE-RISE LIMITS	28
6.2 SWITCHING-VOLTAGES	28
6.3 TIME/CURRENT CHARACTERISTICS	29
6.4 <i>K</i> FACTOR OF FUSE-LINKS FOR MOTOR CIRCUIT APPLICATIONS	29
6.5 WITHSTAND REQUIREMENTS OF FUSE-LINKS FOR MOTOR CIRCUIT APPLICATIONS	29
6.6 CUT-OFF CHARACTERISTICS	29
6.7 I^2t CHARACTERISTICS	29
6.8 MECHANICAL CHARACTERISTICS OF STRIKERS	29
6.9 MARKING AND INFORMATION TO BE GIVEN TO THE PURCHASER	30
APPENDICES	
A METHOD OF DRAWING THE ENVELOPE OF THE PROSPECTIVE TRANSIENT RECOVERY VOLTAGE OF A CIRCUIT AND DETERMINING THE REPRESENTATIVE PARAMETERS	31

	<i>Page</i>
B REASONS FOR CHOICE OF TRV VALUES FOR TEST DUTIES 1, 2 AND 3	33
C PREFERRED ARRANGEMENTS FOR TEMPERATURE-RISE TESTS OF OIL-TIGHT FUSE-LINKS FOR SWITCHGEAR	35
D STANDARDIZATION OF TYPES AND PREFERRED DIMENSIONS OF CURRENT-LIMITING (POWDER-FILLED) FUSES	36
E ITEMS SUBJECT TO AGREEMENT BETWEEN THE PURCHASER AND THE MANUFACTURER	38
F SUMMARY OF TECHNICAL VARIATIONS BETWEEN THIS STANDARD AND IEC 282-1 AND IEC 644	39

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

HIGH VOLTAGE FUSES (FOR RATED VOLTAGES EXCEEDING 1000 V)

PART 2: CURRENT-LIMITING (POWDER-FILLED) TYPE

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard specifies requirements for all types of high voltage current-limiting (powder-filled) fuses designed for use outdoors or indoors on alternating current systems of 50 Hz and 60 Hz and of rated voltages exceeding 1000 V.

Fuses provided with fuse-links equipped with an indicating device or a striker come within the scope of this Standard, but the correct operation of the striker in combination with the tripping device of a switch is outside the scope of this Standard (see AS 2024).

This Standard does not cover expulsion and similar type fuses or the application of high voltage fuses (see Preface).

1.2 REFERENCED DOCUMENTS. The Standards referred to in this Standard are as follows:

- AS
1544 Methods for impact tests on metals
Part 1: Izod (AS 1544.1)
- 1852 International electrotechnical vocabulary
1852(441)—Switchgear, controlgear and fuses
- 1931 High voltage testing techniques
Part 1: General definitions, test requirements, test procedures, and measuring devices (AS 1931.1)
- 2006 High voltage a.c. switchgear and control-gear—Circuit-breakers for rated voltages above 1000 V
- 2024 High voltage fuse/switch combinations and fuse/circuit-breaker combinations
- 2650 High voltage a.c. switchgear and control-gear—Common requirements

- AS
2752 Preferred numbers and their use
- ISO
179 Plastics—Determination of Charpy impact strength of rigid materials

1.3 SERVICE CONDITIONS. Clause 2 of AS 2650 applies with the following addition:

- (a) *Altitude correction factors for rated current and temperature-rise limits.* Where fuses are required for use at altitudes above 1000 m, the rated current or temperature-rise limit in this Standard shall be corrected by using the appropriate correction factors in Table 1.1, Columns 2 and 3 respectively. One correction factor shall be used from either Column 2 or Column 3, but not both for any one application.

TABLE 1.1
ALTITUDE CORRECTION FACTORS FOR
RATED CURRENT AND TEMPERATURE-RISE
LIMITS

1	2	3
Maximum altitude m	Correction factor rated current	Correction factor for temperature rise limit referred to sea level
1000	1.0	1.0
1500	0.99	0.98
3000	0.96	0.92

NOTE: For altitudes between 1000 m and 1500 m, and between 1500 m and 3000 m, the correction factors may be obtained by linear interpolation.