



High-voltage test techniques

Part 1: General definitions and test requirements



AS IEC 60060.1:2018

This Australian Standard® was prepared by EL-007, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 27 September 2018.

This Standard was published on 18 October 2018.

The following are represented on Committee EL-007:

- Australian Industry Group
- Energy Networks Australia
- Engineers Australia
- Testing Interest of Australia
- University of New South Wales

This Standard was issued in draft form for comment as DR AS IEC 60060.1:2018.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.saiglobal.com (sales and distribution)

ISBN 978 1 76072 201 2



High-voltage test techniques

Part 1: General definitions and test requirements

First published as AS IEC 60060.1:2018.

COPYRIGHT

© IEC — All rights reserved
© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Published by SAI Global Pty Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia.

Preface

This Standard was prepared by the Standards Australia Committee EL-007, Power Switchgear.

The objective of this Standard is to set out general definitions and test requirements applicable to dielectric tests with alternating voltage, dielectric tests with direct voltage, dielectric tests with impulse voltage and dielectric tests with combinations of the above. This document is applicable to tests on equipment having its highest voltage for equipment U_m above 1 kV.

This Standard is identical with, and has been reproduced from, IEC 60060-1:2010, *High-voltage test techniques — Part 1: General definitions and test requirements*.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this International Standard/this part of IEC 60060” should read “this Australian Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
3.1 Definitions related to characteristics of discharges	8
3.2 Definitions relating to characteristics of the test voltage	8
3.3 Definitions relating to tolerance and uncertainty	9
3.4 Definitions relating to statistical characteristics of disruptive-discharge voltage values	9
3.5 Definitions relating to classification of insulation in test objects	10
4 General requirements	11
4.1 General requirements for test procedures.....	11
4.2 Arrangement of the test object in dry tests	11
4.3 Atmospheric corrections in dry tests	12
4.3.1 Standard reference atmosphere.....	12
4.3.2 Atmospheric correction factors for air gaps	12
4.3.3 Application of correction factors.....	13
4.3.4 Correction factor components	13
4.3.5 Measurement of atmospheric parameters	16
4.3.6 Conflicting requirements for testing internal and external insulation.....	17
4.4 Wet tests	18
4.4.1 Wet test procedure	18
4.4.2 Atmospheric corrections for wet tests	19
4.5 Artificial pollution tests	19
5 Tests with direct voltage	19
5.1 Definitions for direct voltage tests.....	19
5.2 Test voltage	20
5.2.1 Requirements for the test voltage	20
5.2.2 Generation of the test voltage.....	20
5.2.3 Measurement of the test voltage.....	20
5.2.4 Measurement of the test current	21
5.3 Test procedures	21
5.3.1 Withstand voltage tests	21
5.3.2 Disruptive-discharge voltage tests	22
5.3.3 Assured disruptive-discharge voltage tests	22
6 Tests with alternating voltage	22
6.1 Definitions for alternating voltage tests.....	22
6.2 Test Voltage.....	22
6.2.1 Requirements for the test voltage	22
6.2.2 Generation of the test voltage.....	23
6.2.3 Measurement of the test voltage.....	24
6.2.4 Measurement of the test current	25
6.3 Test procedures	25
6.3.1 Withstand voltage tests	25
6.3.2 Disruptive-discharge voltage tests	25
6.3.3 Assured disruptive-discharge voltage tests	25

7	Tests with lightning-impulse voltage	26
7.1	Definitions for lightning-impulse voltage tests	26
7.2	Test Voltage	33
7.2.1	Standard lightning-impulse voltage	33
7.2.2	Tolerances	34
7.2.3	Standard chopped lightning-impulse voltage	34
7.2.4	Special lightning-impulse voltages	34
7.2.5	Generation of the test voltage	34
7.2.6	Measurement of the test voltage and determination of impulse shape	34
7.2.7	Measurement of current during tests with impulse voltages	35
7.3	Test Procedures	35
7.3.1	Withstand voltage tests	35
7.3.2	Procedures for assured disruptive-discharge voltage tests	36
8	Tests with switching-impulse voltage	36
8.1	Definitions for switching-impulse voltage tests	36
8.2	Test voltage	38
8.2.1	Standard switching-impulse voltage	38
8.2.2	Tolerances	38
8.2.3	Time-to-peak evaluation	38
8.2.4	Special switching-impulse voltages	38
8.2.5	Generation of the test voltage	38
8.2.6	Measurement of test voltage and determination of impulse shape	39
8.2.7	Measurement of current during tests with impulse voltages	39
8.3	Test procedures	39
9	Tests with combined and composite voltages	39
9.1	Definitions for combined- and composite-voltage tests	39
9.2.4	Tolerances	42
9.2.5	Generation	42
9.2.6	Measurement	42
9.3	Composite test voltages	43
9.3.1	Parameters	43
9.3.2	Tolerances	43
9.3.3	Generation	43
9.3.4	Measurement	43
9.4	Test procedures	43
	Annex A (informative) Statistical treatment of test results	45
	Annex B (normative) Procedures for calculation of parameters of standard lightning-impulse voltages with superimposed overshoot or oscillations	54
	Annex C (informative) Guidance for implementing software for evaluation of lightning-impulse voltage parameters	59
	Annex D (informative) Background to the introduction of the test voltage factor for evaluation of impulses with overshoot	62
	Annex E (informative) The iterative calculation method in the converse procedure for the determination of atmospheric correction factor	68
	Bibliography	73

Figure 1 – Recommended minimum clearance D of extraneous live or earthed objects to the energized electrode of a test object, during an a.c. or positive switching impulse test at the maximum voltage U applied during test

12

Figure 2 – k as a function of the ratio of the absolute humidity h to the relative air density ρ (see 4.3.4.2 for limits of applicability) 14

Figure 3 – Values of exponents m and w 16

Figure 4 – Absolute humidity of air as a function of dry- and wet-bulb thermometer readings 17

Figure 5 – Full lightning-impulse voltage 26

Figure 6 – Test voltage function 28

Figure 7 – Full impulse voltage time parameters 29

Figure 8 – Voltage time interval 30

Figure 9 – Voltage integral 30

Figure 10 – Lightning-impulse voltage chopped on the front 31

Figure 11 – Lightning-impulse voltage chopped on the tail 32

Figure 12 – Linearly rising front chopped impulse 32

Figure 13 – Voltage/time curve for impulses of constant prospective shape 33

Figure 14 – Switching-impulse voltage 37

Figure 15 – Circuit for a combined voltage test 40

Figure 16 – Schematic example for combined and composite voltage 41

Figure 17 – Circuit for a composite voltage test 42

Figure 18 – Definition of time delay Δt 43

Figure A.1 – Example of a multiple-level (Class 1) test 48

Figure A.2 – Examples of decreasing and increasing up-and-down (Class 2) tests for determination of 10 % and 90 % disruptive-discharge probabilities respectively 49

Figure A.3 – Examples of progressive stress (Class 3) tests 50

Figure B.1 – Recorded and base curve showing overshoot and residual curve 55

Figure B.2 – Test voltage curve (addition of base curve and filtered residual curve) 55

Figure B.3 – Recorded and test voltage curves 56

Figure D.1 – “Effective” test voltage function in IEC 60060-1:1989 63

Figure D.2 – Representative experimental points from European experiments and test voltage function 65

Figure E.1 – Atmospheric pressure as a function of altitude 69

Table 1 – Values of exponents, m for air density correction and w for humidity correction, as a function of the parameter g 15

Table 2 – Precipitation conditions for standard procedure 19

Table A.1– Discharge probabilities in up-and-down testing 52

Table E.1 – Altitudes and air pressure of some locations 69

Table E.2 – Initial K_t and its sensitivity coefficients with respect to U_{50} for the example of the standard phase-to-earth a.c. test voltage of 395 kV 70

Table E.3 – Initial and converged K_t values for the example of the standard phase-to-earth a.c. test voltage of 395 kV 72

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE TEST TECHNIQUES –**Part 1: General definitions and test requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60060-1 has been prepared by IEC technical committee 42: High-voltage test techniques.

This third edition of IEC 60060-1 cancels and replaces the second edition, published in 1989, and constitutes a technical revision.

The significant technical changes with respect to the previous edition are as follows:

- a) The general layout and text was updated and improved to make the standard easier to use.
- b) Artificial pollution test procedures were removed as they are now described in IEC 60507.
- c) Measurement of impulse current has been transferred to a new standard on current measurement (IEC 62475).
- d) The atmospheric correction factors are now presented as formulas.

- e) A new method has been introduced for the calculation of the time parameters of lightning impulse waveforms. This improves the measurement of the time parameters of lightning impulses with oscillations or overshoot.

The text of this standard is based on the following documents:

FDIS	Report on voting
42/277/FDIS	42/282/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2

A list of all the parts in the IEC 60060 series, under the general title *High-voltage test techniques*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to this specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition or
- amended.

HIGH-VOLTAGE TEST TECHNIQUES –

Part 1: General definitions and test requirements

1 Scope

This part of IEC 60060 is applicable to:

- dielectric tests with direct voltage;
- dielectric tests with alternating voltage;
- dielectric tests with impulse voltage;
- dielectric tests with combinations of the above.

This part is applicable to tests on equipment having its highest voltage for equipment U_m above 1 kV.

NOTE 1 Alternative test procedures may be required to obtain reproducible and significant results. The choice of a suitable test procedure should be made by the relevant Technical Committee.

NOTE 2 For voltages U_m above 800 kV meeting some specified procedures, tolerances and uncertainties may not be achievable.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60507:1991, *Artificial pollution tests on high-voltage insulators to be used on a.c. systems*

IEC 61083-1, *Instruments and software used for measurement in high-voltage impulse tests – Part 1: Requirements for instruments*

IEC 61083-2, *Digital recorders for measurements in high-voltage impulse tests – Part 2: Evaluation of software used for the determination of the parameters of impulse waveforms*

IEC 62475, *High-current test techniques: Definitions and requirements for test currents and measuring systems*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.