

Australian/New Zealand Standard™

Lamp Controlgear

**Part 2.9: Particular requirements
for electromagnetic controlgear for
discharge lamps (excluding fluorescent
lamps) (IEC 61347-2-9:2012
(ED. 2.0), MOD)**



AS/NZS 61347.2.9:2019

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-041, Lamps and Related Equipment. It was approved on behalf of the Council of Standards Australia on 15 October 2018 and by the New Zealand Standards Approval Board on 6 November 2018.

This Standard was published on 20 February 2019.

The following are represented on Committee EL-041:

- Australian Industry Group
- Consumers' Federation of Australia
- Department of the Environment and Energy (Australian Government)
- Electrical Compliance Testing Association of Australia
- Electrical Regulatory Authorities Council
- IES: The Lighting Society
- Joint Accreditation System of Australia and New Zealand
- Lighting Council Australia
- Lighting Council New Zealand
- Master Electricians Australia
- WorkSafe New Zealand

This Standard was issued in draft form for comment as DR AS/NZS 61347.2.9:2018.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

www.saiglobal.com (sales and distribution)

ISBN 978 1 76072 265 4

Australian/New Zealand Standard™

Lamp Controlgear

Part 2.9: Particular requirements for electromagnetic controlgear for discharge lamps (excluding fluorescent lamps) (IEC 61347-2-9:2012 (ED. 2.0), MOD)

First published in Australia as part of AS 1468—1974.
Jointly revised and redesignated AS/NZS 60922:1998.
Jointly revised and redesignated AS/NZS 61347.2.9:2004.
Second edition AS/NZS 61347.2.9:2019.

COPYRIGHT

© IEC — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2019

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Pty Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, PO Box 1473, Wellington 6140.

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-041, Lamps and Related Equipment to supersede AS/NZS 61347.2.9:2004, *Lamp controlgear, Part 2.9: Particular requirements for ballasts for discharge lamps (excluding fluorescent lamps)* (IEC 61347-2-9:2000 MOD).

The objective of this Standard is to specify particular safety requirements for electromagnetic controlgear for discharge lamps such as high-pressure mercury vapour, low-pressure sodium vapour, high-pressure sodium vapour and metal halide lamps. The Standard covers inductive-type electromagnetic controlgear for use on a.c. supplies up to 1 000 V at 50 Hz or 60 Hz, associated with discharge lamps, having rated wattages, dimensions and characteristics as specified in IEC 60188, IEC 60192 and IEC 60662.

This Standard is an adoption with national modifications, and has been reproduced from, IEC 61347-2-9:2012 (ED.2.0), *Lamp controlgear — Part 2-9: Particular requirements for electromagnetic controlgear for discharge lamps (excluding fluorescent lamps)*. Appendix ZZ lists the variations for the application of this Standard in Australia and New Zealand.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of the IEC 61347 series” should read “this Australian/New Zealand Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 General requirements	8
4.1 General	8
4.2 Capacitors and other components	8
4.3 Thermally protected electromagnetic controlgear	8
5 General notes on tests	8
6 Classification	9
7 Marking	9
7.1 General	9
7.2 Mandatory markings	9
7.3 Information to be provided, if applicable	9
7.4 Other information	9
8 Protection against accidental contact with live parts	10
9 Terminals	10
10 Provisions for earthing	10
11 Moisture resistance and insulation	10
12 Electric strength	10
13 Thermal endurance test for windings	10
14 Electromagnetic controlgear heating	10
14.1 General	10
14.2 Test requirements	10
14.3 Normal operating condition	11
14.4 Abnormal operating condition	11
15 High-voltage impulse testing	14
15.1 General	14
15.2 Test for electromagnetic controlgear operating with lamp with external starting devices	14
15.3 Test for electromagnetic controlgear operating with lamps with internal starting devices	14
16 Fault conditions	16
17 Construction	16
18 Creepage distances and clearances	16
19 Screws, current-carrying parts and connections	16
20 Resistance to heat, fire and tracking	16
21 Resistance to corrosion	16
22 No-load output voltage	16
Annex A (normative) Test to establish whether a conductive part is a live part which may cause an electric shock	17
Annex B (normative) Particular requirements for thermally protected lamp electromagnetic controlgear	18

Annex C (normative) Particular requirements for electronic lamp controlgear with means of protection against overheating	19
Annex D (normative) Requirements for carrying out the heating tests of thermally protected lamp electromagnetic controlgear	20
Annex E (normative) Use of constant S other than 4 500 in t_w tests.....	21
Annex F (normative) Draught-proof enclosure	22
Annex G (normative) Explanation of the derivation of the values of pulse voltages	23
Annex H (normative) Tests.....	24
Annex I (normative) Method for selection of varistors	25
Annex J (informative) Explanation of electromagnetic controlgear temperatures	26
Annex K (normative) Additional requirements for built-in electromagnetic controlgear with double or reinforced insulation.....	29
Bibliography.....	30
Figure 1 – Test circuit for electromagnetic controlgear for lamps with integral starting devices	15
Figure J.1 – Test hood for electromagnetic controlgear heating test.....	28
Figure J.2 – Test corner for electromagnetic controlgear heating	28
Table 1 – Test voltages for electromagnetic controlgear generating pulse voltages.....	10
Table 2 – Maximum temperatures	12
Table 3 – Limiting temperatures of windings under abnormal operating conditions and at 110 % of rated voltage for electromagnetic controlgear subjected to endurance test duration of 30 days	13
Table 4 – Limiting temperatures of windings under abnormal operating conditions and at 110 % of rated voltage for electromagnetic controlgear marked D6 which are subjected to an endurance test duration of 60 days	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LAMP CONTROLGEAR –

Part 2-9: Particular requirements for electromagnetic controlgear for discharge lamps (excluding fluorescent lamps)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61347-2-9 has been prepared by subcommittee 34C: Auxiliaries for lamps, of IEC technical committee 34: Lamps and related equipment.

This second edition cancels and replaces the first edition published in 2000, Amendment 1:2003 and Amendment 2:2006. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the addition of a new Clause 14;
- b) the word "ballast" is changed to "electromagnetic controlgear".

The text of this standard is based on the following documents:

FDIS	Report on voting
34C/1022/FDIS	34C/1028/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard shall be used in conjunction with IEC 61347-1.

This Part 2-9 supplements or modifies the corresponding clauses in IEC 61347-1, so as to convert that publication into the IEC Standard: Particular requirements for electromagnetic controlgear for discharge lamps (excluding fluorescent lamps).

Where the requirements of any of the clauses of IEC 61347-1 are referred to in this standard by the phrase "The requirements of clause n of IEC 61347-1 apply", this phrase is interpreted as meaning that all requirements of the clause in question of Part 1 apply, except any which are clearly inapplicable to the specific type of lamp controlgear covered by this particular part of IEC 61347-2.

NOTE In this standard, the following print types are used:

- Requirements proper: in roman type.
- *Test specifications: in italic type.*
- Explanatory matter: in smaller roman type.

A list of all parts of the IEC 61347 series, published under the general title *Lamp controlgear*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This second edition of IEC 61347-2-9 is published in conjunction with IEC 61347-1. The formatting into separately published parts provides for ease of future amendments and revisions. Additional requirements will be added as and when a need for them is recognized.

This standard, and the parts which make up IEC 61347-2, in referring to any of the clauses of IEC 61347-1, specify the extent to which such a clause is applicable and the order in which the tests are to be performed; they also include additional requirements, as necessary. All parts which make up IEC 61347-2 are self-contained and, therefore, do not include references to each other.

LAMP CONTROLGEAR –

Part 2-9: Particular requirements for electromagnetic controlgear for discharge lamps (excluding fluorescent lamps)

1 Scope

This part of the IEC 61347 series specifies particular safety requirements for electromagnetic controlgear for discharge lamps such as high-pressure mercury vapour, low-pressure sodium vapour, high-pressure sodium vapour and metal halide lamps. The standard covers inductive-type electromagnetic controlgear for use on a.c. supplies up to 1 000 V at 50 Hz or 60 Hz, associated with discharge lamps, having rated wattages, dimensions and characteristics as specified in IEC 60188, IEC 60192 and IEC 60662.

This standard applies to complete electromagnetic controlgear and to their component parts such as reactors, transformers and capacitors. Particular requirements for thermally protected electromagnetic controlgear are given in Annex B.

For certain types of discharge lamps, an ignitor is required.

NOTE Electromagnetic controlgear for fluorescent lamps are covered by IEC 61347-2-8.

Performance requirements are the subject of IEC 60923.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60188, *High-pressure mercury vapour lamps – Performance specifications*

IEC 60192, *Low-pressure sodium vapour lamps – Performance specifications*

IEC 60598-1, *Luminaires – Part 1: General requirements and tests*

IEC 60662, *High-pressure sodium vapour lamps – Performance specifications*

IEC 61347-1:2007, *Lamp controlgear – Part 1: General and safety requirements Amendment 1:2010*

IEC 61347-2-1, *Lamp controlgear – Part 2-1: Particular requirements for starting devices (other than glow starters)*

IEC 62035, *Discharge lamps (excluding fluorescent lamps) – Safety specifications*

3 Terms and definitions

For the purpose of this document, the terms and definitions given in IEC 61347-1:2007, together with the following apply: