

AS 1741—1991
Reconfirmed 2018

Australian Standard[®]

**Vitrified clay pipes and fittings
with flexible joints—Sewer quality**

This Australian Standard was prepared by Committee WS/15, Vitrified Clay Pipes. It was approved on behalf of the Council of Standards Australia on 4 April 1991 and published on 12 July 1991.

The following interests are represented on Committee WS/15:

Australian Clay Pipe Manufacturers Association
Board of Works, Melbourne
Department of Conservation and Environment, Victoria
Engineering and Water Supply Department, South Australia
Hunter Water Board
Public Works Department, New South Wales
Water Authority of Western Australia
Water Board, Sydney—Illawarra—Blue Mountains

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 88215.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 1741–1991

**Vitrified clay pipes and fittings with flexible
joints–Sewer quality**

RECONFIRMATION NOTICE

Major stakeholders of this publication have reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 29 August 2018.

NOTES

Australian Standard®

**Vitrified clay pipes and fittings
with flexible joints—Sewer quality**

First published in part as AS B57—1935.
Revised and redesignated AS A164—1968.
Revised and redesignated AS 1741—1975.
AS A165 first published 1968.
Revised and redesignated AS 1693.1—1975.
AS 1693.2 first published 1977.
AS 1741—1975, AS 1693.1—1975 and AS 1693.2—1977
revised and amalgamated as AS 1741—1991.

PREFACE

This Standard was prepared by the Standards Australia Committee on Vitrified Clay Pipes to supersede AS 1741—1975, *Vitrified clay pipes* and also to supersede AS 1693, *Rubber ring joints for vitrified clay pipes, Part 1—1975: 100 mm diameter* and Part 2—1977: 150 mm diameter.

The dimensional and performance requirements of the Standard are either superior to or equal to those of the 1975 edition. This has been achieved by smaller dimensional tolerances and either increased or additional performance criteria. These requirements are compatible with overseas Standards to ensure international acceptance of this Standard.

The principal changes in this edition are as follows:

- (a) Inclusion of crushing strength class and crushing load instead of pipe class and ring loading and rationalization with Australian Standards for rigid pipes of other material.
- (b) Inclusion of requirements for both socket and sleeve type flexible joints and dimensions for socket type to permit the interchange of production pipes and fittings from different manufacturers.
- (c) Inclusion of an alternative flexural strength test, using bending moment resistance, for nominal sizes DN 100 to DN 225, based on the three-point loading test of BS 65:1988.
- (d) Inclusion of test specimens, wetted by either immersion or internal hydrostatic pressure, for crushing and flexure strength tests.
- (e) Inclusion of a significantly reduced allowable permeability for test pipes.
- (f) Inclusion of a description, size and classification for twelve physical defects and a quantitative basis for the acceptance or rejection of production pipes and fittings.
- (g) Inclusion of acid resistance test, based on BS 65:1988, to measure the degree of vitrification of the manufacturing process as fully vitrified clay is inert.

In the preparation of the Standard, reference was made to BS 65: 1988, *Specification for vitrified clay pipes and fittings, joints and ducts* and the assistance gained from this source is acknowledged.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
FOREWORD	5
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 REFERENCED DOCUMENTS	6
1.3 DEFINITIONS	6
1.4 CLASSIFICATION AND DESIGNATION	7
1.5 RANGE OF NOMINAL SIZES	7
1.6 MATERIALS AND MANUFACTURE	7
1.7 GLAZING	8
SECTION 2 PIPES—DIMENSIONAL REQUIREMENTS	
2.1 INTERNAL DIAMETER	9
2.2 LENGTH	9
2.3 STRAIGHTNESS	9
2.4 OVALITY	9
2.5 CONCENTRICITY	10
2.6 END SQUARENESS	10
2.7 FLEXIBLE JOINTS	10
SECTION 3 PIPES—PERFORMANCE REQUIREMENTS	
3.1 CRUSHING STRENGTH	11
3.2 FLEXURAL STRENGTH	11
3.3 WATER PERMEABILITY	12
3.4 ACID RESISTANCE	12
3.5 STRUCTURAL SOUNDNESS	12
SECTION 4 FITTINGS—DIMENSIONAL REQUIREMENTS	
4.1 DIMENSIONS AND TOLERANCES	13
SECTION 5 FITTINGS—PERFORMANCE REQUIREMENTS	
5.1 CRUSHING STRENGTH	14
5.2 ACID RESISTANCE	14
5.3 STRUCTURAL SOUNDNESS	14
SECTION 6 FLEXIBLE JOINTS—DIMENSIONAL, DESIGN AND PERFORMANCE REQUIREMENTS	
6.1 GENERAL	15
6.2 DIMENSIONS	15
6.3 DESIGN	15
6.4 PERFORMANCE	15
SECTION 7 PIPES AND FITTINGS—PHYSICAL DEFECTS	
7.1 PHYSICAL DEFECTS	17
SECTION 8 MARKING	
8.1 PIPES, FITTINGS AND SLEEVES	19
8.2 JOINT SEALS	19
8.3 GROUPING	19
APPENDICES	
A PURCHASING GUIDELINES	20
B METHODS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	21
C EPOXY ADHESIVES TEST—FITTINGS	22
D STRAIGHTNESS AND END SQUARENESS TESTS—PIPES	24

	<i>Page</i>
E SOCKET TYPE FLEXIBLE JOINTS—DIMENSIONAL REQUIREMENTS	27
F CRUSHING STRENGTH TEST—PIPES AND FITTINGS	29
G BENDING MOMENT RESISTANCE TEST—PIPES WITH AND WITHOUT INTEGRAL SOCKETS	31
H BEAM LOADING STRENGTH TEST—PIPES WITH INTEGRAL SOCKETS	33
I WATER PERMEABILITY TEST—PIPES	35
J ACID RESISTANCE TEST—PIPES AND FITTINGS	38
K BURSTING STRENGTH TEST—FLEXIBLE JOINTS	40
L HYDROSTATIC TEST—PIPES AND FITTINGS	42
M FITTINGS—DIMENSIONS AND TOLERANCES	43
N MECHANICAL TESTS—FLEXIBLE JOINTS	54

FOREWORD

A designer of a vitrified clay pipeline should, among other duties, evaluate the possible conditions to which component pipes, fittings and flexible joints will be exposed.

STANDARDS AUSTRALIA

Australian Standard

Vitrified clay pipes and fittings with flexible joints—Sewer quality

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard specifies requirements for vitrified clay pipes and fittings with flexible joints, for operation under gravity, intended for the conveyance of sewage and industrial waste.

NOTES:

- 1 Appendix A sets out guidelines on the information to be provided by the purchaser at the time of enquiry or order.
- 2 Methods for determining compliance with this Standard are given in Appendix B.

1.2 REFERENCED DOCUMENTS The following documents are referred to in this Standard.

AS

- 1057 Quality assurance and quality control—Glossary of terms
 1152 Test sieves
 1199 Sampling procedures and tables for inspection by attributes
 1293 Retractable steel pocket rules
 1399 Guide to AS 1199—Sampling procedures and tables for inspection by attributes
 1449 Wrought alloy steels—Stainless and heat-resisting steel plate, sheet and strip
 1646 Rubber joint rings for water supply, sewerage and drainage purposes
 2193 Methods for calibration and grading of force-measuring systems of testing machines
 3900 Quality systems—Guide to selection and use
 3904 Quality systems—Guide to quality management and quality system elements

ISO

- 175 Plastics—Determination of the effects of liquid chemicals, including water

BS

- 65 Specification for vitrified clay pipes, fittings, joints and ducts

1.3 DEFINITIONS For the purpose of this Standard, the definitions below apply.

1.3.1 Flexible joint A joint with sealing and deflection performance, as specified in Section 6, for jointing pipes and fittings with elastomeric joint seal or seals housed in either—

- (a) an integrally manufactured socket (socket type); or
- (b) a separately manufactured sleeve (sleeve type).

1.3.2 Production pipe, fitting, sleeve, flexible joint or joint seal A pipe or fitting with or without an integral socket, sleeve or joint seal suitable for jointing with socket type or sleeve type flexible joint, manufactured in accordance with this Standard for the purpose of sale.

1.3.3 Test flexible joint A production flexible joint with the following component dimensions—

- (a) socket or sleeve, maximum diameter of joint seal seating area;
- (b) spigot(s), minimum diameter of joint seal seating area; and
- (c) joint seal(s), minimum uncompressed cord diameter;

for minimum joint seal(s) compression in an assembled joint configuration and representative of a nominated group of production flexible joints.

1.3.4 Test piece A test piece may be either cut from a production pipe or be a clay bar (see Paragraph C4) or be a portion of a test pipe or test fitting (see Paragraph J4).

1.3.5 Test pipe, fitting, sleeve or joint seal A production pipe, fitting, sleeve or joint seal chosen at random and representative of a nominated group of production pipes, fittings, sleeves or joint seals respectively.

1.3.6 Test representative pipe A production pipe or special pipe manufactured using the same blend and materials and manufacturing process (see Clause 1.6.1) as that for the nominated group of production fittings of which it is representative and is deemed to have the crushing strength of such production fittings.