

Australian Standard™

Uninterruptible power systems (UPS)

**Part 2: Electromagnetic compatibility
(EMC) requirements**



S t a n d a r d s Australia

This Australian Standard was prepared by Committee EL-027, Power Electronics. It was approved on behalf of the Council of Standards Australia on 18 January 2001 and published on 21 February 2001.

The following interests are represented on Committee EL-027:

Australian Communications Authority
Australian Electrical and Electronic Manufacturers Association
Bureau of Steel Manufacturers of Australia
Electricity Supply Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Uninterruptible power systems (UPS)

Part 2: Electromagnetic compatibility (EMC) requirements

First published as AS 62040.2—2001.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 3763 3

PREFACE

This Standard was prepared by the Standards Australia Committee EL-027, Power Electronics.

The objective of this Standard is to provide manufacturers, users and regulators with requirements for electromagnetic compatibility (EMC) for uninterruptible power systems (UPS).

This Standard is identical with and has been reproduced from IEC 62040-2:1999, *Uninterruptible power systems (UPS) Part 2: Electromagnetic compatibility (EMC) requirements*.

A reference to an International Standard identified in the Normative References Clause by strikethrough (~~example~~) is replaced by a reference to the Australian or Australian/New Zealand Standard(s) listed immediately thereafter and identified by shading (example). Where the struck-through referenced document and the referenced Australian or Australian/New Zealand Standard are identical, this is indicated in parenthesis after the title of the latter.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this standard' should read 'this Australian Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the annex to which they apply. A 'normative annex' is an integral part of a Standard, whereas an 'informative annex' is only for information and guidance.

CONTENTS

	<i>Page</i>
1 General	1
1.1 Scope	1
1.2 Normative references	2
1.3 Definitions	3
2 Emission	4
2.1 General requirements	4
2.2 Classification of UPS	4
2.3 General measurement conditions	5
2.3.1 Documentation for the purchaser/user	6
2.3.2 Applicability	6
2.4 Conducted emissions	6
2.4.1 Limits of mains terminal interference voltage	6
2.4.2 Limits of a.c. output interference voltage	7
2.4.3 Limits of signal ports	7
2.4.4 Limits of d.c. ports	7
2.4.5 Low frequency emissions – Input current harmonics	7
2.5 Radiated emissions	8
2.5.1 Electric field	8
2.5.2 Magnetic field (optional)	8
2.5.3 Limits of power (under consideration)	8
3 Immunity	8
3.1 General requirements and performance criteria	9
3.2 Immunity to electrostatic discharges	9
3.3 Immunity to radiated electromagnetic fields	9
3.4 Immunity to fast transients	9
3.5 Immunity to surges	10
3.6 Immunity to low-frequency signals	10
Annexes	
A Electromagnetic emission – Test methods	11
B Electromagnetic emission limits of magnetic field – H field (optional where requested by purchaser)	26
C Electromagnetic emission – Limits of signal ports	27
D Electromagnetic immunity – Test methods	28
E UPS attenuation test method (under consideration)	32

NOTES

STANDARDS AUSTRALIA

Australian Standard

Uninterruptible power systems (UPS)

Part 2: Electromagnetic compatibility (EMC) requirements

Any IEC table, figure or passage of text that is struck-through is not part of this Standard. Any Australian table, figure or passage of text that is added (and identified by shading) is part of this Standard.

1 General**1.1 Scope**

This International Standard applies to single UPS units or UPS systems comprising a number of interconnected UPS and associated control/switchgear forming a single power system, intended to be installed in any operator accessible area or in separated electrical locations, connected to either industrial or public low voltage supply networks.

This product EMC standard takes precedence over all aspects of the generic standards, and no additional testing is necessary.

The requirements have been selected so as to ensure an adequate level of electromagnetic compatibility (EMC) for UPS at public and industrial locations. These levels cannot, however, cover extreme cases which may occur in any location, but with extremely low probability of occurrence.

It takes into account differing test conditions necessary to encompass the range of physical sizes and power ratings of UPS.

A UPS unit or system shall meet the relevant requirements of this standard as a stand-alone product. EMC phenomena produced by any customers' load connected to the output of the UPS equipment shall not be taken into account.

Special installation environments are not covered, nor are fault conditions of UPS taken into account.

This standard does not cover d.c. supplied electronic ballast (IEC 60924 and IEC 60925) or UPS based on rotating machines.

This standard states:

- EMC requirements;
- test methods;
- minimum performance levels.