

Australian Standard[®]

**Approval and test specification—
Semi-enclosed fuses for a.c. circuits**

This Australian Standard was prepared by Committee EL/4, Electrical Accessories. It was approved on behalf of the Council of Standards Australia on 12 June 1997 and published on 5 September 1997.

The following interests are represented on Committee EL/4:

Australasian Railway Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronics Manufacturers Association
Consumer Electronics Suppliers Association
Electricity Supply Association of Australia
Ministry of Commerce, New Zealand
National Electrical Contractors Association of Australia
New Zealand Manufacturers Federation
Plastics and Chemical Industries Association Inc
Regulatory authorities (electrical)
Testing interests

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 97027.

Australian Standard[®]

**Approval and test specification—
Semi-enclosed fuses for a.c. circuits**

Originated as AS C35—1941.
Previous edition AS 3135—1980.
Third edition 1997.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL/4, Electrical Accessories, to supersede AS 3135—1980 from the date of publication.

This Standard is the result of a consensus among Australian and New Zealand representatives on the Joint Committee to produce it as an Australian Standard.

This Standard is one of a series of Approval and Test specifications issued by Standards Australia. It is to be read in conjunction with AS 3100, *Approval and test specification—General requirements for electrical equipment*.

The objective of these Standards is to outline the conditions that must be met to secure approval for the sale and use of electrical equipment. Only safety matters and related conditions are covered.

The Standard was revised to incorporate Amendment 1, to introduce a table for the cross-sectional area for the wiring in test circuits (Table 3) and to effect some editorial changes to bring it into line with current Standards Australia practice.

The term 'normative' has been used in this Standard to define the application of the appendix to which it applies. A 'normative' appendix is an integral part of a Standard.

This Standard does not provide all the necessary conditions for a contract.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
1 SCOPE	4
2 REFERENCED DOCUMENTS	4
3 DEFINITIONS	4
4 COMPLIANCE	5
5 STANDARD CONDITION FOR OPERATION IN SERVICE	6
6 PREFERRED VOLTAGE RATINGS, PREFERRED CURRENT RATINGS AND CATEGORIES OF DUTY	6
7 TEMPERATURE LIMITS	6
8 DESIGN AND CONSTRUCTION	6
9 MARKING	7
10 TESTS	8
 APPENDICES	
A DETERMINATION OF POWER FACTOR OF THE TEST CIRCUIT	14
B MEASUREMENT OF RECOVERY VOLTAGE AND TRANSIENT RECOVERY VOLTAGE	16
C MEASUREMENT OF PROSPECTIVE CURRENT	18

STANDARDS AUSTRALIA

Australian Standard

Approval and test specification—Semi-enclosed fuses for a.c. circuits

1 SCOPE This Standard specifies essential safety requirements for semi-enclosed electric fuses, with current ratings up to, and including, 100 A, intended for installation as protective devices required under AS 3000 and intended for use in 50 Hz a.c. circuits with voltages not exceeding 650 V.

In general, these fuses are used to protect circuits having a prospective fault current up to 4 kA. Household installations usually come within this category.

NOTE: At currents smaller than rated minimum fusing current, the fuses do not give protection, because they do not blow, or blow only after an indeterminately long time. They may, however, deteriorate if they continuously carry currents greater than rated current.

2 REFERENCED DOCUMENTS The following documents are referred to in this Standard:

AS

1152 Specification for test sieves

3000 Electrical installations—Buildings, structures and premises (known as the SAA Wiring Rules)

3100 Approval and test specification—General requirements for electrical equipment

3 DEFINITIONS For the purpose of this Standard, the definitions below apply

3.1 Breaking current—the prospective current that a fuse is capable of breaking when tested in accordance with Clause 10.6.

3.2 Categories of duty—a code reference to the breaking current rating in kiloamperes (kA) and the power factor associated with it. The code consists of the letter 'A' followed by the breaking current value in kA (see Clause 6.3).

3.3 Conventional fusing current (I_f)—a value of current specified as that which causes operation of the fuse link within a specified time (conventional time).

3.4 Fuse—a device that, by the fusing of one or more of its specially designed and proportioned components, opens the circuit in which it is inserted and breaks the current when it exceeds a given value for a sufficient time. The fuse comprises all the parts that form the complete device (see Figure 1).

3.5 Fuse base—the fixed part of a fuse provided with terminals for connection to the external circuit.

3.6 Fuse-base contact (fixed contact)—a conducting part of a fuse base, connected to a terminal and intended to engage with a fuse-carrier contact.

3.7 Fuse carrier—the removable part of a fuse designed to carry the fuse element.

3.8 Fuse-carrier contact—a conducting part of a fuse carrier intended to engage with a fuse-base contact.

3.9 Fuse element—the part of a fuse designed to melt when the fuse operates.