

Australian/New Zealand Standard™

**Anhydrous ammonia—Storage and
handling**

AS/NZS 2022:2003

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee ME-032, Anhydrous Ammonia Storage and Handling. It was approved on behalf of the Council of Standards Australia on 28 February 2003 and on behalf of the Council of Standards New Zealand on 5 March 2003. It was published on 25 March 2003.

The following are represented on Committee ME-032:

Australian Chamber of Commerce and Industry
Australasian Fire Authorities Council
Australian Industrial Gas Manufacturers Association
Department for Administrative and Information Services, S.A.
New Zealand chemical Industry Council
Plastics and Chemical Industries Association
Victorian WorkCover Authority
WorkCover New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Anhydrous ammonia—Storage and handling

Originated as AS CB23—1969.
Previous edition AS 2022—1983.
AS 2022—1983 jointly revised and designated AS/NZS 2022:2003.
Reissued incorporating Amendment No. 1 (December 2003).

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 5106 7

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee ME-032, Anhydrous Ammonia Storage and Handling to supersede AS 2022—1983, *Anhydrous ammonia—Storage and handling (known as the SAA Anhydrous Ammonia Code)*.

This Standard incorporates Amendment No. 1 (December 2003). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

The objective of this Standard is to provide distributors and users with procedures for the safe storage and handling of anhydrous ammonia.

In addition to the updating of the list of reference documents and editorial changes in accordance with current policy, the following changes have been included in this edition:

- (a) Reference to AS/NZS 3788 for pressure vessel inspections.
- (b) Reduction in test pressure and increase in frequency for the testing of flexible hoses.
- (c) Changes to the requirements for personal protective equipment during transfer operations.
- (d) Alignment with the Australian Dangerous Goods Code, as appropriate.
- (e) Addition of requirements for emergency shut down and drive-away protection systems.
- (f) Addition of requirements for the management of emergencies.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	Page
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	6
1.2 REFERENCED DOCUMENTS.....	6
1.3 DEFINITIONS.....	6
SECTION 2 GENERAL REQUIREMENTS FOR SYSTEMS AND EQUIPMENT	
2.1 APPLICATION	9
2.2 OPERATING PRESSURE AND DESIGN PRESSURE	9
2.3 MATERIALS.....	9
2.4 ELECTRICAL EQUIPMENT AND WIRING.....	9
2.5 PROTECTION OF FITTINGS	9
2.6 FILLING AND DISCHARGE CONNECTIONS.....	10
2.7 VALVES AND FITTINGS.....	10
2.8 EXCESS FLOW VALVES AND EXCESS FLOW PROTECTION	10
2.9 PIPING	12
2.10 LIQUID LOADING AND UNLOADING CONNECTIONS.....	13
2.11 FLEXIBLE STEEL HOSE.....	13
2.12 RUBBER HOSE	13
2.13 PUMPS.....	14
2.14 COMPRESSORS	14
2.15 VAPORIZERS.....	15
2.16 EMERGENCY SHUT DOWN SYSTEM	15
2.17 DRIVE-AWAY PROTECTION	16
2.18 SAFETY EQUIPMENT.....	16
2.19 PERSONAL PROTECTION EQUIPMENT	17
SECTION 3 TANK STORAGE	
3.1 APPLICATION	18
3.2 TANKS.....	18
3.3 PRESSURE RELIEF VALVES	18
3.4 EXCESS FLOW VALVES AND NON RETURN VALVES.....	19
3.5 MANUAL SHUT OFF VALVES	19
3.6 VAPOUR RETURN VALVE	20
3.7 LIQUID LEVEL GAUGES	20
3.8 PRESSURE GAUGES.....	20
3.9 TEMPERATURE GAUGES.....	20
3.10 TANK LOCATION	21
3.11 INSTALLATION	22
3.12 SAFETY EQUIPMENT.....	23
SECTION 4 TANKS FOR TRANSPORTATION	
4.1 APPLICATION	25
4.2 GENERAL.....	25
4.3 ROAD AND RAIL TANK VEHICLES.....	25
4.4 SKID TANKS, NURSE TANKS AND APPLICATOR TANKS	25
4.5 PLACARDING.....	26

SECTION 5 CYLINDERS AND CYLINDER SYSTEMS	
5.1 APPLICATION	27
5.2 EQUIPMENT	27
5.3 STORAGE AND HANDLING	27
5.4 INSPECTION AND TESTING.....	28
5.5 FILLING CYLINDERS.....	28
5.6 CYLINDER HANDLING AND TRANSPORT.....	28
5.7 SAFETY EQUIPMENT.....	28
SECTION 6 REFRIGERATED STORAGE	
6.1 APPLICATION OF SECTION	30
6.2 TANK CONSTRUCTION	30
6.3 LOCATION AND INSTALLATION	30
6.4 FILLING AND DISCHARGING VALVES	31
6.5 PRESSURE RELIEF	32
6.6 REFRIGERATION SYSTEMS	32
SECTION 7 OPERATIONS	
7.1 APPLICATION	35
7.2 ESTABLISHMENT OF PROCEDURES.....	35
7.3 PLACARDING.....	37
7.4 TRAINING OF PERSONNEL.....	37
7.5 WORK ACTIVITIES AND SUPERVISION	38
7.6 COMPLIANCE WITH PROCEDURES	38
7.7 RECORDS.....	38
7.8 GENERAL PRECAUTIONS.....	38
7.9 INSPECTION AND TESTING.....	39
7.10 TRANSFER OF ANHYDROUS AMMONIA	40
7.11 LEAK DETECTION AND LOCATION	41
7.12 REPAIRS.....	42
SECTION 8 EMERGENCY MANAGEMENT	
8.1 APPLICATION	43
8.2 PLANNING FOR EMERGENCIES	43
8.3 MANIFEST	44
8.4 PLACARDING.....	45
8.5 MANAGEMENT OF LEAKS AND SPILLS	45
SECTION 9 FIRE PROTECTION	
9.1 APPLICATION	47
9.2 GENERAL CONSIDERATIONS	47
9.3 FIXED FIRE PROTECTION AND DETECTION SYSTEMS	49
9.4 FIRE ALARM SYSTEMS.....	49
9.5 FIRE EXTINGUISHERS.....	49
9.6 HOSE REELS.....	50
9.7 FIRE HYDRANTS	50
9.8 MONITORS	51
9.9 SPRINKLER SYSTEMS	51
9.10 WATER SUPPLY.....	51
9.11 FIRE PROTECTION REQUIREMENTS	52
9.12 ACTION IN EVENT OF A FIRE	52

Page

APPENDICES

A	PROPERTIES OF ANHYDROUS AMMONIA	53
B	REFERENCED DOCUMENTS.....	56
C	STRESS CORROSION CRACKING	59
D	CAPACITY OF SAFETY VALVES	61
E	TANK FILLING LEVEL.....	63
F	INFORMATION TO BE PROVIDED TO EMERGENCY SERVICES	66

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Anhydrous ammonia—Storage and handling

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for the design, repair, alteration, location, installation and operation of plant used for the storage, handling and transport of anhydrous ammonia in industrial and rural situations.

This Standard is not applicable to—

- (a) ammonia manufacturing plants;
- (b) manufacturing plants and other systems involving the use of ammonia; and
- (c) refrigeration systems, where anhydrous ammonia is used solely as a refrigerant.

The storage, handling and transport of anhydrous ammonia associated with these plants are not excluded.

NOTE: A guide to the properties of anhydrous ammonia is given in Appendix A.

1.2 REFERENCED DOCUMENTS

The documents listed in the Appendix B are referred to in the Standard.

1.3 DEFINITIONS

For the purpose of this Standard, the definitions given in AS 4942 and those below apply.

1.3.1 Authorized person

A person specifically appointed by an anhydrous ammonia distributor or the distributor's agent to perform the duties of that position.

1.3.2 Capacity (of a tank, cylinder or drum)

The total volume of the space enclosed within the tank or cylinder, expressed in litres or cubic metres.

NOTES:

- 1 This is synonymous with and numerically equal to water capacity.
- 2 Capacity is sometimes expressed as the equivalent mass of water.

1.3.3 Container

A cylinder or tank specifically designed and constructed for the storage or transport of anhydrous ammonia.

1.3.4 Depot

A stationary anhydrous ammonia storage system, including the container or containers, container fittings and the ancillary equipment essential for the safe operation of the system.

1.3.5 Filler

A competent person authorized to fill containers with anhydrous ammonia.