

Australian/New Zealand Standard™

Rotating electrical machines—General requirements

Part 5: Three-phase cage induction motors—High efficiency and minimum energy performance standards requirements

AS/NZS 1359.5:2004

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-046, Rotating Electrical Machinery—Efficiency. It was approved on behalf of the Council of Standards Australia on 7 July 2004 and on behalf of the Council of Standards New Zealand on 23 July 2004. This Standard was published on 6 September 2004.

The following are represented on Committee EL-046:

Airconditioning and Refrigeration Equipment Manufacturers Association of
Australia
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Greenhouse Office
Bureau of Steel Manufacturers of Australia
Electricity Supply Association of Australia
Energy Efficiency and Conservation Authority of New Zealand
Institution of Professional Engineers New Zealand
National Appliance and Equipment Energy Efficiency Committee

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Rotating electrical machines—General requirements

Part 5: Three-phase cage induction motors—High efficiency and minimum energy performance standards requirements

Originated as AS/NZS 1359.5:2000.
Second edition 2004.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-046, Rotating Electrical Machinery—Efficiency to supersede AS/NZS 1359.5:2000 on publication. AS/NZS 1359.5:2000 will remain an available superseded Standard.

The objective of this part of the Standard is to specify the minimum energy performance standards (MEPS) requirements for electric motors commonly used in the industry. This Standard also specifies the performance levels required for high efficiency motors. The MEPS levels in this Standard are intended to eliminate the low efficiency motors from the Australian and New Zealand markets.

This Standard has seamless interface with AS/NZS 1359.102.3, *Rotating electrical machines—General requirements—Methods for determining losses and efficiency—Three-phase cage induction motors* and the equivalent IEC Standard 61972, *Method for determining losses and efficiency of three-phase cage induction motors*.

EL-046 is reviewing IEC 61972 for adoption as a Joint AS/NZS Standard to replace AS/NZS 1359.102.3.

This part of the Standard is a mandatory reference document for manufacturers and importers of commonly used three-phase cage induction motors and is published with the approval of the regulatory authorities. In Australia, it is structured for reference in MEPS regulation, under the effective joint control of the State and Territory energy regulators. Regulatory authorities will enforce MEPS and high efficiency levels specified in this Standard. This Standard includes the revised efficiency requirements which commence from 1 April 2006 for minimum efficiency (MEPS) and 1 April 2005 for high efficiency. Please contact the equipment energy efficiency regulator in your jurisdiction to ascertain the status of MEPS transition arrangements specified in this Standard. Contact details for these regulatory bodies together with information on making a MEPS application are available from <http://www.energyrating.gov.au>

In New Zealand, Energy Efficiency (Energy Using Products) Regulations 2002 had a commencement date of 1 July 2002 for MEPS for three-phase electric motors. The introductory date for the revised efficiency requirement will be addressed by an amendment to this Standard and a subsequent gazette notice.

In the earlier edition of this Standard—

- (a) the efficiency levels were finalized based on the analysis of the Australian market in 1997 and subsequent negotiations with the industry;
- (b) the MEPS levels (named as Level 2 in this Standard) coincide with the European efficiency Level 2 for 2-pole and 4-pole configurations where values existed;
- (c) the high efficiency levels (named as Level 1 in this Standard) coincide with European efficiency Level 1, where values existed for 2 pole and 4 pole configurations. These were similar to United States/Canadian MEPS levels introduced in 1997; and
- (d) the high efficiency levels for 6-pole configurations were somewhat less stringent than United States/Canadian MEPS levels, introduced in 1997.

In this Standard—

- (i) the revised MEPS levels for motors of all pole configurations is set at the high efficiency levels (Level 1) of the previous edition of this Standard; and
- (ii) the high efficiency levels (named as Heff) are set, based on a 15% reduction of losses from the levels stated in the previous edition.

The MEPS relevant parts of the AS/NZS Standards for motors will be reviewed in the next phase in line with the development of publications from EL-009 and/or the IEC Committee TC 2. The MEPS levels in the next phase will not however commence earlier than 2010.

The terms 'normative' and 'informative' are used to define the application of the appendix to which they apply. A normative appendix is an integral part of a standard, whereas an informative appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 EXCLUSIONS	6
1.3 REFERENCED DOCUMENTS	7
1.4 DEFINITIONS	7
1.5 MARKING	7
1.6 VERIFICATION OF COMPLIANCE WITH THE STANDARD.....	8
1.7 TOLERANCES	8
SECTION 2 MINIMUM EFFICIENCIES—ALL MOTORS (METHODS A AND B)	
2.1 GENERAL	9
2.2 MINIMUM EFFICIENCY—TEST METHOD A	9
2.3 MINIMUM EFFICIENCY—TEST METHOD B	9
SECTION 3 MINIMUM EFFICIENCIES—HIGH EFFICIENCY MOTORS (METHODS A AND B)	
3.1 GENERAL	10
3.2 HIGH EFFICIENCY—TEST METHOD A	10
3.3 HIGH EFFICIENCY—TEST METHOD B	10
SECTION 4 APPLICATION AND TEST RESULT FORMATS	
4.1 APPLICATION FOR REGISTRATION	11
4.2 HOLDING OF RECORDS	11
APPENDICES	
A EFFICIENCY REQUIREMENTS—TEST METHOD A.....	13
B EFFICIENCY REQUIREMENTS—TEST METHOD B.....	17
C APPLICATION FOR REGISTRATION OR RENEWAL OF REGISTRATION OF ELECTRIC MOTOR FOR ENERGY EFFICIENCY DETERMINATION	21

FOREWORD

This Standard features two test methods for determination of losses.

Method A: This method is identical to Method 1 of IEC 61972. It is also technically equivalent to the method specified in IEEE 112-B(USA). This method requires direct measurement of additional load losses and differs from Method B described below.

Method B: This method is drawn from AS 1359.102.1, which is based on IEC 60034-2, including Amendment 1:1995 and Amendment 2:1996. In this method, an allowance of 0.5% fixed stray (additional load) loss is assumed for all the motors.

Previous surveys of the efficiency of machines on the Australian market used figures based on Method B.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Rotating electrical machines—General requirements

Part 5: Three-phase cage induction motors—High efficiency and minimum energy performance standards requirements

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard applies to three-phase cage induction motors with ratings from 0.73 kW and up to but not including 185 kW. The scope covers motors of rated voltages up to 1100 V a.c.

NOTE: This range includes motors with ratings of 1 hp and 1 CV/PS (French/German or metric horsepower).

This Standard specifies the minimum efficiency values that a motor shall meet, and also the minimum efficiency values that a motor shall meet in order to be designated 'high efficiency'. Two methods of measurement are prescribed (Method A and Method B) for determination of efficiency. See Sections 2 and 3 for details. Only one method need be applied.

NOTES:

- 1 Minimum efficiency and high efficiency values covered by this Standard are categorized based on the regulatory dates.
- 2 In New Zealand, the MEPS covered by this Standard will be addressed by an amendment to this Standard and a subsequent gazette notice.

1.2 EXCLUSIONS

The MEPS requirements of this Standard do not apply to the following:

- (a) Submersible (sealed) motors specifically designed to operate wholly immersed in a liquid.

NOTE: This exclusion does not apply to motors that normally operate with a surrounding medium of air but that may withstand inundation.

- (b) Motors that are integral with, and not separable from, a driven unit.

NOTE: An example is a motor constructed on the same shaft as a compressor for an air-conditioning unit.

- (c) Multi-speed motors.

- (d) Motors that have been granted exemption by the relevant Australian or New Zealand regulatory authority due to their application placing restraints on the motor dimensions or other key design aspects.

- (e) Motors for use only for short-time duty cycle applications (e.g. those used for hoists, roller doors and cranes) which have a duty type rating of S2 under IEC 60034-12.

NOTE: Exclusion from MEPS for these types of motors is based on their low projected usage and hence low total energy consumption.

This Standard does not apply to a rewind motor except where a supplier claims the rewind motor meets the efficiency requirement of one of the levels defined in this Standard.