

Australian Standard™

Instrument transformers

**Part 1: Current transformers
(IEC 60044-1:1996, MOD)**

This Australian Standard was prepared by Committee EL-013, Measurement and Protection Transformers. It was approved on behalf of the Council of Standards Australia on 13 December 2002 and published on 3 February 2003.

The following are represented on Committee EL-013:

Australian Electrical and Electronic Manufacturers Association
CSIRO
CIGRE AP12
Electricity Supply Association of Australia
University of South Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Instrument transformers

Part 1: Current transformers (IEC 60044-1:1996, MOD)

Originated as part of AS C45—1928.
Previous edition AS 1243—1982.
AS 1243—1982 revised and re-designated in part as AS 60044.1—2003.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5020 6

PREFACE

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers to supersede AS 1675—1986 one year after publication. During this period it is anticipated that regulatory authorities will approve current transformers to either standard.

The objective of this Standard is to provide users and manufacturers of current transformers with definitions of terms, safety requirements, methods of specifying performance and methods of test.

This Standard is Part One of a series covering instrument transformers. The series consists of the following Standards:

AS

60044 Instrument transformers

60044.1 Part 1: Current transformers (this Standard)

60044.2 Part 2: Single-phase inductive voltage transformers

This Standard is an adoption with national modifications of IEC 60044-1:1996, *Instrument transformers*, Part 1: *Current Transformers* (including Amendment 1: 2000).

Variations to IEC 60044-1:1996 are indicated at the appropriate places throughout this standard. Strikethrough (~~example~~) identifies IEC text, tables and figures which, for the purposes of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this standard' should read 'this Australian Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

Attention is drawn to the following differences between this Standard and AS 1675—1986.

- (a) This Standard has a new thermal class for windings in oil and hermetically sealed that allows 65 K temperature rise. See Table 2, *Limits of temperature rise of the windings*.
- (b) This Standard has highest voltages for equipment of 170 kV and 245 kV in place of 245 kV in AS 1675—1986. See Table 3, *Rated insulation levels for transformer primary windings*.
- (c) This Standard introduces reduced levels of permissible partial discharges across the complete range of system earthing types and voltages, with increases in prestress voltage level (from the current 1.3 times the nominal voltage of the system U_n level to the induced voltage withstand test level) and in testing voltage level (from 1.1 U_m to 1.3 U_m). See Clause 5.1.2.2, *Partial discharges* and Clause 8.2.2.2, *Partial discharge test procedure*.
- (d) This Standard allows a maximum permissible voltage across secondary winding of up to 4.5 kV for all cores and up to 10 kV for PX class (the PL class of AS 1675—1986). See Clause 5.1.5, *Inter-turn insulation requirements*.

- (e) This Standard introduces requirements for minimum insulator creepage distance and arcing/creepage ratio for various pollution levels. See Clause 5.1.6, *Requirements for the external insulation*.
- (f) This Standard requires repeated dielectric testing to be performed at 80% of the initial power frequency voltage (and not 75% as in AS 1675—1986). See Clause 6.2.
- (g) This Standard covers measurement of dielectric dissipation factor as a special test, and not as a routine test as does AS 1675—1986. See Clause 6.3, *Special tests*.
- (h) This Standard tests radio interference voltage with a prestress voltage of $1.5 U_m/\sqrt{3}$, and a limit of 300 pC or 2500 μ V at $1.1 U_m/\sqrt{3}$. This test is also required for voltages 123 kV and upwards (and not from 245 kV as in AS 1675—1986). See Clause 7.5, *Radio interference voltage measurement*.
- (i) This Standard includes requirements for measurement of partial discharges different to those in AS 1675—1986 (which calls up AS 2532 which has been withdrawn). See Clause 8.2.2, *Partial discharge measurement*.
- (j) This Standard introduces new special tests of chopped impulse on primary winding and mechanical testing of primary terminals. See Clause 9.1, *Chopped impulse test on primary winding* and Clause 5.2, *Mechanical requirements*.
- (k) Special Metering Classes are introduced in this Standard as classes 0.2S and 0.5S for the secondary current 5 A only, with a current range from 1-120% (that can be extended to 150% and 200%). AS 1675—1986 has classes 0.1ME, 0.2ME and 0.5ME for secondary currents 1 A and 5 A, but the current range is 2.5-125/150/200%. See Clause 11.2, *Limits of current error and phase displacement for measuring current transformers*.
- (l) This Standard allows a higher error margin for errors measured at 5-20% of rated current than does AS 1675—1986, but better accuracy can be achieved by selecting a different class for such needs. See Clause 11.2, *Limits of current error and phase displacement for measuring current transformers*.
- (m) This Standard requires a maximum current of 120% for accuracy testing of metering CTs instead of the 125% required in AS 1675—1986. See Clause 11.2, *Limits of current error and phase displacement for measuring current transformers*.
- (n) This Standard allows protection classes 5P and 10P to have accuracies of 1% and 3% respectively. See Clause 12.3, *Limits of errors for protective current transformers*.
- (o) Tests for accuracy are done at 1.0 power factor in AS 1675—1986. This Standard requires tests for accuracy to be done at 0.8 power factor or at 1.0 power factor with the results converted to equivalent results at 0.8 power factor. See Clause 12.3, *Limits of errors for protective current transformers*.
- (p) AS 1675—1986 covered class PS which is not covered in this Standard. However, class PR (air gaps) of this Standard deals with requirements of this type. See Clause 13, *Additional requirements for class PR protective current transformers*.
- (q) This Standard includes a class PX which covers all requirements of class PL in AS 1675—1986. See Clause 14, *Additional requirements for class PX protective current transformers*.
- (r) This Standard does not have requirements for thermal stability testing.
- (s) This Standard has no requirements for variation of error margins during accuracy testing of metering cores.

CONTENTS

	<i>Page</i>
Clauses	
1	General 1
1.1	Scope 1
1.2	Normative references 2
2	Definitions 3
2.1	General definitions 3
2.2	Additional definitions for measuring current transformers 6
2.3	Additional definitions for protective current transformers 7
3	Normal and special service conditions 8
3.1	Normal service conditions 8
3.1.1	Ambient air temperature 8
3.1.2	Altitude 8
3.1.3	Vibrations or earth tremors 8
3.1.4	Other service conditions for indoor current transformers 8
3.1.5	Other service conditions for outdoor current transformers 9
3.2	Special service conditions 9
3.2.1	Ambient air temperature 9
3.2.2	Altitude 10
3.2.3	Earthquakes 10
3.3	System earthing 10
4	Ratings 10
4.1	Standard values of rated primary currents 10
4.1.1	Single-ratio transformers 10
4.1.2	Multi-ratio transformers 10
4.2	Standard values of rated secondary currents 10
4.3	Rated continuous thermal current 10
4.4	Standard values of rated output 10
4.5	Short-time current ratings 11
4.5.1	Rated short-time thermal current (I_{th}) 11
4.5.2	Rated dynamic current (I_{dyn}) 11
4.6	Limits of temperature rise 11
5	Design requirements 12
5.1	Insulation requirements 12
5.1.1	Rated insulation levels for primary windings 12
5.1.2	Other requirements for primary winding insulation 14
5.1.3	Between-section insulation requirements 16
5.1.4	Insulation requirements for secondary windings 16
5.1.5	Inter-turn insulation requirements 16
5.1.6	Requirements for the external insulation 16
5.1.7	Requirements for radio interference voltage (RIV) 17
5.2	Mechanical requirements 17
6	Classification of tests 18
6.1	Type tests 18
6.2	Routine tests 19
6.3	Special tests 19

7	Type tests.....	19
7.1	Short-time current tests	19
7.2	Temperature-rise test	20
7.3	Impulse tests on primary winding	20
7.3.1	General.....	20
7.3.2	Lightning impulse test	21
7.3.3	Switching impulse test	21
7.4	Wet test for outdoor type transformers.....	22
7.5	Radio interference voltage measurement.....	22
8	Routine tests	23
8.1	Verification of terminal markings.....	23
8.2	Power-frequency withstand tests on primary windings and partial discharge measurement.....	23
8.2.1	Power-frequency test	23
8.2.2	Partial discharge measurement.....	23
8.3	Power-frequency withstand tests between sections of primary and secondary windings and on secondary windings	24
8.4	Inter-turn overvoltage test.....	24
9	Special tests	25
9.1	Chopped impulse test on primary winding.....	25
9.2	Measurement of capacitance and dielectric dissipation factor	25
9.3	Mechanical tests.....	26
10	Markings.....	27
10.1	Terminal markings – General rules	27
10.1.1	Method of marking	27
10.1.2	Markings to be used.....	28
10.1.3	Indication of relative polarities	28
10.2	Rating plate markings	28
11	Additional requirements for measuring current transformers	29
11.1	Accuracy class designation for measuring current transformers	29
11.1.1	Standard accuracy classes	29
11.2	Limits of current error and phase displacement for measuring current transformers	29
11.3	Extended current ratings.....	30
11.4	Type tests for accuracy of measuring current transformers	30
11.5	Routine tests for accuracy of measuring current transformers.....	31
11.6	Instrument security factor	31
11.7	Marking of the rating plate of a measuring current transformer	31
12	Additional requirements for protective current transformers	31
12.1	Standard accuracy limit factors.....	31
12.2	Accuracy classes for protective current transformer.....	32
12.2.1	Accuracy class designation	32
12.2.2	Standard accuracy classes	32
12.3	Limits of errors for protective current transformers.....	32
12.4	Type and routine tests for current error and phase displacement of protective current transformers	32
12.5	Type tests for composite error	33
12.6	Routine tests for composite error	33
12.7	Marking of the rating plate of a protective current transformer	34

13	Additional requirements for class PR protective current transformers.....	37
13.1	Standard accuracy limit factors.....	37
13.2	Accuracy classes for class PR protective circuit transformers.....	37
13.2.1	Accuracy class designation.....	37
13.2.2	Standard accuracy class.....	37
13.3	Limits of error for class PR protective current transformers.....	37
13.3.1	Current error, phase displacement and composite error.....	37
13.3.2	Remanence factor (K_r).....	38
13.3.3	Secondary loop time constant (T_s).....	38
13.3.4	Secondary winding resistance (R_{ct}).....	38
13.4	Type and routine tests for current error and phase displacement of class PR protective current transformers.....	38
13.4.1	Determination of remanence factor (K_r).....	38
13.4.2	Determination of secondary loop time constant (T_s).....	38
13.4.3	Determination of secondary winding resistance (R_{ct}).....	38
13.5	Marking of rating plate of class PR current transformers.....	38
13.5.1	Principal marking.....	38
13.5.2	Special marking (when required):.....	38
14	Additional requirements for class PX protective current transformers.....	39
14.1	Specification of performance for class PX protective current transformers.....	39
14.2	Insulation requirements for class PX protective current transformers.....	39
14.2.1	Insulation requirements for secondary winding.....	39
14.2.2	Inter-turn insulation requirements.....	39
14.3	Type tests for class PX protective current transformers.....	39
14.3.1	Proof of low reactance type.....	39
14.4	Routine tests for class PX protective current transformers.....	40
14.4.1	Rated knee point e.m.f. (E_k) and maximum exciting current (I_e).....	40
14.4.2	Secondary winding resistance (R_{ct}).....	40
14.4.3	Turns ratio error (ϵ_t).....	40
14.4.4	Insulation tests.....	40
14.4.5	Inter-turn insulation tests.....	40
14.5	Marking of rating plate of class PX current transformers.....	40
14.5.1	Principal marking.....	40
14.5.2	Special marking.....	40
	Annex A (normative) Protective current transformers.....	41
	Annex B (informative) Multiple chopped impulse test.....	45
	Annex ZA (normative) Calibration of a CT at a 0.8 power factor lagging burden.....	46

STANDARDS AUSTRALIA

Australian Standard**Instrument transformers****Part 1: Current transformers (IEC 60044-1:1996, MOD)**

Any table, figure or text of the international standard that is struck through is not part of this standard. Any Australian/New Zealand table, figure or text that is added is part of this standard and is identified by shading.

1 General**1.1 Scope**

This part of IEC 44 applies to newly manufactured current transformers for use with electrical measuring instruments and electrical protective devices at frequencies from 15 Hz to 100 Hz.

Although the requirements relate basically to transformers with separate windings, they are also applicable, where appropriate, to autotransformers.

Clause 11 covers the requirements and tests, in addition to those in clauses 3 to 10, that are necessary for current transformers for use with electrical measuring instruments.

Clause 12 covers the requirements and tests, in addition to those in clauses 3 to 10, that are necessary for current transformers for use with electrical protective relays, and in particular for forms of protection in which the prime requirement is the maintenance of accuracy up to several times the rated current.

For certain protective systems, where the current transformer characteristics are dependant on the overall design of the protective equipment (for example high-speed balanced systems and earth-fault protection in resonant earthed networks), additional requirements are given in clause 13 for class PR transformers and in clause 14 for class PX transformers.

Clause 13 covers the requirements and tests in addition to those in clauses 3 to 10 that are necessary for current transformers for use with electrical protective relays, and in particular for forms of protection in which the prime requirement is the absence of remanent flux.

Clause 14 covers the requirements and tests in addition to those in clauses 3 to 10 that are necessary for current transformers for use with electrical protective relays, and in particular for forms of protection for which knowledge of the transformer's secondary excitation characteristic, secondary winding resistance, secondary burden resistance and turns ratio is sufficient to assess its performance in relation to the protective relay system with which it is to be used.

Current transformers intended for both measurement and protection shall comply with all the clauses of this standard.