

Australian/New Zealand Standard™

**Residual current operated circuit-
breakers without integral overcurrent
protection for household and similar
uses (RCCBs)**

**Part 1: General rules
(IEC 61008-1, Ed. 3.2 (2013) MOD)**



AS/NZS 61008.1:2015

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-004, Electrical Accessories. It was approved on behalf of the Council of Standards Australia on 12 February 2015 and on behalf of the Council of Standards New Zealand on 10 February 2015.

This Standard was published on 23 March 2015.

The following are represented on Committee EL-004:

Australian Chamber of Commerce and Industry
Australian Industry Group
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
Engineers Australia
International Accreditation New Zealand
Ministry of Business, Innovation and Employment. NZ
New Zealand Manufacturers and Exporters Association
NSW Office of Fair Trading
Plastics Industry Pipe Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)

Part 1: General rules (IEC 61008-1, Ed. 3.2 (2013) MOD)

Originated as AS/NZS 3175.1:1994.
Previous edition AS/NZS 61008.1:2011.
Third edition 2015.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-004, Electrical Accessories, to supersede AS/NZS 61008.1:2011, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)—General rules*.

The objective of this Standard is to provide Australian and New Zealand electrical industries with requirements for residual current operated circuit-breakers with integral overcurrent protection functionally independent of, or functionally dependent on, line voltage for household and similar uses.

This Standard is an adoption with national modifications and has been reproduced from IEC 61008-1, Ed. 3.2 (2013), *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)—Part 1: General rules*, which incorporates Amendment 1 (2012) and Amendment 2 (2013) and has been varied as indicated to take account of Australian/New Zealand conditions. The variations are specified in Appendix ZZ.

This Standard will exist in parallel with AS/NZS 3190, *Approval and test specification—Residual current devices (current-operated earth-leakage devices)*, and any revisions thereof. Both this Standard and AS/NZS 3190 are acceptable for RCCBs. PRCDs are acceptable only if they comply with AS/NZS 3190.

The essential safety requirements in AS/NZS 3820, *Essential safety requirements for electrical equipment* that could be applicable to RCCBs are covered by this Standard.

The variations described in Appendix ZZ form the Australian and New Zealand variations for the purposes of the CB scheme for recognition of testing to standards for safety of electrical equipment (the CB Scheme).

This Standard is structured as follows:

- (a) Preface.
- (b) IEC 61008-1 Ed. 3.2 (2013) (unedited from the contents page to the final clause of the source document).
- (c) Appendix ZZ—(Australian/New Zealand) variations to the source document.

The variations listed in Appendix ZZ address issues including the following:

- (i) Verification of the correct operation in case of sudden appearance of residual currents at specified currents between $5I_{\Delta n}$ and 500 A.
- (ii) Type 1 RCCB additional requirements.
- (iii) Add verification of the test device circuit.

As this Standard is reproduced from an International Standard, the following applies:

- (A) In the source text ‘this International Standard’ should read ‘this Australian/New Zealand Standard’.
- (B) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS	
60038	IEC standard voltages	60038	Standard voltages
60060	High-voltage test techniques	1931	High-voltage test techniques
60060-1	Part 1: General definitions and test requirements	1931.1	Part 1: General definitions and test requirements
60060-2	Part 2: Measuring systems	1931.2	Part 2: Measuring systems
60068	Environmental testing	60068	Environmental testing
60068-3-4	Part 3-4: Supporting documentation and guidance—Damp heat tests	60068.3.4	Part 3.4: Supporting documentation and guidance—Damp heat tests
60417	Graphical symbols for use on equipment	60417	Graphical symbols for use on equipment
60417-1	Part 1: Overview and application	60417.1	Part 1: Overview and application
60529	Degrees of protection provided by enclosures (IP Code)	60529	Degrees of protection provided by enclosures (IP Code)
		AS/NZS	
60695	Fire hazard testing	60695	Fire hazard testing
60695-2-10	Part 2-10: Glowing/hot-wire based test methods—Glow-wire apparatus and common test procedure	60695.2.10	Part 2.10: Glowing/hot-wire based test methods—Glow-wire apparatus and common test procedure
60884	Plugs and socket-outlets for household and similar purposes	60884	Plugs and socket-outlets for household and similar purposes
60884-1	Part 1: General requirements	60884.1	Part 1: General requirements (IEC 60884-1, Ed.3.1 (2006) MOD)
61009	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)	61009	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
61009-1	Part 1: General rules	61009.1	Part 1. General rules (IEC 61009-1, Ed.3.0 (2010) MOD)
CISPR		AS/NZS CISPR	
14	Electromagnetic compatibility—Requirements for household appliances, electric tools and similar apparatus	14	Electromagnetic compatibility—Requirements for household appliances, electric tools and similar apparatus
14-1	Part 1: Emission	14.1	Part 1: Emission

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex or appendix to which they apply. A ‘normative’ annex or appendix is an integral part of a Standard, whereas an ‘informative’ annex or appendix is only for information and guidance.

CONTENTS

1	Scope	12
2	Normative references	13
3	Terms and definitions	14
3.1	Definitions relating to currents flowing from live parts to earth	14
3.2	Definitions relating to the energization of a residual current circuit-breaker	15
3.3	Definitions relating to the operation and functions of residual current circuit-breakers	15
3.4	Definitions relating to values and ranges of energizing quantities	17
3.5	Definitions relating to values and ranges of influencing quantities	19
3.6	Definitions relating to terminals	20
3.7	Definitions relating to conditions of operation	21
3.8	Definitions relating to tests	22
3.9	Definitions relating to insulation coordination	22
4	Classification	24
4.1	According to the method of operation	24
4.1.1	RCCB functionally independent of line voltage (see 3.3.4)	24
4.1.2	RCCB functionally dependent on line voltage (see 3.3.5)	24
4.2	According to the type of installation	24
4.3	According to the number of poles and current paths	24
4.4	According to the possibility of adjusting the residual operating current	24
4.5	According to resistance to unwanted tripping due to voltage surges	24
4.6	According to behaviour in presence of d.c. components	24
4.7	According to time-delay (in presence of a residual current)	25
4.8	According to the protection against external influences	25
4.9	According to the method of mounting	25
4.10	According to the method of connection	25
4.11	According to the type of terminals	26
5	Characteristics of RCCBs	25
5.1	Summary of characteristics	25
5.2	Rated quantities and other characteristics	26
5.2.1	Rated voltage (U_N)	26
5.2.2	Rated current (I_N)	26
5.2.3	Rated residual operating current ($I_{\Delta N}$)	26
5.2.4	Rated residual non-operating current ($I_{\Delta no}$)	26
5.2.5	Rated frequency	27
5.2.6	Rated making and breaking capacity (I_M)	27
5.2.7	Rated residual making and breaking capacity ($I_{\Delta M}$)	27
5.2.8	RCCB type S	27
5.2.9	Operating characteristics in case of residual currents with d.c. components	27
5.3	Standard and preferred values	27
5.3.1	Preferred values of rated voltage (U_N)	27
5.3.2	Preferred values of rated current (I_N)	28
5.3.3	Standard values of rated residual operating current ($I_{\Delta N}$)	28

5.3.4	Standard value of residual non-operating current ($I_{\Delta no}$)	28
5.3.5	Standard minimum value of non-operating overcurrent in case of a multiphase balanced load through a multipole RCCB (see 3.4.2.1)	28
5.3.6	Standard minimum value of the non-operating overcurrent in case of a single-phase load through a three-pole or four-pole RCCB (see 3.4.2.2)	29
5.3.7	Preferred values of rated frequency	29
5.3.8	Minimum value of the rated making and breaking capacity (I_M)	29
5.3.9	Minimum value of the rated residual making and breaking capacity ($I_{\Delta M}$)	29
5.3.10	Standard and preferred values of the rated conditional short-circuit current (I_{nc})	29
5.3.11	Standard values of the rated conditional residual short-circuit current ($I_{\Delta C}$)	29
5.3.12	Limit values of break time and non-actuating time for RCCB of type AC and A	30
5.3.13	Standard value of rated impulse withstand voltage (U_{imp})	31
5.4	Coordination with short-circuit protective devices (SCPDs)	31
5.4.1	General	31
5.4.2	Rated conditional short-circuit current (I_{nc})	32
5.4.3	Rated conditional residual short-circuit current ($I_{\Delta C}$)	32
6	Marking and other product information	32
7	Standard conditions for operation in service and for installation	34
7.1	Standard conditions	34
7.2	Conditions of installation	34
7.3	Pollution degree	35
8	Requirements for construction and operation	35
8.1	Mechanical design	35
8.1.1	General	35
8.1.2	Mechanism	35
8.1.3	Clearances and creepage distances (see Annex B)	37
8.1.4	Screws, current-carrying parts and connections	39
8.1.5	Terminals for external conductors	40
8.2	Protection against electric shock	42
8.3	Dielectric properties and isolating capability	43
8.4	Temperature-rise	43
8.4.1	Temperature-rise limits	43
8.4.2	Ambient air temperature	44
8.5	Operating characteristic	44
8.6	Mechanical and electrical endurance	44
8.7	Performance at short-circuit currents	44
8.8	Resistance to mechanical shock and impact	44
8.9	Resistance to heat	44
8.10	Resistance to abnormal heat and to fire	45
8.11	Test device	45
8.12	Requirements for RCCBs functionally dependent on line voltage	45
8.13	Behaviour of RCCBs in case of overcurrents in the main circuit	46
8.14	Behaviour of RCCBs in the case of current surges caused by impulse voltages	46

8.15	Behaviour of RCCBs in case of earth fault currents comprising a d.c. component	46
8.16	Reliability	46
8.17	Electromagnetic compatibility (EMC).....	46
9	Tests.....	46
9.1	General.....	46
9.2	Test conditions	47
9.3	Test of indelibility of marking.....	48
9.4	Test of reliability of screws, current-carrying parts and connections	48
9.5	Tests of reliability of screw-type terminals for external copper conductors.....	49
9.6	Verification of protection against electric shock	51
9.7	Test of dielectric properties.....	51
9.7.1	Resistance to humidity	51
9.7.2	Insulation resistance of the main circuit.....	52
9.7.3	Dielectric strength of the main circuit.....	53
9.7.4	Insulation resistance and dielectric strength of auxiliary circuits	53
9.7.5	Secondary circuit of detection transformers	54
9.7.6	Capability of control circuits connected to the main circuit withstanding high d.c. voltages due to insulation measurements	54
9.7.7	Verification of impulse withstand voltages (across clearances and across solid insulation) and of leakage current across open contacts	55
9.8	Test of temperature-rise	58
9.8.1	Ambient air temperature.....	58
9.8.2	Test procedure.....	58
9.8.3	Measurement of the temperature of parts	59
9.8.4	Temperature rise of a part.....	59
9.9	Verification of the operating characteristics	59
9.9.1	Test circuit and test procedure	59
9.9.2	Tests for all RCCBs	59
9.9.3	Additional verification of correct operation at residual currents with d.c. components for type A RCCBs	61
9.9.4	Particular test conditions for RCCBs functionally dependent on line voltage	62
9.10	Verification of mechanical and electrical endurance.....	62
9.10.1	General test conditions	62
9.10.2	Test procedure.....	62
9.10.3	Condition of the RCCB after test.....	63
9.11	Verification of the behaviour of the RCCB under short-circuit conditions	63
9.11.1	List of the short-circuit tests	63
9.11.2	Short-circuit tests.....	63
9.12	Verification of resistance to mechanical shock and impact.....	72
9.12.1	Mechanical shock	72
9.12.2	Mechanical impact	73
9.13	Test of resistance to heat	75
9.14	Test of resistance to abnormal heat and to fire	76
9.15	Verification of the trip-free mechanism	77
9.15.1	General test conditions	77
9.15.2	Test procedure.....	77
9.16	Verification of the operation of the test device at the limits of rated voltage.....	77

9.17	Verification of the behaviour of RCCBs functionally dependent on line voltage, classified under 4.1.2.1, in case of failure of the line voltage	78
9.17.1	Determination of the limiting value of the line voltage (U_x)	78
9.17.2	Verification of the automatic opening in case of failure of the line voltage	78
9.17.3	Verification of the correct operation, in presence of a residual current, for RCCBs opening with delay in case of failure of the line voltage	78
9.17.4	Verification of the correct operation of RCCBs with three or four current paths, with a residual current, one line terminal only being energized.....	79
9.17.5	Verification of the reclosing function of automatically reclosing RCCBs	79
9.18	Verification of limiting values of the non-operating current under overcurrent conditions.....	79
9.18.1	Verification of the limiting value of overcurrent in case of a load through an RCCB with two current paths	79
9.18.2	Verification of the limiting value of overcurrent in case of a single phase load through a three-pole or four-pole RCCB	79
9.19	Verification of behaviour of RCCBs in case of current surges caused by impulse voltages.....	80
9.19.1	Current surge test for all RCCBs (0,5 μ s/100 kHz ring wave test)	80
9.19.2	Verification of behaviour at surge currents up to 3 000 A (8/20 μ s surge current test).....	80
9.20	Void	81
9.21	Void	81
9.22	Verification of reliability.....	81
9.22.1	Climatic test.....	81
9.22.2	Test with temperature of 40 °C	83
9.23	Verification of ageing of electronic components	83
9.24	Electromagnetic compatibility (EMC)	84
9.24.1	Tests covered by the present standard	84
9.24.2	Additional tests	84
9.25	Test of resistance to rusting.....	84
Annex A (normative) Test sequence and number of samples to be submitted for certification purposes.....		107
Annex B (normative) Determination of clearances and creepage distances		112
Annex C (normative) Arrangement for the detection of the emission of ionized gases during short-circuit tests.....		117
Annex D (normative) Routine tests		120
Annex E (informative) Void.....		121
Annex IA (informative) Methods for determination of short-circuit power-factor		122
Annex IB (informative) Glossary of symbols.....		123
Annex IC (informative) Examples of terminal designs.....		124
Annex ID (informative) Correspondence between ISO and AWG copper conductors		127
Annex IE (informative) Follow-up testing program for RCCBs.....		128
Annex IF (informative) SCPDs for short-circuit tests		132
Annex J (normative) Particular requirements for RCCBs with screwless type terminals for external copper conductors		133

Annex K (normative) Particular requirements for RCCBs with flat quick-connect terminations.....	141
Annex L (normative) Specific requirements for RCCBs with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors	148
Bibliography	158
Figure 1 – Thread forming tapping screw (3.6.10).....	85
Figure 2 – Thread cutting tapping screw (3.6.11)	85
Figure 3 – Standard test finger (9.6).....	86
Figure 4 – Test circuit for the verification of – operating characteristics (9.9) – trip-free mechanism (9.15) – behaviour in case of failure of line voltage (9.17.3 and 9.17.4) for RCCBs functionally dependent on line voltage	87
Figure 5 – Test circuit for the verification of the correct operation of RCCBs in the case of residual pulsating direct currents.....	88
Figure 6 – Test circuit for the verification of the correct operation in case of residual pulsating direct currents in presence of a standing smooth direct current of 0,006 A.....	89
Figure 7 – Typical diagram for all short circuit tests except for 9.11.2.3 c).....	91
Figure 8 – Typical diagram for short circuit tests according to 9.11.2.3 c).....	92
Figure 9 – Detail of impedances Z , Z_1 and Z_2	92
Figure 10 – Void	92
Figure 11 – Void	92
Figure 12 – Void	92
Figure 13 – Test apparatus for the verification of the minimum I^2t and I_p values to be withstood by the RCCB (9.11.2.1 a))	93
Figure 14 – Mechanical shock test apparatus (9.12.1)	94
Figure 15 – Mechanical impact test apparatus (9.12.2.1)	95
Figure 16 – Striking element for pendulum impact test apparatus (9.12.2.1)	96
Figure 17 – Mounting support for sample for mechanical impact test (9.12.2.1)	97
Figure 18 – Example of mounting and unenclosed RCCB for mechanical impact test (9.12.2.1)	98
Figure 19 – Example of mounting of panel mounting type RCCB for the mechanical impact test (9.12.2.1)	99
Figure 20 – Application of force for mechanical test of rail mounted RCCB (9.12.2.2)	100
Figure 21 – Ball-pressure test apparatus (9.13.2)	100
Figure 22 – Test circuit for the verification of the limiting value of overcurrent in case of single-phase load through a three-pole RCCB (9.18.2)	101
Figure 23 – Current ring wave 0,5 μ s/100 kHz	102
Figure 24 – Test circuit for the ring wave test at RCCBs	102
Figure 25 – Stabilizing period for reliability test (9.22.1.3).....	103
Figure 26 – Reliability test cycle (9.22.1.3).....	104
Figure 27 – Example for test circuit for verification of ageing of electronic components (9.23)	105
Figure 28 – Surge current impulse 8/20 μ s	105
Figure 29 – Test circuit for the surge current test at RCCBs.....	106

Figure 30 – Example of calibration record for short-circuit test (9.11.2.1 j) ii).....	106
Figure B.1 – Examples of methods of measuring creepage distances and clearances.....	116
Figure C.1 – Test arrangement.....	118
Figure C.2 – Grid.....	119
Figure C.3 – Grid circuit.....	119
Figure IC.1 – Examples of pillar terminals	124
Figure IC.2 – Examples of screw terminals and stud terminals	125
Figure IC.3 – Examples of saddle terminals.....	126
Figure IC.4 – Examples of lug terminals	126
Figure J.1 – Connecting samples	138
Figure J.2 – Examples of screwless-type terminals	139
Figure K.1 – Example of position of the thermocouple for measurement of the temperature-rise	144
Figure K.2 – Dimensions of male tabs	145
Figure K.3 – Dimensions of round dimple detents (see Figure K.2).....	146
Figure K.4 – Dimensions of rectangular dimple detents (see Figure K.2).....	146
Figure K.5 – Dimensions of hole detents	147
Figure K.6 – Dimensions of female connectors	147
Figure L.1 – General arrangement for the test	156
Figure L.2.....	156
Figure L.3.....	157
Figure L.4.....	157
Figure L.5.....	157
Figure L.6.....	157
Table 1 – Limit values of break time and non-actuating time for alternating residual currents (r.m.s. values) for type AC and A RCCB.....	30
Table 2 – Maximum values of break time for half-wave pulsating residual currents (r.m.s. values) for type A RCCB	31
Table 3 – Rated impulse withstand voltage as a function of the nominal voltage of the installation.....	31
Table 4 – Standard conditions for operation in service	34
Table 5 – Minimum clearances and creepage distances.....	38
Table 6 – Connectable cross-sections of copper conductors for screw-type terminals.....	44
Table 7 – Temperature-rise values.....	45
Table 8 – Requirements for RCCBs functionally dependent on line voltage	45
Table 9 – List of type tests	46
Table 10 – Test copper conductors corresponding to the rated currents	47
Table 11 – Screw thread diameters and applied torques	49
Table 12 – Pulling forces	50
Table 14 – Test voltage of auxiliary circuits	54
Table 16 – Test voltage for verification of impulse withstand voltage	56
Table 17 – Tests to be made to verify the behaviour of RCCBs under short-circuit conditions.....	63
Table 18 – Minimum values of I^2t and I_p	65

Table 19 – Power factors for short-circuit tests	69
Table 21 – Tests covered by this standard	84
Table 22 – Test voltage for verifying the suitability for isolation, referred to the rated impulse withstand voltage of the RCCB and the altitude where the test is carried out	57
Table 23 – Tests to be carried out according to IEC 61543	84
Table A.1 – Test sequences	107
Table A.2 – Number of samples for full test procedure	109
Table A.3 – Number of samples for simplified test procedure	110
Table A.4 – Test sequences for RCCBs of different classification according to 4.6	111
Table IE.1 – Test sequences during follow-up inspections	128
Table IE.2 – Number of samples to be tested	131
Table IF.1 – Indication of silver wire diameters as a function of rated currents and short-circuit currents	132
Table J.1 – Connectable conductors	135
Table J.2 – Cross-sections of copper conductors connectable to screwless-type terminals	136
Table J.3 – Pull forces	137
Table K.1 – Informative table on colour code of female connectors in relationship with the cross section of the conductor	142
Table K.2 – Overload test forces	143
Table K.3 – Dimensions of tabs	144
Table K.4 – Dimensions of female connectors	147
Table L.1 – Marking for terminals	149
Table L.2 – Connectable cross-sections of aluminium conductors for screw-type terminals	150
Table L.3 – List of tests according to the material of conductors and terminals	151
Table L.4 – Connectable conductors and their theoretical diameters	151
Table L.5 – Cross sections (S) of aluminium test conductors corresponding to the rated currents	152
Table L.6 – Test conductor length	153
Table L.7 – Equalizer and busbar dimensions	155
Table L.8 – Test current as a function of rated current	155
Table L.9 – Example of calculation for determining the average temperature deviation D....	155

INTRODUCTION

This part includes definitions, requirements and tests, covering all types of RCCBs. For the applicability to a specific type this part applies in conjunction with the relevant part, as follows:

Part 2-1: Applicability of the general rules to RCCBs functionally independent of line voltage.

Part 2-2: Applicability of the general rules to RCCBs functionally dependent on line voltage.

AUSTRALIAN/NEW ZEALAND STANDARD

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)**Part 1:
General rules (IEC 61008-1, Ed. 3.2 (2013) MOD)****1 Scope**

This International Standard applies to residual current operated circuit-breakers functionally independent of, or functionally dependent on, line voltage, for household and similar uses, not incorporating overcurrent protection (hereafter referred to as RCCBs), for rated voltages not exceeding 440 V a.c. with rated frequencies of 50 Hz, 60 Hz or 50/60 Hz and rated currents not exceeding 125 A, intended principally for protection against shock hazard.

These devices are intended to protect persons against indirect contact, the exposed conductive parts of the installation being connected to an appropriate earth electrode. They may be used to provide protection against fire hazards due to a persistent earth fault current, without the operation of the overcurrent protective device.

RCCBs having a rated residual operating current not exceeding 30 mA are also used as a means for additional protection in case of failure of the protective means against electric shock.

This standard applies to devices performing simultaneously the functions of detection of the residual current, of comparison of the value of this current with the residual operating value and of opening of the protected circuit when the residual current exceeds this value.

NOTE 1 The requirements for RCCBs are in line with the general requirements of IEC 60755. RCCBs are essentially intended to be operated by uninstructed persons and designed not to require maintenance. They may be submitted for certification purposes.

NOTE 2 Installation and application rules of RCCBs are given in the IEC 60364 series.

They are intended for use in an environment with pollution degree 2.

They are suitable for isolation.

RCCBs complying with this standard, with the exception of those with an uninterrupted neutral, are suitable for use in IT systems.

Special precautions (e.g. lightning arresters) may be necessary when excessive overvoltages are likely to occur on the supply side (for example in the case of supply through overhead lines) (see IEC 60364-4-44).

RCCBs of the general type are resistant to unwanted tripping including the case where surge voltages (as a result of switching transients or induced by lightning) cause loading currents in the installation without occurrence of flashover.

RCCBs of type S are considered to be sufficient proof against unwanted tripping even if the surge voltage causes a flashover and a follow-on current occurs.

NOTE 3 Surge arresters installed downstream of the general type of RCCBs and connected in common mode may cause unwanted tripping.

NOTE 4 For RCCBs having a degree of protection higher than IP20 special constructions may be required.