

Australian Standard®

**LETTER SYMBOLS
FOR USE IN
ELECTROTECHNOLOGY**

Part 1—GENERAL

The following scientific, industrial and governmental organizations and departments were officially represented on the committee entrusted with the preparation of this standard:

Australian Electrical and Electronics Manufacturers Association
Australian Institute of Refrigeration, Air Conditioning and Heating Inc.
Confederation of Australian Industry
Department of Construction
Department of Defence
Department of Productivity
Department of Transport
Electricity Supply Association of Australia
Institute of Draftsmen, Australia
Institution of Radio and Electronics Engineers, Australia
Melbourne and Metropolitan Board of Works
Queensland Chamber of Mines
Railways of Australia Committee
Technical press
Telecom Australia

This standard, prepared by the Joint Telecommunications and Electronics and Electrical Committee TE/13, Symbols, Units and Quantities for Electrotechnology, was approved on behalf of the Council of the Standards Association of Australia on 4 August 1977, and was published on 1 December 1978.

***Review of Australian Standards.** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

**LETTER SYMBOLS
FOR USE IN
ELECTROTECHNOLOGY**

Part 1—GENERAL

First published	1972
Revised	1978

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 4633 6

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
LETTER SYMBOLS FOR USE IN ELECTROTECHNOLOGY

PART 1 — GENERAL

1 SCOPE. This standard specifies letter symbols for physical quantities and abbreviations and symbols for units for general use in electrotechnology and lays down general principles governing their use.

2 APPLICATION. The recommendations in this standard on the use of symbols, alphabets and type fonts relate specifically to printed matter. In written and typewritten documents it is recommended that the choice of type be indicated by underlining with a straight line for italic type and with a wavy line for bold type.

In order to make the best use of the limited number of readily available alphabets and fonts, it is recommended that the general principles specified internationally be adopted.

Even with the provisions made for the use of different fonts, and cases, the number of distinctive letter symbols available for use is insufficient to enable each physical quantity or unit to be allotted a unique symbol or abbreviation. Alternatives have therefore been allotted where a need for them is most likely to arise or where alternative usage has been firmly established.

The use of the preferred symbol or abbreviation is strongly recommended.

3 LETTER SYMBOLS FOR PHYSICAL QUANTITIES.

3.1 Choice of Alphabet. Letter symbols for physical quantities shall be single letters of the Latin or Greek alphabets, with subscripts or other modifying signs where appropriate.

3.2 Choice of Type. Letter symbols for physical quantities shall be printed in *italic* (sloping) type.

It is recommended that subscripts to letter symbols for physical quantities or running numbers should also be printed in *italic* type.

Examples:

C_p	heat capacity at constant pressure p
F_x	x -component of force
σ_{xy}	x , y -component of a stress tensor σ
a_n	coefficient with $n = 1, 2, 3 \dots$

All other subscripts should be printed in roman (upright) type.

Examples:

C_g	heat capacity in the gas phase
μ_r	relative permeability
B_i	intrinsic magnetic flux density
N_A	Avogadro constant
m_0	rest mass of the electron.

It is recognized that on many occasions it will be unnecessary or undesirable to adhere to this principle; then the same type should be used consistently for all subscripts.

3.3 Vector Quantities. Letter symbols indicating the vector character of a physical quantity shall be printed in *bold face italic type* (e.g. \mathbf{H}). When such type is not available an arrow should be placed above the symbol (e.g. \vec{H}).

3.4 Quantities Which Vary with Time.

3.4.1 Physical quantities. Quantities which vary with time shall be indicated as in Table 1.

Case 1 applies where both upper-case (capital) and lower-case letters are available.

Case 2 applies where only upper-case or only lower-case letters are available.

3.4.2 General comments. Time-dependent quantities can be periodic, transient or random. The variable quantity can often be represented by a combination, e.g. sum, product, polynomial, of components which are functions such as trigonometric functions, exponentials, distributions, etc.

The intention of this clause is to codify additional symbols for the components of a combination of functions or for special values, e.g. instantaneous, root-mean-square, of more complicated time-dependent quantities, e.g. modulated wave, sets of impulses.

3.4.3 Terminology. The terminology for designating parts of symbols, additional marks and subscripts is specified in Clause 6. Definitions of special values or components of a time-dependent quantity are given in AS 1852 (101), International Electrotechnical Vocabulary—Mathematics. No definitions are given, the meaning of the symbols being illustrated by the figures in Appendix C.

3.4.4 Types of symbol for time-dependent quantities. Two types of symbols are given, one using additional marks, the other using only letter subscripts such as are found on an ordinary typewriter. A combination of both systems is possible. Most examples given in Table 7I use one set of those symbols only.

The symbol for a time-dependent quantity implies in itself the dependency on time and indicates therefore the instantaneous value.

Where both upper-case and lower-case letters are used, the lower-case letter indicates an instantaneous value and an upper-case letter an average value.

Example:

i	instantaneous value of a time-dependent electric current
I	its r.m.s. value.