

AS 3439.1—1993  
Type-tested and partially type-tested assemblies  
(IEC 439-1:1992)  
(In Professional Package 24) 135pp L  
Specifies requirements for type-tested and partially type-tested low voltage switchgear and controlgear assemblies for rated voltages up to 1000 V a.c. at frequencies not exceeding 1000 Hz, or 1500 V d.c. Applies to assemblies intended for use with generation, transmission, distribution and conversion of electrical energy and the control of electrical energy consuming equipment. This Standard is technically equivalent to and has been reproduced from IEC 439-1:1992.

Committee EL6: Supersedes AS 1136.1—1988:  
Draft for Comment DR 92127: Publication date  
1993-12-20: ISBN 0 7262 9623 0.

Amdt 1. 1989-03-13

WITHDRAWN T&S  
DECEMBER 1993  
SK BY  
AS 3439.1-1993



Standards  
Association of  
Australia



# Australian Standard® 1136.1—1988

## LOW VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES Part 1—GENERAL REQUIREMENTS

This Australian Standard was prepared by Committee EL/6, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of the Standards Association of Australia on 22 December 1987 and published on 7 March 1988.

---

The following interests are represented on Committee EL/6:

Australian-British Chamber of Commerce  
Australian Electrical and Electronic Manufacturers Association  
Bureau of Steel Manufacturers of Australia  
Department of Defence  
Electrical Contractors Associations of Australia  
Electricity Supply Association of Australia  
Independent Electrical Switchboard Manufacturers Association Ltd  
Institution of Engineers, Australia  
Metropolitan Water Sewerage and Drainage Board (Sydney)  
Testing authorities

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

*This Standard was issued in draft form for comment as DR 86175.*

**AUSTRALIAN STANDARD**

**LOW VOLTAGE SWITCHGEAR AND  
CONTROLGEAR ASSEMBLIES**  
**Part 1**  
**GENERAL REQUIREMENTS**

**AS 1136.1—1988**

First published as AS 1136—1974.  
Second edition 1980.  
Revised and redesignated AS 1136.1—1988.

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 4884 3

## PREFACE

This Standard was prepared by the Association's Committee on Industrial Switchgear and Controlgear to supersede AS 1136—1980, *Switchgear and controlgear assemblies for voltages up to 1000 V a.c.*

It is based on the 1985 edition of IEC 439-1, *Low-voltage switchgear and controlgear assemblies, Part 1: Requirements for type-tested and partially type-tested assemblies*, and acknowledgement is made of the assistance received from this source. Further Standards in this series are under consideration to cover particular requirements for assemblies to which unskilled persons may have access for their use and assemblies for construction sites.

In this Standard a type-tested low-voltage switchgear and controlgear assembly is referred to by the abbreviation TTA. Similarly a partially type-tested assembly is referred to by the abbreviation PTTA. When both a TTA and a PTTA are being referred to, the word 'assembly' (or 'assemblies') is used. The Standard defines what is meant by an assembly, a TTA and a PTTA.

This Standard differs significantly from IEC 439-1 and this is indicated both in Appendix L and by a rule in the margin against the clause or part thereof affected. Some important differences are as follows:

- (a) The manufacturer of an assembly is responsible for the correct selection and installation of components having regard to their conditions of use within the assembly including any necessary derating. Appendix J has been added concerning the selections of components.
- (b) Minimum impulse withstand voltages and minimum creepage distances are specified.
- (c) The typical forms of segregation have been extended to cover a number of variations frequently encountered.
- (d) Appendix B lists items subject to agreement between the purchaser and the manufacturer.
- (e) Appendix D is included to give guidance for the design of assemblies intended to provide increased security against the occurrence of or the effects of internal arcing faults.
- (f) Appendix E is included for the verification of the performance of assemblies designed in accordance with the guidelines set out in Appendix D. It specifies standard test conditions with the arc initiated by the connection of fuse wire at selected terminals or connections on the load side of the protective device within each compartment tested and insulation may be removed for this purpose. It also provides for special internal arcing fault tests, which may be required.
- (g) Tests carried out on assemblies to Appendix E of previous editions of AS 1136 are recognized as meeting either the standard test or a special test to Appendix E of this Standard.
- (h) Appendix F is included to show the types of system earthing for which assemblies may need to be designed.
- (i) Alternative test method for Test Duties 1 and 2 is given in Appendix K.

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1988

Users of Standards are reminded that copyright subsists in all SAA publications. Except where the Copyright Act otherwise allows, no part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia. Requests for permission should be directed to the Head Office of the Association. Where such requests relate to the reproduction of the whole or a substantial part of any Standard, permission may be conditional on an appropriate royalty payment.

## CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND OBJECT	
1.1 SCOPE .....	5
1.2 OBJECT .....	5
1.3 REFERENCED DOCUMENTS .....	5
1.4 COMPLIANCE .....	5
SECTION 2. DEFINITIONS	
2.1 GENERAL .....	6
2.2 GENERAL DEFINITIONS .....	6
2.3 CONSTRUCTIONAL UNITS .....	6
2.4 EXTERNAL DESIGN (TYPES) .....	7
2.5 STRUCTURAL PARTS .....	7
2.6 CONDITIONS OF INSTALLATION .....	7
2.7 PROTECTIVE MEASURES WITH REGARD TO ELECTRIC SHOCK .....	7
2.8 GANGWAYS .....	8
2.9 ELECTRONIC FUNCTIONS .....	8
SECTION 3. DESCRIPTION OF ASSEMBLIES	
3.1 GENERAL .....	9
SECTION 4. ELECTRICAL CHARACTERISTICS	
4.1 RATED VOLTAGES .....	10
4.2 RATED CURRENT OF A CIRCUIT .....	10
4.3 RATED SHORT-TIME WITHSTAND CURRENT OF A CIRCUIT .....	10
4.4 RATED PEAK WITHSTAND CURRENT OF A CIRCUIT .....	10
4.5 RATED PROSPECTIVE SHORT-CIRCUIT WITHSTAND CURRENT OF A CIRCUIT .....	10
4.6 RATED CONDITIONAL SHORT-CIRCUIT CURRENT OF A CIRCUIT .....	10
4.7 RATED FUSED SHORT-CIRCUIT CURRENT OF A CIRCUIT .....	10
4.8 RATED DIVERSITY FACTOR .....	10
4.9 RATED FREQUENCY .....	10
4.10 PREFERRED SHORT-CIRCUIT CAPACITY .....	11
SECTION 5. INFORMATION TO BE PROVIDED BY THE MANUFACTURER	
5.1 GENERAL .....	12
5.2 NAMEPLATES .....	12
5.3 MARKINGS .....	12
5.4 INSTRUCTIONS FOR INSTALLATION, OPERATION AND MAINTENANCE .....	12
5.5 MARKING OF TERMINALS FOR EXTERNAL CONDUCTORS .....	12
SECTION 6. SERVICE CONDITIONS	
6.1 NORMAL SERVICE CONDITIONS .....	13
6.2 SPECIAL SERVICE CONDITIONS .....	13
6.3 CONDITIONS DURING TRANSPORT, STORAGE AND ERECTION .....	13
SECTION 7. DESIGN AND CONSTRUCTION	
7.1 GENERAL .....	14
7.2 DIELECTRIC REQUIREMENTS .....	14
7.3 TERMINALS FOR EXTERNAL CONDUCTORS .....	14

	<i>Page</i>
7.4 ENCLOSURE AND DEGREE OF PROTECTION ....	15
7.5 TEMPERATURE RISE ....	16
7.6 PROTECTION AGAINST ELECTRIC SHOCK ....	16
7.7 SHORT-CIRCUIT PROTECTION AND SHORT-CIRCUIT STRENGTH ....	19
7.8 INSTALLED COMPONENTS ....	20
7.9 INTERNAL SEGREGATION BY BARRIERS OR PARTITIONS	22
7.10 INTERNAL ELECTRICAL CONNECTIONS, BARS AND INSULATED CONDUCTORS ....	24
7.11 ELECTRONIC EQUIPMENT SUPPLY CIRCUIT REQUIRE- MENTS ....	26
 SECTION 8. TEST SPECIFICATIONS	
8.1 CLASSIFICATION OF TESTS ....	27
8.2 TYPE TESTS ....	27
8.3 ROUTINE TESTS ....	34
 APPENDICES	
A INFORMATION TO BE SUPPLIED BY THE PURCHASER WHEN PLACING ENQUIRY OR ORDER ....	36
B ITEMS SUBJECT TO AGREEMENT BETWEEN THE PUR- CHASER AND THE MANUFACTURER ....	38
C DIAGRAMS SHOWING TYPICAL EXAMPLES OF LOW VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES	39
D GUIDELINES FOR ASSEMBLIES INTENDED TO PROVIDE INCREASED SECURITY AGAINST THE OCCURRENCE OF OR THE EFFECTS OF INTERNAL ARCING FAULTS ....	49
E INTERNAL ARCING-FAULT TESTS ....	51
F TYPES OF SYSTEM EARTHING ....	55
G MINIMUM AND MAXIMUM CROSS-SECTION OF COPPER CONDUCTORS SUITABLE FOR CONNECTION TO TERMI- NALS ....	57
H METHOD OF CALCULATING THE CROSS-SECTIONAL AREA OF PROTECTIVE CONDUCTORS WITH REGARD TO THER- MAL STRESSES DUE TO CURRENTS OF SHORT DURATION	58
J SELECTION OF COMPONENTS ....	59
K ALTERNATIVE TEST OF OUTGOING CIRCUITS (IF AGREED TO BE INCLUDED) ....	60
L SUMMARY OF TECHNICAL VARIATIONS BETWEEN THIS STANDARD AND IEC 439-1 ....	61

## STANDARDS ASSOCIATION OF AUSTRALIA

## Australian Standard

## LOW VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES

## Part 1—GENERAL REQUIREMENTS

## SECTION 1. SCOPE AND OBJECT

**1.1 SCOPE.** This Standard specifies requirements for type-tested and partially type-tested low-voltage switchgear and controlgear assemblies, for which—

- (a) the rated phase current  $\geq 100$  A or the rated prospective short-circuit current  $\geq 5$  kA;
- (b) the rated voltage  $\leq 1000$  V a.c. or 1500 V d.c.; and
- (c) the rated frequency  $\leq 1000$  Hz.

NOTE: For higher frequencies, special considerations may be necessary.

This Standard also applies to assemblies incorporating control and/or power equipment, the frequencies of which are higher. For such equipment appropriate additional requirements apply.

This Standard applies to stationary or movable assemblies with or without enclosures intended for use in connection with generation, transmission, distribution and conversion of electric energy and for the control of electric energy consuming equipment.

It also applies to such assemblies designed for use under special service conditions, e.g. in ships, in rail vehicles, for machine tools, for hoisting equipment, or in explosive atmospheres, provided that the relevant specific requirements are complied with.

The Standard is not intended to apply to small domestic type switchboards or to cover the performance of individual devices and self-contained components such as motor starters, circuit-breakers, contactors, fuse switches, electronic components, etc., which comply with their respective Standards. However, the compliance of such devices and components with their respective Standards does not necessarily ensure compliance of an assembly containing those components with this Standard.

## NOTES:

1. Guidance is given in Appendix D for assemblies intended to provide increased security against the occurrence of, or the effects of, internal arcing faults.
2. Parts 2 and 3 of this Standard which are under consideration will modify, supplement or replace the specific requirements of this Standard (Part 1) for—
  - (a) assemblies intended to be installed in places where unskilled persons have access for their use; and
  - (b) assemblies for construction sites.
3. Maintenance and installation recommendations are not included in this Standard. *deleted Amdt 1.*

**1.2 OBJECT.** The object of this Standard is to define the terms used and to state the service conditions, construction requirements, technical characteristics and tests.

**1.3 REFERENCED DOCUMENTS.** The following Standards are referred to in this Standard:

AS  
1202 A.C. motor starters (up to and including 1000 V)

AS	
1431	Control switching devices for voltages up to 650 V a.c. and 250 V d.c. Part 2: Particular requirements (AS 1431.2)
1775	Low voltage switchgear and controlgear—Air-break switches, isolators and fuse-combination units (up to and including 1000 V a.c. and 1200 V d.c.)
1852(441)	International electrotechnical vocabulary—Switchgear, controlgear and fuses
1931	High voltage testing techniques Part 1: General definitions, test requirements, test procedures and measuring devices (AS 1931.1)
1939	Classification of degrees of protection provided by enclosures for electrical equipment
2279	Disturbance in mains supply networks Part 2: Limitation of harmonics caused by industrial equipment (AS 2279.2) Part 4: Limitation of voltage fluctuations caused by industrial equipment (AS 2279.4)
<del>2420</del>	<del>Fire test methods for solid insulating materials and non-metallic enclosures used in electrical equipment</del>
2467	Maintenance of electrical switchgear
2752	Preferred numbers and their use <i>(Amtd)</i>
3000	SAA Wiring Rules
<del>3121</del>	<del>Approval and test specification—Insulating mouldings</del>
IEC	
112	Method for determining the comparative and the proof tracking indices of solid insulating materials under moist conditions
439	Low-voltage switchgear and controlgear assemblies Part 1: Requirements for type-tested and partially type-tested assemblies

**1.4 COMPLIANCE.** Assemblies shall be considered to comply with this Standard only when they meet all its relevant requirements.

NOTE: The requirements of this Standard for TTA are intended to apply to standardized designs of assembly intended for volume production.

The requirements of this Standard for PTTA are applicable to one-off custom built assemblies or variations of standardized designs where the variations are such that they are not fully supported by type tests. In such cases the purchaser and manufacturer must agree as to both the nature and extent of type tests to be performed, if any.