

Australian Standard<sup>®</sup>

---

**SAA LOADING CODE**

**Part 1— DEAD AND LIVE LOADS**

---

The following scientific, industrial, professional and governmental organizations and departments were officially represented on the committee entrusted with the preparation of this standard:

Association of Consulting Engineers Australia  
Australian Clay Brick Association  
Australian Council of Local Government Associations  
Australian Federation of Construction Contractors  
Australian Institute of Steel Construction Ltd  
Bureau of Meteorology  
Bureau of Steel Manufacturers of Australia  
Department of Housing and Construction  
Department of Local Government, Queensland  
Department of Public Works, Western Australia  
Division of Building Research CSIRO  
Electricity Supply Association of Australia  
Engineering and Water Supply Department South Australia  
Experimental Building Station  
Master Builders Federation of Australia Incorporated  
National Association of Australian State Road Authorities  
James Cook University of North Queensland  
Monash University  
University of Melbourne

---

This standard, prepared by Committee BD/ 6, Loading on Structures, was approved on behalf of the Council of the Standards Association of Australia on 12 September 1980, and was published on 1 March 1981.

This standard is intended to establish the minimum intensity of loading to be used in the structural design of buildings but does not purport to comprise all the necessary provisions of a contract.

---

**Review of Australian Standards.** *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

*Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.*

*Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.*

Australian Standard<sup>®</sup>

---

**MINIMUM DESIGN LOADS ON  
STRUCTURES**

**KNOWN AS THE  
SAA LOADING CODE**

**Part 1  
DEAD AND LIVE LOADS**

---

First published . . . . .	1971
Second edition . . . . .	1981

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
1 THE CRESCENT, HOMEBUSH, NSW 2140

## PREFACE

This edition of this standard has been prepared by the Association's Committee on Loading of Structures. No new technical changes from the 1971 edition have been introduced in this edition, but some editorial updating has been carried out and the opportunity has been taken to present the standard in A4 size in order to facilitate reference from other major SAA structural codes, all of which are now in A4 size.

The standard is intended to be used in establishing the minimum dead and imposed loadings to be assumed in the structural design of buildings, industrial structures and the like but does not apply to special structures such as bridges and cranes nor to loads arising from fluid pressures.

In establishing the metric unit values derived from the former imperial-unit standard (AS CA34, Part 2), some rounding off of numbers has been carried out generally in line with BS CP3, Chapter V—Part 1; for example—

1 in = 25 mm (25.4 mm exact).

Similarly, concentrated loads have been limited to one place of decimals; e.g.—

1.8 kN = 400 lbf (405 lbf exact).

The density of materials has been rounded to the nearest 10 kg/m<sup>3</sup>; e.g. aluminium 2720 kg/m<sup>3</sup> (2723 kg/m<sup>3</sup> exact). It should be noted that where data in this standard are given in units of *mass*, the gravitational forces in newtons imposed by such masses may be obtained by multiplying the values given in kilograms by 10. This is an approximation of the value of acceleration due to gravity which is very close to 9.8 ms<sup>-2</sup> in Australia (see AS 1155—1974, Appendix B).

Attention is drawn to the following Australian standards which may be required for use in connection with this standard:

- AS 1000 The International System of Units (SI) and its Application
- AS 1155 Metric Units for Use in the Construction Industry
- AS 1170 SAA Loading Code  
Part 2—Wind Forces
- AS 1418 SAA Crane Code
- AS 1657 SAA Code for Fixed Platforms, Walkways, Stairways and Ladders
- AS 1684 SAA Timber Framing Code
- AS 1735 SAA Lift Code
- AS 2121 SAA Earthquake Code.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 Scope . . . . .	4
1.2 Combinations of Loading . . . . .	4
1.3 Definitions . . . . .	4
1.4 Working Drawings . . . . .	4
1.5 Posting of Floor Capacities . . . . .	4
SECTION 2. DEAD LOADS	
2.1 Masses of Materials and Construction . . . . .	5
2.2 Provision for Partitions . . . . .	5
SECTION 3. LIVE LOADS	
3.1 Floor, Ceiling and Like Live Loads . . . . .	6
3.2 Partial Loading . . . . .	6
3.3 Impact and Inertia Loads . . . . .	6
3.4 Crane, Hoist and Lift Loads . . . . .	6
3.5 Long Duration Loading . . . . .	6
3.6 Thermal Movements Loads . . . . .	6
3.7 Other Live Loads . . . . .	6
3.8 Roof Live Loads . . . . .	7
3.9 Reduction of Uniformly Distributed Live Loads . . . . .	8
APPENDIX A. DENSITY AND MASS OF MATERIALS AND CONSTRUCTION . . .	9
Table A1 Basic Materials . . . . .	9
Table A2 Building Materials and Construction . . . . .	10
APPENDIX B. MINIMUM FLOOR LIVE LOADS . . . . .	12
APPENDIX C. DENSITY OF DENSE-AGGREGATE CONCRETE . . . . .	17
APPENDIX D. LIVE LOAD REDUCTIONS ON BEARING WALLS . . . . .	18

STANDARDS ASSOCIATION OF AUSTRALIA

---

**Australian Standard**

**for**

**MINIMUM DESIGN LOADS ON STRUCTURES**

---

**PART 1—DEAD AND LIVE LOADS**

---

**SECTION 1. SCOPE AND GENERAL**

**1.1 SCOPE.** This standard sets out requirements for establishing the minimum dead and live loads to be used in the structural design of buildings and of structures associated with buildings which are to be erected under the provisions of building regulations, by-laws, ordinances, and the like.

It does not cover loads arising from pressures exerted by contained material in bunkers, tanks, silos and the like, nor does it cover loadings on special structures such as road or rail bridges or lifting devices.

For wind loads for structural design purposes, see AS 1170, Part 2.

NOTE: Information on earthquake loads is provided in AS 2121.

**1.2 COMBINATIONS OF LOADING.** Except as otherwise noted, all structures to which this standard applies shall be designed, consistently with relevant SAA structural design standards, to withstand such combinations of dead, live, wind and other loads as are appropriate to the design of the structure and will produce the most adverse effects.

**1.3 DEFINITIONS.** For the purposes of this standard the following definitions apply:

*Live load*—the load assumed to arise from the intended use or purpose of the building or structure, including distributed, concentrated, impact and inertia loads, but excluding wind, snow and earthquake loads.

NOTE: Many live loads are applied for short durations relative to the life of the structure. However, the attention of the designer is drawn to the fact that some live loads falling within the definition given above may be of long duration, and have an effect similar to dead loads (see Clause 3.5, Long Duration Loading).

*Dead load*—the load imposed by components of the building or structure including the forces imposed by all walls, floors, roofs, suspended ceilings, permanent partitions, service machinery (including lift and air-conditioning machinery), and other permanent construction (including reticulated services).

**1.4 WORKING DRAWINGS.** The live loads for which each floor system, or part of the floor system where the load capacity is not uniform throughout, has been designed shall be clearly marked on floor plans of structural working drawings.

**1.5 POSTING OF FLOOR CAPACITIES.** Where a floor or part of a floor of a building has been designed in accordance with this standard to sustain a uniformly distributed live load exceeding 5 kPa, a notice in the form shown hereunder and indicating the actual loadings for which the floor has been structurally designed shall be conspicuously and permanently posted in a position adjacent to such floor or such part of a floor.

<b>DESIGNED FLOOR LOADING</b>	
<b>Distributed</b> .....	<b>kilograms per square metre</b>
<b>Concentrated</b> .....	<b>kilograms</b>

The lettering of such notice shall be embossed or cast into a metal tablet not less than 225 mm square and located not less than 1 m above floor level.