

Australian Standard<sup>®</sup>

---

**SURGE ARRESTERS (DIVERTERS)  
Part 1—SILICON CARBIDE TYPE  
FOR A.C. SYSTEMS**

---

This Australian standard was prepared by Committee EL/7, Power Switchgear. It was approved on behalf of the Council of the Standards Association of Australia on 13 January 1986 and published on 7 April 1986.

---

The following interests are represented on Committee EL/7:

Australian-British Chamber of Commerce  
Australian Electrical and Electronic Manufacturers' Association  
Confederation of Australian Industry  
Electricity Supply Association of Australia  
Institution of Engineers, Australia  
Railways of Australia Committee  
Testing Authorities

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

*This standard was issued in draft form for comment as DR 84248.*

Australian Standard<sup>®</sup>

---

**SURGE ARRESTERS (DIVERTERS)  
Part 1—SILICON CARBIDE TYPE  
FOR A.C. SYSTEMS**

---

First published (as AS C338) . . . . .	1965
Revised and issued as AS 1307 . . . . .	1974
Revised and issued as AS 1307.1 . . . . .	1986

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 4086 9

## PREFACE

This standard was prepared by the Association's Committee on Power Switchgear to supersede AS 1307—1974, Surge Diverters—Non-linear Resistor Type.

NOTE: The internationally accepted term arrester is now used in place of 'diverter' as used in AS 1307—1974.

Due to the development in surge arresters, it is now necessary to have two standards, one for silicon carbide type and one for metal-oxide type. These standards now form the AS 1307 series and are as follows:

Part 1—Silicon Carbide Type for A.C. Systems

Part 2—Metal-oxide Type for A.C. Systems

This standard (i.e. AS 1307.1) is based generally on the IEC standards listed below. Acknowledgement is made of the assistance received therefrom.

IEC 99-1 (1970) Lightning Arresters Part 1. Non-linear Resistor Type for A.C. Systems

IEC 99-1A (1965) First Supplement to Publication 99-1 (First Edition, 1958)

This standard differs from AS 1307-1974 in a number of ways. These include:

- (a) Incorporation of Australian submissions to IEC for the revision of the above IEC Standards.
- (b) Appendices based on Appendices A, D and E of IEC 99-1, omitted from AS 1307—1974, are now included as Appendices F, H and G respectively.
- (c) The definition of homogeneous series of arresters (Clause 2.2.7) and amendments to requirements associated therewith, are now included.
- (d) The specification of rated continuous operating voltage and the test for its verification (Clauses 3.2 and 5.6) are included.
- (e) Arresters are no longer required to withstand their rated voltage continuously.
- (f) Introduction of pressure-relief Types S and NS (Clause 5.7).
- (g) The pressure-relief classes in Table 5.5 are now extended by the addition of classes for 63 000 A and 50 000 A minimum prospective symmetrical fault current.
- (h) Revised requirement for the determination of current amplitude in the first major loop (Clause 5.7.2.3).
- (j) Amendment to Appendix C based on IEC document 37(Central Office)30 and incorporating an Australian submission concerning temporary overvoltages due to earth faults and for the determination of earth fault factors.
- (k) Cross-references to other standards have been updated.

Where this standard deviates technically from IEC 99-1 and 99-1A by way of different or additional requirements, this is indicated by a rule in the margin against the Clause, or part thereof, affected. A summary of such technical variations is given in the Annex.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 Scope . . . . .	4
1.2 Referenced Documents . . . . .	4
1.3 Service Conditions . . . . .	4
SECTION 2. DEFINITIONS	
2.1 Application . . . . .	5
2.2 Arresters and Their Component Parts . . . . .	5
2.3 Electrical Testing . . . . .	5
2.4 Electrical Characteristics . . . . .	6
2.5 Protective Characteristics . . . . .	7
2.6 Classification of Tests . . . . .	7
SECTION 3. RATING AND MARKING	
3.1 Rated Arrester Voltage . . . . .	8
3.2 Rated Continuous Operating Voltage . . . . .	8
3.3 Rated Frequency . . . . .	8
3.4 Nominal Discharge Current . . . . .	8
3.5 Marking . . . . .	8
SECTION 4. ARRESTER CLASSIFICATION AND TEST REQUIREMENTS	
4.1 Arrester Classification . . . . .	9
4.2 Test Samples and Measurements . . . . .	9
4.3 Type Tests . . . . .	9
4.4 Additional Type Tests . . . . .	9
4.5 Routine Tests . . . . .	9
4.6 Acceptance Tests . . . . .	9
SECTION 5. TESTS AND TEST PROCEDURES	
5.1 Power-frequency Voltage Tests . . . . .	11
5.2 Impulse-voltage Tests . . . . .	11
5.3 Residual-voltage Test (Test (f)) . . . . .	13
5.4 Impulse-current Withstand Tests . . . . .	14
5.5 Operating-duty Test (Test (j)) . . . . .	16
5.6 Continuous Operating-voltage Test (Test (k)) . . . . .	17
5.7 Pressure-relief Tests (Test (l)) . . . . .	18
5.8 Arrester-seal Leakage-rate (Test (m)) . . . . .	20
5.9 Accelerated Ageing Test for Elastomeric Seals (Test (n)) . . . . .	20
5.10 Test for Resistance of Arrester Seals to Damage Caused by Over Tightening of Terminals (Test (o)) . . . . .	21
5.11 Tests on Arrester Disconnectors (Test (p)) . . . . .	21
APPENDICES	
A Special Service Conditions . . . . .	23
B Information to be Provided by Purchaser with Enquiry and Order . . . . .	24
C Application Guide for Silicon Carbide Type Arresters . . . . .	25
D Impulse Voltage and Current Waveshapes . . . . .	43
E Measurement of Leakage Current . . . . .	46
F Typical Circuit for the Operating-duty Test (Clause 5.5) . . . . .	47
G Typical Circuit for a Distributed-constant Impulse Generator for the Long-duration Current-impulse Withstand Test (Clause 5.4.3) . . . . .	49
H Proposals for the Artificial-pollution Testing of Surge Arresters . . . . .	50
J Items Subject to Agreement Between the Purchaser and the Manu- facturer . . . . .	55
ANNEX. SUMMARY OF TECHNICAL DEVIATIONS BETWEEN THIS STANDARD AND IEC 99-1 AND 99-1A . . . . .	56

## STANDARDS ASSOCIATION OF AUSTRALIA

**Australian Standard**  
**for**  
**SURGE ARRESTERS (DIVERTERS)**

## PART 1—SILICON CARBIDE TYPE FOR A.C. SYSTEMS

## SECTION 1. SCOPE AND GENERAL

**1.1 SCOPE.** This standard specifies requirements for non-linear silicon carbide resistor gap type surge arresters (diverters) designed for repeated operation to limit voltage surges on a.c. power circuits and to interrupt power follow-current. In particular, for use on high voltage a.c. power circuits, it applies to surge arresters consisting of single or multiple spark gaps in series with one or more silicon carbide type non-linear resistors.

It does not specify requirements for non-linear metal-oxide type surge arresters; requirements for such arresters are specified in AS 1307.2.

**1.2 REFERENCED DOCUMENTS.** The following standards are referred to in this standard:

AS 1824	Insulation Coordination (Phase-to-earth and Phase-to-phase, Above 1 kV) Part 1—Basic Principles, Standard Insulation Levels and Test Procedures Part 2—Application Guide
AS 1931	High Voltage Testing Techniques Part 1—General Definitions, Test Requirements, Test Procedures and Measuring Devices
AS 2650	High-voltage A.C. Switchgear and Controlgear—Common Requirements
AS 1307.2	Surge Arresters (Diverters) Part 2—Metal-oxide Type for A.C. Systems*
IEC 99-1	Lightning Arresters Part 1—Non-linear Resistor Type for A.C. Systems
ASTM D2000	Classification System for Rubber Products in Automotive Applications

**1.3 SERVICE CONDITIONS.**

**1.3.1 Normal service conditions.** Surge arresters which comply with this standard shall be suitable for outdoor operation under the following conditions:

- (a) Ambient temperature within the range of  $-10^{\circ}\text{C}$  to  $+50^{\circ}\text{C}$ .
- (b) Maximum solar radiation does not exceed  $1.1 \text{ kW/m}^2$ . (This is equivalent to a black body temperature of  $80^{\circ}\text{C}$ .)
- (c) The ambient air not excessively (or abnormally) polluted by dust, smoke, corrosive or flammable gases, vapour or salt.
- (d) Altitude not exceeding 1000 m.
- (e) Frequency of the a.c. power supply not less than 48 Hz and not greater than 52 Hz.
- (f) The power-frequency voltage applied continuously between the live and earth terminals of the arrester shall not exceed its continuous operating voltage.
- (g) Wind pressure not exceeding 1.2 kPa.  
NOTE: The wind pressure is the free stream dynamic pressure and corresponds to a wind velocity of 45 m/s (on a projected flat surface).
- (h) Vibrations due to causes external to the surge arrester and earth tremors are negligible.

**1.3.2 Special service conditions.** Arresters subjected to other than normal application or service conditions may require consideration in manufacture or application and each such case should be subject to discussion between the purchaser and the manufacturer. See Appendix A for special service conditions, and Appendix C for special applications of surge arresters.

\* In course of preparation.