

Australian/New Zealand Standard™

**Performance of electrical appliances—
Airconditioners and heat pumps**

**Part 1.2: Ducted airconditioners and air-
to-air heat pumps—Testing and rating
for performance (ISO 13253:2011, MOD)**



AS/NZS 3823.1.2:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-015, Quality and Performance of Household Electrical Appliances. It was approved on behalf of the Council of Standards Australia on 3 April 2012 and on behalf of the Council of Standards New Zealand on 27 April 2012. This Standard was published on 11 May 2012.

The following are represented on Committee EL-015:

Australian Building Codes Board
Australian Industry Group
Australian Retailers Association
Business New Zealand
CHOICE
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Department of Climate Change and Energy Efficiency
Department of Justice and Attorney General, Qld
Electrical Compliance Testing Association
Energy Efficiency & Conservation Authority of New Zealand
Energy Safe Victoria
Equipment Energy Efficiency Committee
Industry and Investment NSW
Institution of Professional Engineers New Zealand
National Association of Testing Authorities Australia
Office of the Technical Regulator, SA

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 3823.1.2.

Australian/New Zealand Standard™

**Performance of electrical appliances—
Airconditioners and heat pumps**

**Part 1.2: Ducted airconditioners and air-
to-air heat pumps—Testing and rating
for performance (ISO 13253:2011, MOD)**

Originated as AS/NZ 3823.1.2:2001.
Second edition 2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 1 74342 105 5

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-015, Quality and Performance of Household Electrical Appliances.

This Standard is an adoption with national modifications and has been reproduced from ISO 13253:2011, *Ducted air-conditioners and air-to-air heat pumps—Testing and rating for performance*, and has been varied as indicated to take account of Australian/New Zealand conditions. The modifications are set out in Appendix ZZ.

Although there have been many detailed changes to ISO 13253:2011 compared with ISO 13253:1995, many of these changes were anticipated in AS/NZS 3823.1.2:2001 Appendix ZZ, so there are few net technical changes in the new edition. The most significant changes are:

- (a) The more detailed test procedures for cyclic heating tests to improve the reproducibility of testing.
- (b) The addition of equations for calculating the discharge coefficient of nozzles.
- (c) The introduction of uncertainty of measurement requirements.
- (d) The ability to use a calorimeter to test ducted units (this was already in AS/NZS 3823.1.2 Appendix ZZ but is now included in ISO 13253).
- (e) There are two methods described for setting and controlling the air-flow rate on the indoor side. Both methods simulate a fixed duct resistance in the airconditioner installation, not a fixed air-flow rate as in the previous edition.

As this Standard is reproduced from an International Standard, the following applies:

- (i) Its number appears on the cover and title page while the International Standard number appears only on the cover.
- (ii) In the source text ‘this International Standard’ should read ‘this Australian/New Zealand Standard’.
- (iii) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian/New Zealand Standard</i>
ISO	AS/NZS
5151 Non-ducted air conditioners heat pumps—Testing and rating for performance	3823 Performance of electrical appliances—Airconditioners and heat pumps
	3823.1.1 Part 1.1: Non-ducted airconditioners and heat pumps—Testing and rating for performance

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex or appendix to which they apply. A ‘normative’ annex or appendix is an integral part of a Standard, whereas an ‘informative’ annex or appendix is only for information and guidance.

CONTENTS

1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Symbols	4
5	Airflow	7
5.1	General	7
5.2	Indoor airflow setting	7
5.3	ESP for rating	7
5.4	Outdoor airflow	9
5.5	Unit supplied without indoor fan	9
6	Cooling tests	9
6.1	Cooling capacity tests	9
6.2	Maximum cooling performance test	11
6.3	Minimum cooling performance test	13
6.4	Condensate control and enclosure sweat performance test	15
7	Heating tests	16
7.1	Heating capacity tests	16
7.2	Maximum heating performance test	21
7.3	Minimum heating performance test	22
8	Test methods and uncertainties of measurement	23
8.1	Test methods	23
8.2	Uncertainty of measurement	24
8.3	Test tolerances for steady-state cooling and heating capacity tests	25
8.4	Test tolerances for steady state performance tests	26
9	Test results	27
9.1	Capacity results	27
9.2	Data to be recorded	28
9.3	Test report	31
10	Marking provisions	32
10.1	Nameplate requirements	32
10.2	Nameplate information	32
10.3	Split systems	32
11	Publication of ratings	32
11.1	Standard ratings	32
11.2	Other ratings	33
	Annex A (normative) Airflow settings for ducted units	34
	Annex B (normative) Test requirements	39
	Annex C (informative) Airflow measurement	45
	Annex D (normative) Calorimeter test method	51
	Annex E (normative) Indoor air enthalpy test method	59
	Annex F (informative) Compressor calibration test method	65
	Annex G (informative) Refrigerant enthalpy test method	68

Annex H (informative) Outdoor air enthalpy test method	70
Annex I (informative) Indoor calorimeter confirmative test method	73
Annex J (informative) Outdoor calorimeter confirmative test method	75
Annex K (informative) Balanced-type calorimeter confirmative test method	77
Annex L (informative) Cooling condensate measurements	78
Annex M (normative) Supplemental requirements when rating fan-less (coil-only) type units	79
Annex N (informative) Pictorial examples of the heating capacity test procedures given in 7.1	82
Bibliography	89

AUSTRALIAN/NEW ZEALAND STANDARD

Performance of electrical appliances—Airconditioners and heat pumps

Part 1.2:

Ducted airconditioners and air-to-air heat pumps—Testing and rating for performance (ISO 13253:2011, MOD)

1 Scope

This International Standard specifies the standard conditions for capacity and efficiency ratings of ducted, air-cooled air-conditioners and ducted air-to-air heat pumps. This International Standard is applicable to the test methods for determining the capacity and efficiency ratings. Residential, commercial, and industrial single-package and split-system air-conditioners and heat pumps are included. The equipment (taken to mean ducted air-conditioners and/or ducted heat pumps) shall be factory-made and electrically driven, and shall use mechanical compression.

This International Standard is applicable to equipment utilizing one or more refrigeration systems, one outdoor unit and one or more indoor units controlled by a single thermostat/controller. This International Standard is applicable to equipment utilizing single-, multiple- and variable-capacity components.

This International Standard is not applicable to the rating and testing of the following:

- a) water-source heat pumps or water-cooled air-conditioners;
- b) multi-split-system air-conditioners and air-to-air heat pumps (see ISO 15042 for testing of such equipment);
- c) mobile (windowless) units having a condenser exhaust duct;
- d) individual assemblies not constituting a complete refrigeration system;
- e) equipment using the absorption refrigeration cycle;
- f) non-ducted equipment (see ISO 5151 for testing of such equipment).

This International Standard does not cover the determination of seasonal efficiencies that can be required in some countries because they provide a better indication of efficiency under actual operating conditions.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC Guide 98-3, *Uncertainty of measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

ISO 817, *Refrigerants — Designation and safety classification*

ISO 5151, *Non-ducted air conditioners and heat pumps — Testing and rating for performance*