

Australian Standard[®]

**Separable insulated connectors for
power distribution systems above 1 kV**



This Australian Standard® was prepared by Committee EL-007, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 8 November 2007. This Standard was published on 15 August 2008.

The following are represented on Committee EL-007:

- Australian British Chamber of Commerce
 - Australian Electrical and Electronic Manufacturers Association
 - Australian Railway Association
 - Energy Networks Association
 - Engineers Australia
 - Testing interests
-

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting **www.standards.org.au**

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at **mail@standards.org.au**, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Separable insulated connectors for
power distribution systems above 1 kV**

Originated as AS 2629—1983.
Second edition 2008.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia
ISBN 0 7337 8869 6

PREFACE

This Standard was reviewed by the Standards Australia Committee EL-007, Power Switchgear to supersede AS 2629—1983.

This Standard is republished from AS 2629—1983, without technical alterations. Referenced documents have been updated.

It applies to a simple and relatively inexpensive method of connection and switching of transformers and other electrical equipment in distribution systems using special flexible cable connectors.

The separable connectors covered by this Standard are intended for use only as a part of a fully protected distribution system.

This Standard illustrates a number of suitable connection interfaces, and users and manufacturers are encouraged to adopt the interface designs shown. However, connectors with interfaces different from those shown in this Standard may be in the course of development.

ANSI/IEEE Standard 386—1977 was used as the basis for this Standard and acknowledgement is made of the assistance received therefrom.

Owing to the fact that separable insulated connectors imported into Australia are manufactured to comply with requirements specified in the country of manufacture and may not be available in a form to comply with all the requirements of AS 1824, *Insulation Coordination*, certain exemptions are permitted in this Standard subject to the agreement of the purchaser.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 SERVICE CONDITIONS.....	4
SECTION 2 DEFINITIONS	
2.1 APPLICATION OF SECTION.....	6
2.2 GENERAL TERMS.....	6
2.3 HARDWARE ITEMS.....	6
2.4 ELECTRICAL CHARACTERISTICS	7
SECTION 3 RATINGS	
3.1 VOLTAGE RATINGS	13
3.2 RATED FREQUENCY	13
3.3 CURRENT RATINGS.....	13
SECTION 4 DESIGN, CONSTRUCTION AND MARKING	
4.1 DESIGN	15
4.2 INTERCHANGEABILITY	15
4.3 OPERATING MEANS.....	15
4.4 SHIELDING.....	15
4.5 TEST POINTS.....	15
4.6 HOLD-DOWN BAILS	15
4.7 MARKING	16
SECTION 5 PERFORMANCE	
5.1 BEHAVIOUR ON TESTAND IN SERVICE	28
5.2 OPERATING TEMPERATURE OF MATERIALS	28
SECTION 6 CLASSIFICATION OF TESTS	
6.1 TYPE TESTS	29
6.2 ROUTINE TESTS	29
6.3 TESTS AT SITE.....	29
SECTION 7 DETAILS OF TYPE TESTS	
7.1 DIELECTRIC TESTS	32
7.2 SHORT-CIRCUIT CURRENT-CARRYING CAPABILITY TEST	33
7.3 SWITCHING CURRENT TESTS (Applicable to load-break connectors only)	33
7.4 SHORT-CIRCUIT MAKING CURRENT TEST (Applicable to load-break connectors only).....	35
7.5 CONNECTOR ELBOW DISTORTION TEST FOR OFF-AXIS FORCE (Applicable only to elbows of the non-bolted type).....	35
7.6 CURRENT CYCLING TEST	38
7.7 CABLE PULL-OUT TEST.....	39
7.8 OPERATING FORCE TEST.....	40
7.9 OPERATING EYE TEST.....	40
7.10 TEST POINT CAP MECHANICAL TEST	40
7.11 TEST POINT ELECTRICAL TESTS.....	41
7.12 SHIELDING TEST.....	41
7.13 ACCELERATED SEALING LIFE TEST	41

STANDARDS AUSTRALIA

Australian Standard

**Separable insulated connectors for power distribution systems
above 1 kV**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for load-break and dead-break separable insulated connectors and ancillary equipment for use on power distribution systems at alternating voltages above 1 kV.

The Standard applies to separable insulated connectors rated at not more than 1250 A.

NOTE: Load-break connectors are available only for the lower current ratings. The purchaser should obtain information from manufacturers on available current ratings.

1.2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

60270 High-voltage test techniques—Partial discharge measurements

1931 High-voltage test techniques

1931.1 Part 1: General definitions and test requirements

AS/NZS

1429 Electric cables—Polymeric insulated

1429.1 Part 1: For working voltages 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV

IEEE

592 Exposed Semiconducting Shields on High Voltage Cable Joints and Separable Connectors

1.3 SERVICE CONDITIONS**1.3.1 Normal service conditions**

Connectors complying with this Standard are suitable for use in clean air and exposure to direct sunlight, under the following conditions:

- (a) The ambient air temperature does not exceed 40°C, and its average value measured over a period of 24 h does not exceed 35°C.
- (b) The ambient air temperature is not less than –10°C.
- (c) The maximum temperature due to sunlight does not exceed an equivalent black body temperature of 80°C.

NOTE: For practical purposes this is equivalent to 1.1 kW/m².

- (d) The altitude does not exceed 1000 m.
- (e) The ambient air is not materially polluted by dust, smoke, corrosive or flammable gases and vapours or salt.

NOTE: Sudden drops of temperature of up to 20°C in a period of 20 min and the presence of rain and condensation should be taken into account.