

AS 2022—1983

Australian Standard[®]

**SAA ANHYDROUS
AMMONIA CODE**

This Australian standard was prepared by Committee ME/32, Anhydrous Ammonia. It was approved on behalf of the Council of the Standards Association of Australia on 7 July 1983 and published on 5 September 1983.

The following interests are represented on Committee ME/32:

Australian Road Transport Federation
Board of Fire Commissioners, N.S.W.
Confederation of Australian Industry
Department of Employment and Labour Relations, Qld
Department of Health, N.S.W.
Department of Industrial Affairs and Employment, S.A.
Department of Industrial Relations, N.S.W.
Department of Labour and Industry, W.A.
Department of Minerals and Energy, Vic.
Department of Mines, W.A.
Metropolitan Fire Brigades Board, Melbourne
Railways of Australia Committee

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 2022—1983

Australian Standard[®]

**ANHYDROUS AMMONIA –
STORAGE AND HANDLING**

known as the

SAA ANHYDROUS AMMONIA CODE

First published (as AS CB23)	1969
Revised and issued as AS 2022	1978
Second edition	1983

Incorporating:
Amdt. 1–1985

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 3103 7

PREFACE

This edition of this standard was prepared by the Association's Committee on Anhydrous Ammonia to supersede AS 2022-1978.

The most significant technical difference in this edition is that the design pressure has been adjusted to correct value for ammonia, i.e. 1.73 MPa. The previous edition had specified that the design pressure be that for propane, i.e. 1.75 MPa, the intention being to provide for those cases where tanks might be switched from one usage to another. It has now been decided that, to be technically correct, the standard must specify the exact minimum acceptable design pressure, and that the matter of changing cargoes should be covered by a warning note.

The testing and inspection periods for tanks and tank components have been reviewed, and adjusted where necessary. The requirement for the number of people in attendance during transfer has been reviewed, and the point of change from one attendant to two has been altered.

The terminology used in relation to sizes of tanks and cylinders, previously expressed variously in terms of volume, water capacity, or ammonia tonnage, has been rationalized and is now based on a concept similar to that adopted in AS 1596, SAA LP Gas Code, and AS 1940, ASS Flammable and Combustible Liquids Code, i.e. the internal capacity of the container expressed as a volume.

The only other adjustments are editorial, the most significant of which concern the updating of the list of referenced standards, now transferred to an annex.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>		<i>Page</i>
SECTION 1. SCOPE AND GENERAL		SECTION 4. TANKS FOR TRANSPORTATION	
1.1 Scope	4	4.1 General	13
1.2 Application	4	4.2 Road and Rail Tank Vehicles	13
1.3 New Designs and Innovations	4	4.3 Skid Tanks, Nurse Tanks and Applicator Tanks	13
1.4 Interpretations	4		
1.5 Referenced Documents	4	SECTION 5. CYLINDERS AND CYLINDER SYSTEMS	
1.6 Definitions	4	5.1 Equipment	14
		5.2 Location and Installation	14
SECTION 2. COMMON REQUIREMENTS FOR SYSTEMS AND EQUIPMENT		SECTION 6. REFRIGERATED STORAGE	
2.1 General	6	6.1 Application of Section	15
2.2 Cylinders, Tanks, Storages	6	6.2 Tank Construction	15
2.3 Ancillary Fittings and Equipment ...	6	6.3 Location and Installation	15
2.4 Pressure-relief Valves	7	6.4 Filling and Discharging Valves	15
2.5 Excess-flow Valves and Non-return Valves	7	6.5 Pressure Relief	15
2.6 Manual Shut-off Valves	7	6.6 Refrigeration System	16
2.7 Liquid Level Gauges	8		
2.8 Pressure Gauges	8	SECTION 7. OPERATIONS	
2.9 Temperature Gauges	8	7.1 General Precautions	17
2.10 Piping	8	7.2 Responsibility	17
2.11 Flexible Pipe Connections	8	7.3 Inspection and Testing	18
2.12 Flexible Steel Hose	9	7.4 Filling and Discharging	18
2.13 Rubber Hose	9	7.5 Cylinder Handling and Transport	19
2.14 Pumps	9	7.6 Leak Detection and Location	19
2.15 Compressors	9	7.7 Repairs	19
2.16 Vaporizers	10		
SECTION 3. FIXED TANK STORAGE		APPENDICES	
3.1 Application of Section	11	A Properties of Anhydrous Ammonia	20
3.2 Tank Location	11	B Capacity of Safety Valves	22
3.3 Installation	11	C Materials for Ammonia Tanks	23
3.4 Safety Equipment	12	D Tank Filling Level	24
		ANNEX. LIST OF REFERENCED DOCUMENTS	26

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
ANHYDROUS AMMONIA — STORAGE AND HANDLING

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out requirements for the design, construction and operation of equipment and installations for the storage and handling of anhydrous ammonia, and for its transport by road and rail. It does not deal with any plant or equipment in which ammonia is processed, or with any vessels that form an integral part of that processing equipment.

1.2 APPLICATION. The requirements of this standard may be read in conjunction with any Statutory Regulations that may apply in any area.

NOTE: It should be noted that an installation may come under the jurisdiction of several authorities with differing areas of responsibility, and that an approval from one does not necessarily constitute an approval from others. Thus the construction of any plant may require separate approvals from authorities interested in building construction, hazardous materials, factory or machinery safety, electricity, gas, health, environment, water supply, sewerage and drainage, or the training and licensing of personnel.

1.3 NEW DESIGNS AND INNOVATIONS. Any novel materials, designs, methods of assembly, procedures, etc which do not comply with the specific requirements of this standard, or are not mentioned in it, but which give equivalent results to those specified are not necessarily prohibited. The responsible committee, ME/32, Anhydrous Ammonia, can act in an advisory capacity concerning equivalent suitability, but specific approval remains the prerogative of the Statutory Authority.

1.4 INTERPRETATIONS. Questions concerning the clarity, meaning, application or effect of any part of this standard may be referred to SAA Committee ME/32 for explanation. The authority of the committee is limited to matters of interpretations, and it will not adjudicate in disputes.

1.5 REFERENCED DOCUMENTS. A list with titles of the documents referred to in this standard is given in the Annex.

1.6 DEFINITIONS. For the purpose of this standard, the following definitions apply:

1.6.1 Anhydrous ammonia - ammonia gas in compressed and/or liquefied form.

1.6.2 'Approved' or 'approval' - approved by, or approval of, the Statutory Authorities concerned.

1.6.3 Authorized person - a person specifically appointed by an anhydrous ammonia distributor or the distributor's agent to perform the duties of that position.

1.6.4 Capacity (of a tank or cylinder) - the total volume of the space enclosed within the tank or cylinder, expressed in litres or cubic metres.

NOTE: This is synonymous with and numerically equal to water capacity.

1.6.5 Consumer - a person who purchases anhydrous ammonia for his own use and not for resale.

1.6.6 Container - a cylinder or tank specifically designed and constructed for the storage and/or transport of anhydrous ammonia.

1.6.7 Cylinder - a container specifically designed and constructed in accordance with Clause 2.2.1 and used in the manner prescribed in this standard.

1.6.8 Design pressure - the maximum allowable working pressure in a container or pipeline.

1.6.9 Design temperature - the allowable metal temperature of a container or pipe in accordance with the relevant design code.

1.6.10 Excess-flow valve - a valve normally in the open position which closes automatically when the flow in the direction for which the valve was designed exceeds a predetermined limit specified by the manufacturer. The valve will re-open or can be re-opened when the conditions which resulted in closure are no longer present.

1.6.11 Filler - a person authorized to fill containers with anhydrous ammonia.

1.6.12 Mass filling ratio - the ratio between the greatest mass of anhydrous ammonia permitted in a tank and the mass of water at 15°C which would completely fill the tank.

1.6.13 Fixed storage system - a stationary anhydrous ammonia storage system, including the tank or tanks, tank fittings and the ancillary equipment essential for the safe operation of the system. It also includes portable tanks as defined in Clause 1.6.24(d) or (e) if such tanks are installed and used in a fixed storage system.

1.6.14 Fusible plug, fusible link - a safety device consisting of a suitable low melting point material which is intended to yield or melt at a predetermined temperature.

1.6.15 Internal quick-closing remotely controlled shut-off valve - a valve designed to close both automatically on the operation of one or more fusible links or fusible plugs and manually from a remote position by the release of the means of holding the valve open.

1.6.16 Non-return valve - a valve which is normally closed and which permits flow in one direction only.

1.6.17 Pressure vessel - a container constructed in accordance with Clause 2.2.1 or Clause 2.2.2 and used in the manner prescribed in this standard.