

Australian/New Zealand Standard™

**Electric cables—Polymeric insulated**

**Part 1: For working voltages 1.9/3.3  
(3.6) kV up to and including 19/33 (36)  
kV**



## **AS/NZS 1429.1:2006**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-003, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 3 April 2006 and on behalf of the Council of Standards New Zealand on 31 March 2006.

This Standard was published on 21 April 2006.

---

The following are represented on Committee EL-003:

Australasian Railway Association  
Australian Electrical and Electronic Manufacturers Association  
Australian Industry Group  
Canterbury Manufacturers Association New Zealand  
Department of Primary Industries, Mine Safety (NSW)  
Electrical Contractors Association of New Zealand  
Electrical Regulatory Authorities Council  
Energy Networks Association  
Engineers Australia  
Ministry of Economic Development (New Zealand)

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

---

*This Standard was issued in draft form for comment as DR 05363.*

---

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

---

**RECONFIRMATION**

**OF**

**AS/NZS 1429.1:2006**

**Electric cables—Polymeric insulated**

**Part 1: For working voltages 1.9/3.3 (3.6) kV up to and including 19/33 (36) kV**

---

**RECONFIRMATION NOTICE**

Technical Committee EL-003 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 10 October 2016.

Approved for reconfirmation in New Zealand on behalf of the Standards Council of New Zealand on 13 December 2016.

The following are represented on Technical Committee EL-003:

Australian Cable Makers' Association  
Australian Industry Group  
Electrical Compliance Testing Association  
Electrical Regulatory Authorities Council  
National Electrical and Communications Association  
Queensland University of Technology

## NOTES

**Australian/New Zealand Standard™**

**Electric cables—Polymeric insulated**

**Part 1: For working voltages 1.9/3.3  
(3.6) kV up to and including 19/33 (36)  
kV**

Originated as AS 1429—1979.  
Jointly revised and designated AS/NZS 1429.1:2000.  
Third edition 2006.

**COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 7385 0

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-003, Electric Wires and Cables, to supersede AS/NZS 1429.1:2000.

This Standard differs from the previous edition in the following significant ways:

- (a) The range of conductor sizes has been expanded to 1 600 mm<sup>2</sup>.
- (b) The method of specifying the thickness of insulation, separation sheath, metal sheath and oversheath has been aligned with IEC 60502-2.
- (c) MDPE has replaced PE as an optional oversheathing material.
- (d) Cables with collectively screened constructions are no longer specified.
- (e) The requirement for a qualification test report has been added.
- (f) The range of approval has been modified.
- (g) The recommended diameter of drum barrel and minimum installation bending radius has been extended to cover triplex cables.
- (h) The sample test requirement has become mandatory.

In the preparation of this Standard, consideration was given to the following publications and acknowledgment is made of the assistance received:

IEC 60502-2, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ( $U_m = 1,2$  kV) up to 30 kV ( $U_m = 36$  kV), Part 2: Cables for rated voltages from 6 kV ( $U_m = 7,2$  kV) up to 30 kV ( $U_m = 36$  kV)*

IEC 60811, *Common test methods for insulating and sheathing materials of electric cables and optical cables* (all Parts)

The nominal cross-sectional areas of the conductors specified herein are identical with the values specified in AS/NZS 1125, *Conductors in insulated electric cables and flexible cords*.

The dimensions for insulation and oversheath thicknesses are identical with the values recommended in IEC 60502. Certain tests and criteria in this Standard are more stringent than those in IEC 60502.

Two types of insulation compounds are specified in this Standard, namely insulation comprising cross-linked polyethylene (XLPE) and insulation comprising ethylene propylene rubber (EPR).

Although the Standard provides tables of insulation thicknesses and the necessary information to establish precisely the dimensions of the cable protective coverings, no cable dimension tables are provided owing to the variety of cable constructions that could possibly affect such dimensions.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

## CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE .....	4
1.2 REFERENCED DOCUMENTS .....	4
1.3 DEFINITIONS .....	5
1.4 VOLTAGE DESIGNATION .....	7
1.5 MAXIMUM CONDUCTOR TEMPERATURE .....	8
SECTION 2 CONSTRUCTION	
2.1 CONDUCTORS .....	9
2.2 CONDUCTOR SCREEN.....	9
2.3 INSULATION .....	9
2.4 INSULATION SCREEN .....	11
2.5 METALLIC SCREEN .....	12
2.6 IDENTIFICATION OF CORES .....	12
2.7 LAYING-UP .....	13
2.8 FILLERS, BINDERS, AND BARRIER TAPES.....	13
2.9 METAL SHEATH (OPTIONAL).....	13
2.10 SEPARATION SHEATH .....	14
2.11 BEDDING .....	15
2.12 ARMOUR (OPTIONAL).....	16
2.13 OVERSHEATH.....	17
2.14 WATER-BLOCKING (OPTIONAL) .....	18
2.15 PROTECTION FROM INSECT ATTACK (OPTIONAL) .....	18
2.16 CABLE IDENTIFICATION.....	19
2.17 METRE MARKING ON CABLE (OPTIONAL).....	19
2.18 PREPARATION FOR DELIVERY .....	19
2.19 MARKING OF DRUMS .....	19
SECTION 3 TESTS	
3.1 GENERAL .....	20
3.2 QUALIFICATION TEST REPORT .....	20
3.3 HIGH VOLTAGE TEST FOR 5 MIN .....	24
3.4 BENDING TEST FOLLOWED BY PARTIAL DISCHARGE TEST .....	24
3.5 MEASUREMENT OF DDF (TAN $\delta$ ) AS A FUNCTION OF VOLTAGE .....	25
3.6 MEASUREMENT OF DDF (TAN $\delta$ ) AT ELEVATED TEMPERATURE .....	25
3.7 HEAT CYCLING FOLLOWED BY PARTIAL DISCHARGE TEST.....	25
3.8 IMPULSE WITHSTAND TEST FOLLOWED BY A HIGH VOLTAGE TEST .....	25
3.9 HIGH VOLTAGE A.C. TEST FOR 4H.....	26
3.10 RE-QUALIFICATION TESTS.....	26
APPENDICES	
A THE FICTITIOUS CALCULATION METHOD FOR THE DETERMINATION OF THE DIMENSIONS OF PROTECTIVE COVERINGS .....	28
B PURCHASING GUIDELINES.....	31
C WATER PENETRATION TEST.....	32
D RECOMMENDED DIAMETER OF DRUM BARREL AND MINIMUM INSTALLATION BENDING RADIUS FOR CABLES .....	34
E SELECTION AND RETEST PROCEDURE FOR SAMPLE TESTS.....	36
F TESTS AFTER INSTALLATION.....	37
G ROUNDING OF NUMBERS .....	38

## STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

—————  
**Australian/New Zealand Standard**  
**Electric cables—Polymeric insulated**  
 —————

Part 1: For working voltages 1.9/3.3 (3.6) kV up to and including 19/33 (36)  
 kV  
 —————

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard specifies requirements for cross-linked polyethylene (XLPE) and ethylene propylene rubber (EPR) insulated cables for fixed installations for electricity supply at working voltages 1.9/3.3 (3.6) up to and including 19/33 (36) kV.

NOTE: Optional requirements for metal sheath, armour, water-blocking, protection from insect attack and metre marking on cable are provided in Clauses 2.9, 2.12, 2.14, 2.15 and 2.17 respectively.

**1.2 REFERENCED DOCUMENTS**

The following documents are referred to in this Standard:

## AS

1931 High-voltage test techniques (all Parts)

3983 Metal drums for insulated electric cables and bare conductors

## AS/NZS

1125 Conductors in insulated electric cables and flexible cords

1429 Electric cables—Polymeric insulated

1429.2 Part 2: For working voltages above 19/33 (36) kV up to and including  
 76/132 (145) kV

1660 Test methods for electric cables, cords and conductors

1660.1 Method 1: Conductors and metallic components

1660.2.1 Method 2.1: Insulation, extruded semi-conductive screens and non-metallic  
 sheaths—Methods for general application

1660.2.2 Method 2.2: Insulation, extruded semi-conductive screens and non-metallic  
 sheaths—Methods specific to elastomeric, XLPE and XLPVC  
 materials

1660.2.5 Method 2.5: Insulation, extruded semi-conductive screens and non-metallic  
 sheaths—Methods specific to cables above 1 kV

1660.3 Method 3: Electrical tests

2857 Timber drums for insulated electric cables and bare conductors

2893 Electric cables—Lead and lead alloy sheaths—Composition

3808 Insulating and sheathing materials for electric cables

3863 Galvanized mild steel wire for armouring cables