

Superseded by AS 1851.4-1992



**Standards
Association of
Australia**



Australian Standard® 1851.4—1988

**MAINTENANCE OF FIRE PROTECTION
EQUIPMENT**

**Part 4—FIRE HYDRANT
INSTALLATIONS**



This Australian Standard was prepared by Committee FP/9, Fire Hydrant Installations. It was approved on behalf of the Council of the Standards Association of Australia on 15 September 1987 and published on 4 January 1988.

The following interests are represented on Committee FP/9:

Australian Fire Protection Association
Australian Uniform Building Regulations Coordinating Council
Board of Fire Commissioners, New South Wales
Building Owners and Managers Association of Australia
Bush Fire Council of New South Wales
Commonwealth Fire Board
Confederation of Australian Industry
Department of Administrative Services
Department of Defence
Department of Transport and Communications
Fire Protection Industry Association of Australia
Institution of Engineers
Insurance Council of Australia
Melbourne and Metropolitan Board of Works
Metropolitan Fire Brigades Board, Melbourne
Water Board, Sydney
Western Australian Fire Brigades Board

Additional interests participating in preparation of Standard:

Australian Assembly of Fire Authorities

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 86132 (in part). ✓

AUSTRALIAN STANDARD

**MAINTENANCE OF FIRE PROTECTION
EQUIPMENT**

Part 4

**FIRE HYDRANT
INSTALLATIONS**

AS 1851.4—1988

First published as AS 1851.4—1980.
Second edition 1988.

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 4811 8



PREFACE

This Standard was prepared by the Association's Committee on Fire Hydrant Installations, to supersede AS 1851.4—1980.

For effective operation of fire hydrants in an emergency, it is essential that regular testing and maintenance be carried out on the fire hydrant installation. This Standard includes requirements for such regular testing and maintenance, and precautions to be taken when an installation is rendered inoperative.

The changes from the 1980 edition include a revision of the maintenance procedures for fire hydrant installations, and the addition of sample logbook record cards and a checklist summary of maintenance schedules.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	3
1.2 REFERENCED DOCUMENTS	3
1.3 DEFINITIONS	3
SECTION 2. BASIC REQUIREMENTS	
2.1 PERIODIC TESTING AND MAINTENANCE	4
2.2 RECORDS	4
2.3 HYDRANT IDENTIFICATION	4
SECTION 3. MAINTENANCE OF HYDRANT INSTALLATIONS	
3.1 CLASSIFICATION OF MAINTENANCE LEVELS	5
3.2 PRECAUTIONS TO BE TAKEN WHEN AN INSTALLATION IS TO BE RENDERED INOPERATIVE	5
3.3 CURTAILMENT OF WATER SUPPLY	5
3.4 MAINTENANCE SCHEDULES	5
APPENDICES	
A LOGBOOK REPORTS	7
B SUMMARY OF MAINTENANCE SCHEDULES	9

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1988

Users of Standards are reminded that copyright subsists in all SAA publications. Except where the Copyright Act otherwise allows, no part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia. Requests for permission should be directed to the Head Office of the Association. Where such requests relate to the reproduction of the whole or a substantial part of any Standard, permission may be conditional on an appropriate royalty payment.

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

MAINTENANCE OF FIRE PROTECTION EQUIPMENT

PART 4—FIRE HYDRANT INSTALLATIONS

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out requirements for the maintenance of fire hydrant installations and associated equipment, including regular inspections and precautions to be taken when the installation is rendered inoperative.

NOTE: The procedures set out in this Standard should be carried out or supervised by a person accepted as being qualified for this class of work by the Regulatory Authority.

1.2 REFERENCED DOCUMENTS. The following

Standards are referred to in this Standard:

- AS 2419 Installation of Fire Hydrants.
- AS 2484.2 Fire—Glossary of Terms
Part 2: Fire Protection and Firefighting
Equipment.
- AS 2700 Colour Standards for General Purposes.

1.3 DEFINITIONS. For the purpose of this Standard, the definitions given in AS 2484.2 apply.