

Australian Standard™

**Concrete structures for retaining
liquids—Commentary**

(Supplement to AS 3735—2001)



S t a n d a r d s Australia

This Australian Standard was prepared by Committee CE-022, Concrete Structures for Retaining Liquids. It was approved on behalf of the Council of Standards Australia on 17 November 2000 and published on 13 March 2001.

The following interests are represented on Committee CE-022:

Australian Pre-mixed Concrete Association
Institution of Engineers Australia
University of Queensland
Water Services Association of Australia

Additional interests participating in the preparation of this Standard:

Association of Consulting Engineers Australia
Australian Chamber of Commerce and Industry
Australian Post Tensioning Association
Australian Water and Wastewater Association
Brisbane City Council
Department of Public Works and Services, N.S.W.
Melbourne Water
National Precast Concrete Association Australia
NSW Department of Land and Water Conservation
Swimming Pool and Spa Association of NSW
Sydney Water Corporation
University of New South Wales
Water Corporation Western Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

**Concrete structures for retaining
liquids—Commentary**

(Supplement to AS 3735—2001)

Originated as AS 3735 Supp1—1991.
Second edition 2001.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 3715 3

PREFACE

This Supplement was prepared by the Standards Australia Committee CE-022, Concrete Structures for Retaining Liquids, to supersede AS 3735 Suppl—1991.

This Commentary provides background information to AS 3735—2001, and is intended to be used in conjunction with that document. It is not intended to be used as a Standard, or other reference document.

The paragraph numbers of this Commentary are prefixed with the letter C and refer directly to the respective Clause numbers of AS 3735, e.g. Paragraph C5.3.1 refers to Clause 5.3.1. Where there is no commentary to a clause of the Standard, the paragraph number does not appear. Figures and tables are designated C2.2, C3.1, etc., and do not correspond to those in the Standard.

References are listed as the last paragraph of the Section in which they occur.

CONTENTS

	<i>Page</i>
SECTION C1 SCOPE AND GENERAL	
C1.1 SCOPE.....	4
C1.5 USE OF ALTERNATIVE MATERIALS OR METHODS	4
C1.6 DRAWINGS AND SPECIFICATIONS.....	4
SECTION C2 LOADS, LOAD COMBINATIONS FOR STABILITY, STRENGTH AND SERVICEABILITY	
C2.1 GENERAL.....	6
C2.2 LOADS AND OTHER ACTIONS.....	6
C2.3 STABILITY DESIGN	11
C2.4 LOAD COMBINATIONS FOR SERVICEABILITY	11
SECTION C3 DESIGN FOR SERVICEABILITY AND STRENGTH	
C3.1 GENERAL.....	13
C3.2 REINFORCED CONCRETE.....	13
C3.3 PRESTRESSED CONCRETE	18
SECTION C4 DESIGN FOR DURABILITY	
C4.1 GENERAL.....	22
C4.2 EXPOSURE CLASSIFICATION	23
C4.3 REQUIREMENTS FOR CONCRETE.....	31
C4.4 REQUIREMENTS FOR COVER TO REINFORCING STEEL AND TENDONS	33
C4.6 DURABILITY OF WATERSTOPS AND SEALANTS	35
SECTION C5 MATERIALS AND CONSTRUCTION REQUIREMENTS	
C5.2 CONCRETE	37
C5.3 REINFORCEMENT	37
SECTION C6 JOINTS, WATERSTOPS, AND SEALANTS	
C6.1 JOINTS.....	39
C6.2 WATERSTOPS	45
C6.3 JOINT FILLERS.....	46
C6.4 SEALANTS.....	46
C6.5 CONTAMINATION OF WATER	48
SECTION C7 TESTING	
7.1 GENERAL.....	49
APPENDIX A CYLINDRICAL TANK THERMAL STRESSES.....	50

STANDARDS AUSTRALIA

Australian Standard

**Concrete structures for retaining liquids—Commentary
(Supplement to AS 3735—2001)**

SECTION C 1 SCOPE AND GENERAL

C1.1 SCOPE

A lower concrete strength limit of 20 MPa has been imposed, as strength grades less than this are not considered suitable for structures.

An upper concrete strength limit of 50 MPa has been adopted, because much of the research on which the Standard is based involved concrete strengths at or below this value. Nevertheless, higher strength concretes are being used in Australia and overseas (Refs 1 and 2). The Standard may be applied to such concretes, provided that the physical properties appropriate to them are used in design.

The Standard also limits the use of lightweight aggregate in structural concrete. Most Australian structural concretes employ only lightweight coarse aggregate, resulting in concrete with a surface-dry density that is seldom less than 1800 kg/m³.

In the preparation of a Standard such as this, a certain level of knowledge and competence of the majority of users has been assumed. As indicated by the Note to Clause 1.1, it was assumed that the predominant users of this Standard would be professionally qualified civil engineers experienced in the design of concrete structures for retaining liquids, or equally qualified but less experienced persons working under their guidance. It is therefore intended that the Standard be applied and interpreted primarily by such persons.

C1.5 USE OF ALTERNATIVE MATERIALS OR METHODS

The designer is usually required to seek approval from the appropriate Authority for the use of alternative materials or methods and such approval would not mean a relaxation of the requirements of the Standard, e.g. the use of fibre impregnated concrete would not mean an automatic relaxation of the requirements for conventional reinforcement or tendons.

C1.5.3 Ferrocement

Ferrocement should comply with the following:

- (a) Sand/cement ratio, by volume, of not more than 3:1.
- (b) For galvanized and epoxy coated steel reinforcement, the minimum cover given in Table 4.3 may be reduced by 15 mm, provided no negative tolerance is permitted and the surface is hand trowelled.

C1.6 DRAWINGS AND SPECIFICATIONS

The information applicable to most concrete members may be shown on only one of the drawings, usually the first sheet.