

Australian/New Zealand Standard™

**Auxiliaries for lamps—Capacitors for
use in tubular fluorescent and other
discharge lamp circuits—Performance
requirements**

AS/NZS 61049:2002

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-041, Lamps and related equipment. It was approved on behalf of the Council of Standards Australia on 30 July 2002 and on behalf of the Council of Standards New Zealand on 24 July 2002. It was published on 27 August 2002.

The following are represented on Committee EL-041:

Association of Consulting Engineers, Australia
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Consumer Federation of Australia
Electrical Compliance Testing Association of Australia
Energy Efficiency and Conservation Authority of New Zealand
Illuminating Engineering Society of Australia and New Zealand
Ministry of Economic Development, New Zealand
Electrical Regulatory authorities council (Australia)
International Accreditation of NZ (IANZ)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

RECONFIRMATION

OF

AS/NZS 61049:2002

**Auxiliaries for lamps—Capacitors for use in tubular fluorescent and other
discharge lamp circuits—Performance requirements**

RECONFIRMATION NOTICE

Technical Committee EL-041 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 22 July 2015.

Approved for reconfirmation in New Zealand on behalf of the Standards Council of New Zealand on 4 November 2016.

The following are represented on Technical Committee EL-041:

Australasian Fire and Emergency Service Authorities Council
Australian Industry Group
Consumers Federation of Australia
Department of Resources, Energy and Tourism
ECANZ
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
Energy Efficiency & Conservation Authority of New Zealand
Fair Trading NSW
IES: The Lighting Society
Independent Pricing and Regulatory Tribunal
Institution of Professional Engineers New Zealand
Joint Accreditation System of Australia and New Zealand
Lighting Council Australia
Lighting Council New Zealand
Master Electricians Australia
Ministry of Business, Innovation and Employment (NZ)

NOTES

Australian/New Zealand Standard™

Auxiliaries for lamps—Capacitors for use in tubular fluorescent and other discharge lamp circuits—Performance requirements

Originated as AS 2644—1983.
Previous edition AS 2644—1990.
Jointly revised and redesignated in part as AS/NZS 61049:2002.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 4771 X

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-041, Lamps and related equipment.

In Australia, this Standard will supersede AS 2644—1990, *Capacitors for use in discharge lamp circuits*. AS 2644—1990 will co-exist with AS/NZS 61049 until 31 December 2002 on which date AS 2644 will be withdrawn.

The objective of this Standard is to specify performance requirements for continuous rated capacitors up to 2.5 kVAR intended for use in discharge lamp circuits up to 1000 V operating at 50/60 Hz.

This Standard is identical with and has been reproduced from IEC 61049:1991, *Auxiliaries for lamps—Capacitors for use in tubular fluorescent and other discharge lamp circuits—Performance requirements* including Corrigendum 1:1992.

A reference to an International Standard identified in the Normative References Clause by strikethrough (~~example~~) is replaced by a reference to the Australian or Australian/New Zealand Standard(s) listed immediately thereafter and identified by shading (example). Where the struck-through referenced document and the referenced Australian or Australian/New Zealand Standard are identical, this is indicated in parenthesis after the title of the latter.

In this Standard, the following print types are used:

- requirements proper: in arial type;
- *test specifications: in italic type;*
- explanatory matter: in smaller arial type.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this international standard’ should read ‘this Australian/New Zealand Standard’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The term ‘normative’ has been used in this Standard to define the application of the annex to which it applies. A ‘normative’ annex is an integral part of a Standard.

CONTENTS

	<i>Page</i>
1 General	1
1.1 Scope	1
1.2 Normative references	1
2 Definitions	2
3 General notes on tests.....	2
4 Testing sequence	3
5 Marking	3
6 Capacitance.....	3
7 Change of capacitance with temperature	4
8 Endurance test	4
Annexes	
A Conformity of production (normative).....	8
B Test voltage (normative).....	9

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard

Auxiliaries for lamps—Capacitors for use in tubular fluorescent and other discharge lamp circuits—Performance requirements**1 General****1.1 Scope**

This International Standard states the requirements for both self-healing and non-self-healing continuously rated a.c. capacitors of up to and including 2,5 kvar, and not less than 0,1 μF , having a rated voltage not exceeding 1 000 V, which are intended for use in discharge lamp circuits operating at 50 Hz or 60 Hz and at altitudes up to 3 000 m.

It covers capacitors intended for connection in shunt or in series with the lamp circuit or an effective combination of these.

It covers only impregnated or unimpregnated capacitors, having a dielectric of paper, plastic film or a combination of both, either metallized or with metal foil electrodes.

This standard does not cover radio-interference suppressor capacitors the requirements for which are found in IEC 60384-14.

Tests in this standard are type tests. Guidance on conformity of production is given in annex A.

1.2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

References to International Standards that are struck through in this Clause are replaced by references to equivalent Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is appropriately identified.

IEC 60068-2-14: 1984, *Environmental testing - Part 2: Tests. Test N: Change of temperature*. Amendment No. 1 (1986).

*These lamps and associated ballasts are covered in the specifications of the following IEC publications:

60081: 1984, *Tubular fluorescent lamps for general lighting service. Amendment No. 1 (1987)*.

Amendment No. 2 (1988).

60188: 1974, *High-pressure mercury vapour lamps*. Amendment No. 1 (1976). Amendment No. 2 (1979). Amendment No. 3 (1984). Amendment No. 4 (1988).

60192: 1973, *Low-pressure sodium vapour lamps*. Amendment No. 2 (1988).

60921: 1988, *Ballasts for tubular fluorescent lamps*. Performance requirements.

60923: 1988, *Ballasts for discharge lamps (excluding tubular fluorescent lamps)*. Performance requirements.