

Australian/New Zealand Standard™

**Mineral insulated cables and their  
terminations with a rated voltage not  
exceeding 750 V**

**Part 1: Cables**



## **AS/NZS 60702.1:2005**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-003, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 28 October 2005 and on behalf of the Council of Standards New Zealand on 4 November 2005.

This Standard was published on 16 November 2005.

---

The following are represented on Committee EL-003:

Australasian Railway Association  
Australian Electrical and Electronic Manufacturers Association  
Australian Industry Group  
Canterbury Manufacturers Association New Zealand  
Department of Defence (Australia)  
Department of Primary Industries, Mine Safety (NSW)  
Electrical Contractors Association of New Zealand  
Electrical Regulatory Authorities Council  
Energy Networks Association  
Engineers Australia  
Ministry of Economic Development (New Zealand)

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

---

*This Standard was issued in draft form for comment as DR 05340.*

---

# Australian/New Zealand Standard™

## **Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V**

### **Part 1: Cables**

Originated in Australia as AS C351.1—1963.  
Previous edition AS/NZS 3187:1995.  
Jointly revised and redesignated as AS/NZS 60702.1:2005.

#### **COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 6999 3

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-003, Electric Wires and Cables to supersede AS/NZS 3187:1995, *Approval and test specification—Mineral-insulated metal-sheathed cables*.

The objective of this Standard is to specify the construction dimensions and tests for mineral-insulated metal-sheathed cables with rated voltages of 500 V and 750 V.

This Standard is identical with, and has been reproduced from IEC 60702-1, Ed. 3 (2002), *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V, Part 1: Cables*.

Variations to IEC 60702-1, Ed. 3 (2002) are indicated at the appropriate places throughout this standard. Strikethrough (~~example~~) identifies IEC text, tables and figures which, for the purposes of this Australian/New Zealand Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text IEC 60702-1 should read AS/NZS 60702.1.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

## CONTENTS

	<i>Page</i>
1 Scope .....	1
2 Normative references .....	1
3 Definitions .....	2
4 Voltage designations .....	2
4.1 500 V cable (light duty grade) .....	3
4.2 750 V cable (heavy duty grade) .....	3
5 Conductors .....	3
6 Insulation .....	3
6.1 Composition .....	3
6.2 Thickness .....	3
7 Metallic sheath .....	3
7.1 Material .....	3
7.2 Sheath thickness .....	3
7.3 Sheath diameter and ovality .....	3
8 Optional outer covering .....	4
8.1 General .....	4
8.2 Material .....	4
8.2.1 Low temperature impact .....	4
8.2.2 Heat shock test .....	4
8.3 Halogen-free covering .....	4
8.4 Thickness of covering .....	4
9 Marking .....	4
10 General notes on tests .....	5
11 Routine tests .....	5
11.1 General .....	5
11.2 Conductor resistance .....	5
11.3 Insulation resistance .....	6
11.4 Integrity of insulation and copper sheath .....	6
11.5 Spark test on outer covering .....	6
11.6 Diameter and ovality over copper sheath .....	7
12 Sample tests .....	7
12.1 General .....	7
12.2 Voltage test .....	7
12.3 Thickness of outer covering .....	8
12.4 Flame retardance .....	8
12.5 Emission of acidic and corrosive gases .....	8
12.6 Smoke emission .....	8
13 Type tests .....	9
13.1 General .....	9
13.2 Voltage test on completed cable .....	9
13.3 Resistance of copper sheath .....	9
13.4 Thickness of insulation .....	10
13.5 Thickness of copper sheath .....	10

13.6	Bending test.....	10
13.7	Flattening test.....	14
13.8	Fire resistance.....	15
14	500 V mineral insulated cable (light duty grade).....	15
14.1	Code designation.....	15
14.2	Rated voltage.....	15
14.3	Construction.....	15
14.4	Dimensions.....	15
14.5	Requirements.....	16
15	750 V mineral insulated cable (heavy duty grade).....	16
15.1	Code designation.....	16
15.2	Rated voltage.....	17
15.3	Construction.....	17
15.4	Dimensions.....	17
15.5	Requirements.....	19

## STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

---

**Australian/New Zealand Standard****Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V**  
**Part 1: Cables**

---

**1 Scope**

This standard applies to mineral insulated general wiring cables with copper or copper alloy sheath and copper conductors and with rated voltages of 500 V and 750 V. Provision is made for a corrosion-resistant extruded outer covering over the copper sheath, when required. This outer covering is not specified for the purpose of electrical insulation of the metal sheath.

Requirements for terminations for use with these cables are specified in IEC 60702-2.

The purpose of this standard is to specify mineral insulated cables that are safe and reliable when properly used, to state the manufacturing requirements and characteristics to achieve this, and to specify methods for checking conformity with those requirements.

**2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is identified as such.

IEC 60227-1:1993, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60228:1978, *Conductors of insulated cables*

~~IEC 60331-21:1999, Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – Cables of rated voltage up to and including 0,6/1,0 kV~~

AS/NZS 1660.5.5, Test methods for electric cables, cords and conductors, Method 5.5: Fire tests—Circuit integrity

~~IEC 60332-1:1993, Tests on electric cables under fire conditions – Part 1: Test on a single vertical insulated wire or cable~~

AS/NZS 1660.5.6, Test methods for electric cables, cords and conductors, Method 5.6: Fire tests—Test for vertical flame propagation for a single insulated wire or cable

~~IEC 60702-2:2002, Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V – Part 2: Terminations~~