

Australian Standard[®]

Uninterruptible power systems (UPS)

**Part 2: Electromagnetic compatibility
(EMC) requirements**



This Australian Standard® was prepared by Committee EL-027, Power Electronics. It was approved on behalf of the Council of Standards Australia on 26 February 2008. This Standard was published on 19 March 2008.

The following are represented on Committee EL-027:

- Australian Communications and Media Authority
 - Australian Electrical and Electronic Manufacturers Association
 - Bureau of Steel Manufacturers of Australia
 - Energy Networks Association
 - Monash University
-

This Standard was issued in draft form for comment as DR 07442.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting **www.standards.org.au**

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at **mail@standards.org.au**, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Uninterruptible power systems (UPS)

Part 2: Electromagnetic compatibility (EMC) requirements

Originated as AS 62040.2—2001.
Second edition 2008.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 8591 3

PREFACE

This Standard was prepared by the Standards Australia Committee EL-027, Power Electronics, to supersede AS 62040.2—2001.

The objective of this Standard is to provide manufacturers, users and regulators with requirements for electromagnetic compatibility (EMC) for uninterruptible power systems (UPS).

This Standard is identical with, and has been reproduced from IEC 62040-2, Ed. 2.0 (2005), *Uninterruptible power systems (UPS)—Part 2: Electromagnetic compatibility (EMC) requirements*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 62040’ should read ‘this part of AS 62040’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 Scope	1
2 Normative references	2
3 Terms and definitions	3
4 Environment	3
5 UPS Categories	4
5.1 UPS of category C1	4
5.2 UPS of category C2	4
5.3 UPS of category C3	4
5.4 UPS of category C4	4
5.5 Categories and environment	4
6 Emission	5
6.1 General	5
6.2 General requirements	5
6.3 General measurement conditions	5
6.4 Conducted emissions	6
6.5 Radiated emissions	8
7 Immunity	8
7.1 General	8
7.2 General requirements and performance criteria	9
7.3 Basic immunity requirements – High-frequency disturbances	9
7.4 Immunity to low-frequency signals	11
7.5 Immunity to power-frequency magnetic field	12
7.6 Immunity to voltage dips, short interruptions and voltage variations	12
Annex A (normative) Electromagnetic emission – Test methods	13
Annex B (informative) Electromagnetic emission limits and measurement methods of magnetic field – H field	27
Annex C (informative) Electromagnetic emission – Limits of signal ports	29
Annex D (normative) Electromagnetic immunity – Test methods	30
Annex E (informative) User installation testing	33
Figure 1 – Examples of ports	3
Figure A.1 – Circuit for disturbance voltage measurements on mains supply or UPS output	20
Figure A.2 – Minimum alternative test site	20
Figure A.3 – Set-up for measurement of conducted emission for table-top units	21
Figure A.4 – Test set-up for floor-standing units	21
Figure A.5 – Test configuration for table-top equipment (conducted emission measurement)	22
Figure A.6 – Test configuration for table-top equipment (conducted emission measurement) – Plan view	23
Figure A.7 – Alternative test configuration for table-top equipment (conducted emission measurement) – Plan view	23

Figure A.8 – Test configuration for floor-standing equipment (conducted emission measurement)	24
Figure A.9 – Test configuration for table-top equipment (radiated emission requirement).....	25
Figure A.10 – Test configuration for floor-standing equipment (radiated emission measurement)	26
Figure B.1 – Test set-up for measuring radiated disturbances	27
Figure D.1 – Amplitude unbalance.....	31
Figure D.2 – Phase unbalance	32
Table 1 – Limits of mains terminal interference voltage frequency range 0,15 MHz to 30 MHz for category C1 UPS and category C2 UPS equipment	6
Table 2 – Limits of mains terminal interference voltage frequency range 0,15 MHz to 30 MHz for Category C3 UPS equipment.....	7
Table 3 – Limits of radiated emission in the frequency range 30 MHz to 1 000 MHz	8
Table 4 – Performance criteria for immunity tests	9
Table 5 – Minimum immunity requirements for UPS intended for UPS of category C1.....	10
Table 6 – Minimum immunity requirements for UPS of category C2 and C3.....	11
Table B.1 – UPS which has a rated output current less than, or equal to, 16 A	28
Table B.2 – UPS which has a rated output current greater than 16A.....	28
Table C.1 – Limits of signal ports	29

STANDARDS AUSTRALIA

Australian Standard**Uninterruptible power systems (UPS)
Part 2: Electromagnetic compatibility (EMC) requirements**

1 Scope

This part of IEC 62040 applies to UPS units intended to be installed

- as a unit or in UPS systems comprising a number of interconnected UPS and associated control/switchgear forming a single power system; and
- in any operator accessible area or in separated electrical locations, connected to low-voltage supply networks for either industrial or residential, commercial and light industrial environments.

This part of IEC 62040 is intended as a product standard allowing the EMC conformity assessment of products of categories C1, C2 and C3 as defined in this part of IEC 62040, before placing them on the market.

Equipment of category 4 is treated as a fixed installation. Checking is generally done after installation in its final place of use. Sometimes partial checking may be done before. See Annex E.

The requirements have been selected so as to ensure an adequate level of electromagnetic compatibility (EMC) for UPS at public and industrial locations. These levels cannot, however, cover extreme cases, which may occur in any location but with extremely low probability of occurrence.

This part of IEC 62040 takes into account the differing test conditions necessary to encompass the range of physical sizes and power ratings of UPS.

A UPS unit or system shall meet the relevant requirements of this part of IEC 62040 as a stand-alone product. EMC phenomena produced by any customers' load connected to the output of the UPS equipment shall not be taken into account.

Special installation environments are not covered, nor are fault conditions of UPS taken into account.

This part of IEC 62040 does not cover d.c. supplied electronic ballast or UPS based on rotating machines.

This part of IEC 62040 states:

- EMC requirements;
- test methods;
- minimum performance levels.