

Australian/New Zealand Standard™

A1 | **Safety of transformers, reactors, power supply units and combinations thereof**

Part 2.23: Particular requirements and tests for transformers and power supply units for construction sites



AS/NZS 61558.2.23:2011

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-002, Safety of Household and Similar Electrical Appliances and Small Power Transformers. It was approved on behalf of the Council of Standards Australia on 4 April 2011 and on behalf of the Council of Standards New Zealand on 21 April 2011.

This Standard was published on 29 April 2011.

The following are represented on Committee EL-002:

Australian Industry Group
Australian Retailers Association
Business New Zealand
Consumer Electronic Suppliers Association, Australia
Consumers' Federation of Australia
Electrical Regulatory Authorities, Australia
Electrical Compliance Testing Association
Electrical consultants
Engineers Australia
Energy Networks Australia
Ministry of Economic Development, New Zealand
New Zealand Electric Fence Energizer Manufacturers' Standards Group

A1 |

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 10921.

Australian/New Zealand Standard™

A1

Safety of transformers, reactors, power supply units and combinations thereof

Part 2.23: Particular requirements and tests for transformers and power supply units for construction sites

First edition AS/NZS 61558.2.23:2001.
Second edition AS/NZS 61558.2.23:2011.
Reissued incorporating Amendment No. 1 (June 2012).

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

AS/NZS 61558.2.23:2011

Safety of transformers, reactors, power supply units and combinations thereof –
Part 2.23: Particular requirements and tests for transformers and power supply units
for construction sites

Foreword

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-002 - Safety of Household and Similar Electrical Appliances and Small Power Transformers to supersede AS/NZS 61558.2.23:2001 and its amendments three years from the date of its publication. During this period it is anticipated that regulatory authorities will approve transformers and power supply units for construction sites to either standard.

The objective of this Standard is to provide manufacturers, designers, regulatory authorities, testing laboratories and similar organizations with safety requirements for the design, manufacture and testing of transformers and power supply units for construction sites which can form the basis for approval by regulatory authorities.

The text IEC 61558-2-23 Ed 2, prepared by IEC Technical Committee 96, was submitted to the Standards Australia/Standards New Zealand Combined Procedure (dual public comment and committee vote) for adoption of the IEC standard as a Standards Australia/Standards New Zealand joint standard.

This Standard incorporates Amendment No. 1 (June 2012). The changes required by the amendments are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected. Where an application date other than immediate is applicable to an amendment the date of application (DOA) and the date of withdrawal (DOW) if relevant, is indicated by the marginal bar against the part affected.

This Standard is an adoption with national modifications of the second edition of IEC 61558-2-23, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-23: Particular requirements and tests for transformers and power supply units for construction sites*. It has been varied as indicated to take account of Australian and New Zealand conditions.

This part 2 has to be used in conjunction with the latest edition of AS/NZS 61558.1 *Safety of Power Transformers, Power Supplies, Reactors and Similar Products – Part 1: General requirements and tests* and its amendments. It was established on the basis of the 2008 edition of that standard. Amendments and revisions of Part 1 have also to be taken into account and the dates when such changes become applicable will be stated in the relevant amendment or revision of Part 1.

The main changes consist of updating this part in accordance with AS/NZS 61558.1:2008.

This part 2 supplements or modifies the corresponding clauses of AS/NZS 61558.1 so as to convert it into the Australian/New Zealand Standard: *Safety requirements and tests for transformers and power supply units for construction sites*.

When a particular subclause of Part 1 is not mentioned in this part 2, that subclause applies as far as is reasonable. When this standard states "addition", "modification" or "replacement", the relevant text of Part 1 is to be adapted accordingly.

NOTE 1 The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1;
- unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.;
- subclauses, notes and annexes that are additional to those in the IEC standard are prefixed with the letters AZ.

NOTE 2 The following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- notes: in small roman type.

Words in **bold** in the text are defined in Clause 3.

p NOTE 3 In this document, p is used in the margin to indicate instructions for preparing a consolidated version.

A1 | The essential safety requirements in AS/NZS 3820¹ that could be applicable to requirements and tests for transformers and power supply units for construction sites are covered by this standard.

The national variations to the IEC 61558-2-23 Ed 2 form the Australian and New Zealand national variations for purposes of the IECEE scheme for recognition of results of testing to standards for safety of electrical equipment (the CB scheme).

There are no national variations from the IEC Standard from which this standard is adopted, other than those listed in Annex ZZ to AS/NZS 61558.1.

¹ AS/NZS 3820 *Essential safety requirements for electrical equipment*

CONTENTS

FOREWORD.....	3
1 Scope	5
2 Normative references	6
3 Terms and definitions	6
4 General requirements	6
5 General notes on tests.....	6
6 Ratings	6
7 Classification.....	7
8 Marking and other information.....	7
9 Protection against electric shock.....	9
10 Change of input voltage setting.....	9
11 Output voltage and output current under load	9
12 No-load output voltage.....	9
13 Short-circuit voltage.....	10
14 Heating	10
15 Short-circuit and overload protection	10
16 Mechanical strength	10
17 Protection against harmful ingress of dust, solid objects and moisture	12
18 Insulation resistance, dielectric strength and leakage current	12
19 Construction.....	12
20 Components	14
21 Internal wiring.....	14
22 Supply connection and other external flexible cable or cords	14
23 Terminals for external conductors	14
24 Provisions for protective earthing	14
25 Screws and connections	14
26 Creepage distances, clearances and distances through insulation	15
27 Resistance to heat, fire and tracking	15
28 Resistance to rusting	15
Annexes	17
Annex L Routine tests (production tests)	17
Bibliography	18
Figure 101 – Impact test for horizontal surface	16
Figure 102 – Impact test for vertical surface	16
Table 101 – Ratio of output voltages for safety isolating transformers	10
Table 102 – Ratio of output voltages for isolating transformers	10

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-23: Particular requirements and tests for transformers and power supply units for construction sites

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61558-2-23 has been prepared by IEC Technical Committee 96: Transformers, reactors, power supply units, and combinations thereof.

This second edition cancels and replaces the first edition published in 2000. It constitutes a technical revision. The main changes consist of updating this Part 2-23 in accordance with IEC 61558-1:2005.

This part has the status of a group safety publication in accordance with IEC Guide 104: *The preparation of safety publications and the use of basic safety publications and group safety publications*.

The text of this standard is based on the following documents:

FDIS	Report on voting
96/359/FDIS	96/368/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part is intended to be used in conjunction with the latest edition of IEC 61558-1 and its amendments. It is based on the second edition (2005) of that standard.

This part supplements or modifies the corresponding clauses in IEC 61558-1, so as to convert that publication into the IEC standard: *Particular requirements and tests for transformers and power supply units for construction sites*.

A list of all parts of the IEC 61558 series, under the general title: *Safety of transformers, reactors, power supply units and combinations thereof*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where a particular subclause of Part 1 is not mentioned in this part, that subclause applies as far as is reasonable. Where this part states "addition", "modification" or "replacement", the relevant text of Part 1 is to be adapted accordingly.

In this part, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.

In the text of this part, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in Part 1 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 12 months from the date of publication.

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-23: Particular requirements and tests for transformers and power supply units for construction sites

1 Scope

Replacement:

This part of IEC 61558 deals with the safety of **transformers for construction sites** and **power supply units** incorporating **transformers for construction sites**. Transformers incorporating **electronic circuits** are also covered by this standard.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** covers **transformers for construction sites** and **power supply units** incorporating **transformers for construction sites**.

This part is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) **independent** or **associated transformers, being isolating** or **safety isolating dry-type transformers** for the use on **construction sites**. The windings may be encapsulated or non-encapsulated.

The **rated supply voltage** does not exceed 1 000 V a.c., and the **rated supply frequency** and the **internal operating frequencies** do not exceed 500 Hz.

This standard used in combination with Part 2-16 for **Switch mode power supply units (SMPS)** is also applicable to **power supplies** with **internal operating frequencies** higher than 500 Hz. Where the two requirements are in conflict the most severe take precedence

The **rated output** does not exceed:

- 25 kVA for single-phase **transformers**;
- 40 kVA for poly-phase **transformers**.

This part is applicable to **transformers** without limitation of the **rated output** subject to an agreement between the purchaser and the manufacturer.

NOTE 2 **Transformers** intended to supply distribution networks are not included in the scope.

Isolating transformers and **power supply units** incorporating **isolating transformers for construction sites** have a **no-load output voltage** and a **rated output voltage** exceeding 50 V a.c. and not exceeding 250 V a.c.

Safety isolating transformers and **power supply units** incorporating **safety isolating transformers for construction sites** have a **no-load output voltage** and a **rated output voltage** not exceeding 50 V a.c.

NOTE 3 This standard is applicable to **transformers** for the supply of electricity in locations as specified in IEC 60364-7-704. The latter also specifies the protection by using an earthed midpoint or starpoint of the **output winding**.

Transformers and **power supply units** covered by this part are used in applications where it is required by the installation rules or by the appliance specification for protection purposes.

When the **transformers** or **power supply units** are incorporated into **low voltage switchgear and controlgear assemblies for construction sites** as specified in IEC 60439-4, the additional requirements of IEC 60439-4 will apply to the assembly.

NOTE 4 For **transformers** filled with liquid dielectric or pulverised material, such as sand, additional requirements are under consideration.

NOTE 5 Attention is drawn to the following:

- measures to protect the **enclosure** and the components inside the **enclosure** against external influences like fungus, vermin, termites, solar-radiation and icing should also be considered;
- the different conditions for transportation, storage, and operation of the **transformers** and **power supply units** should also be considered;