

Australian Standard™

Insulating liquids

Part 2: Test methods

Method 2.1: Determination of the breakdown voltage at power frequency

[IEC title: Insulating liquids—Determination of the breakdown voltage
at power frequency—Test method]

This Australian Standard was prepared by Committee EL/8, Power Transformers. It was approved on behalf of the Council of Standards Australia on 16 February 1999 and published on 5 May 1999.

The following interests are represented on Committee EL/8:

Australasian Railway Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Institute of Petroleum
Electricity Supply Association of Australia
Electricity Supply Engineers Association of New South Wales
Institution of Engineers Australia
Testing interests

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 97496.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

Australian Standard™

Insulating liquids

Part 2: Test methods **Method 2.1: Determination of the breakdown voltage at power frequency**

Originated as AS 1767.2.1—1999.

PREFACE

This Standard was prepared by the Standards Australia Committee EL/8, Power Transformers.

It is identical with and has been reproduced from IEC 60156:1995, *Insulating liquids—Determination of the breakdown voltage at power frequency—Test method*.

In January 1997, IEC commenced numbering its Standards from 60000 by adding 60000 to the number of each existing Standard. This coordinates IEC numbering with ISO numbering. During the transition period an IEC Standard might be identified by its new number or its old number (e.g. IEC 60050 or IEC 50).

This Standard is Part 2.1 of a series which comprises the following:

AS

- 1767 Insulating liquids
- 1767.1 Part 1: Specification for unused mineral insulating oils for transformers and switchgear
- 1767.2 Part 2: Test methods
- 1767.2.1 Method 2.1: Determination of the breakdown voltage at power frequency (this Standard)
- 1767.2.3 Method 2.3: Method of sampling liquid dielectrics
- 1767.2.4 Method 2.4: Detection and determination of specified anti-oxidant additives in insulating oils
- 1767.2.5 Method 2.5 Unused hydrocarbon-based insulating liquids—Test methods for evaluating the oxidation stability
- 1767.2.7 Method 2.7: Determination of PCB contamination in insulating liquids by capillary column gas chromatography—Identification of congeners

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title pages.
- (b) In the source text, ‘this International Standard’ should read ‘this Australian Standard’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian Standard</i>	
IEC		AS	
60052	Recommendations for voltage measurement by means of sphere-gaps (one sphere earthed)	2886	Voltage measurement—Sphere-gap method (one sphere earthed)
60060	High-voltage test techniques	1931	High-voltage test techniques
60475	Method of sampling liquid dielectrics	1767	Insulating liquids
		1767.2	Part 2: Test methods
		1767.2.4	Method 2.4: Detection and determination of specified anti-oxidant additives in insulating oils

CONTENTS

	<i>Page</i>
1 Scope	1
2 Normative references	1
3 Electrical apparatus	1
3.1 Voltage regulator	1
3.2 Step-up transformer	2
3.3 Current-limiting resistors	2
3.4 Switching system	2
3.5 Measuring device	3
4 Test assembly	3
4.1 Test cell	3
4.2 Electrodes	3
4.3 Stirring (optional)	4
5 Preparation of electrodes	4
6 Test assembly preparation	4
7 Sampling	5
7.1 Sample containers	5
7.2 Sampling technique	5
8 Condition of the sample	5
9 Test procedure	5
9.1 Sample preparation	5
9.2 Filling of the cell	6
9.3 Application of voltage	6
10 Report	6
11 Test data dispersion	6
Figures	7

AUSTRALIAN STANDARD

Insulating liquids

Part 2:

Test methods

Method 2.1: Determination of the breakdown voltage
at power frequency

TEST METHOD

1 Scope

This international Standard specifies the method for determining the dielectric breakdown voltage of insulating liquids at power frequency. The test portion, contained in a specified apparatus, is subjected to an increasing a.c. electrical field by means of a constant rate of voltage rise until breakdown occurs.

The method applies to all types of insulating liquids of nominal viscosity up to $350 \text{ mm}^2\text{s}^{-1}$ at $40 \text{ }^\circ\text{C}$. It is appropriate both for acceptance testing on unused liquids at the time of their delivery and for establishing the condition of samples taken in monitoring and maintenance of equipment.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 52: 1960, *Recommendations for voltage measurement by means of sphere-gaps (one sphere earthed)*

IEC 60, *High-voltage test techniques*

IEC 475: 1974, *Method of sampling liquid dielectrics*

3 Electrical apparatus

The electrical apparatus consists of the following units:

- a) Voltage regulator
- b) Step-up transformer
- c) Switching system
- d) Energy limiting devices

Two or more of these units may be integrated in any equipment system.

3.1 Voltage regulator

Uniform increase of voltage with time by manual means is difficult and, for this reason, automatic control is essential.