

# Australian Standard 1300—1983

---

## ELECTRICAL EQUIPMENT FOR COAL MINES BOLTED FLAMEPROOF CABLE COUPLING DEVICES



**STANDARDS ASSOCIATION OF AUSTRALIA**  
*Incorporated by Royal Charter*



This Australian standard was prepared by Committee EL/23, Electrical Equipment in Coal Mines. It was approved on behalf of the Council of the Standards Association of Australia on 16 May 1983 and published on 4 July 1983.

---

The following interests are represented on Committee EL/23:

Association of Mining Electrical and Mechanical Engineers, Australia  
Australian Coal Association  
Australian Electrical and Electronic Manufacturers Association  
Confederation of Australian Industry  
Department of Industrial Relations, N.S.W.  
Department of Mines, Qld  
Elcom Collieries, N.S.W.  
Joint Coal Board  
Queensland Confederation of Industry  
State Energy Commission of Western Australia

---

To keep abreast of progress in industry, Australian standards are subject to continuous review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that their standards are up-to-date. Full details of all SAA publications will be found in the Annual List of Australian Standards; these details are supplemented by listings in the SAA monthly journal 'The Australian Standard'. Information on the Annual List and 'The Australian Standard' may be obtained from any sales office of the Association, where details are also available of the current status of individual standards. Suggestions for improvements to published standards, addressed to the head office of the Association, are welcomed.

**AUSTRALIAN STANDARD**

**ELECTRICAL EQUIPMENT  
FOR COAL MINES  
BOLTED FLAMEPROOF  
CABLE COUPLING DEVICES**

**AS 1300—1983**

First published .....	1973 ✓
Second edition .....	1983

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**



ISBN 0 7262 3029 4

## PREFACE

This edition of this standard was prepared by the Association's Committee on Electrical Equipment in Coal Mines to supersede AS 1300—1973. It is intended for the guidance of manufacturers, users, statutory authorities and associated interests and for use with SAA standards and relevant mining regulations.

The major changes in this edition are as follows:

- (a) The deletion of the requirement for polarizing.
- (b) The amendment of the requirements for earthing; it is now no longer required for an earthing facility to be provided on the face of the plug body—instead, a requirement has been included for an external earthing bond.
- (c) Rationalization of plug ratings and body sizes.
- (d) Amendments to test criteria.
- (e) Changes to terminology used.

## CONTENTS

	<i>Page</i>
<b>SECTION 1. SCOPE AND GENERAL</b>	
1.1 Scope .....	3
1.2 Application .....	3
1.3 Referenced Documents .....	3
1.4 Definitions .....	3
1.5 Service Conditions .....	4
1.6 Size Designations .....	4
1.7 Voltage and Current Ratings .....	4
1.8 Colour Coding .....	4
1.9 Dimensions .....	4
1.10 Marking .....	4
<b>SECTION 2. DESIGN AND CONSTRUCTION</b>	
2.1 Flameproof Enclosure .....	11
2.2 Clearance and Creepage .....	11
2.3 Construction .....	11
2.4 Fasteners .....	11
2.5 Cable Glands .....	11
2.6 Terminals .....	11
2.7 Contact Sockets and Pins .....	11
2.8 Insulation .....	11
2.9 Sealing .....	11
2.10 Compound Filling .....	12
<b>SECTION 3. TESTING</b>	
3.1 Routine Tests .....	13
3.2 Type Tests .....	13
<b>APPENDIX A. CABLE GLAND (SLIP LOAD) TEST</b> .....	<b>16</b>

©Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1983

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

## STANDARDS ASSOCIATION OF AUSTRALIA

## Australian Standard

for

## ELECTRICAL EQUIPMENT FOR COAL MINES—BOLTED FLAMEPROOF CABLE COUPLING DEVICES

## SECTION 1. SCOPE AND GENERAL

**1.1 SCOPE.** This standard specifies the dimensional and test requirements for bolted flameproof cable coupling devices of the multiple pin and contact-socket type with separate pins (hereinafter referred to as 'cable coupling devices') for use in coal mines, and including the adaptors for the devices. The devices are designed to enable two feeder cables to be coupled together, or to enable a cable to be coupled to equipment.

Cable coupling devices and adaptors to this standard are not intended to be coupled or uncoupled while the circuit is energized.

The standard prescribes the dimensions necessary to provide for the interconnection of cable coupling devices of different makes; it also deals with some electrical and mechanical requirements including the provision of earthed phase barriers for protection against interphase faults. It does not, however, purport to otherwise specify a fully detailed design.

Dimensions and requirements for an earthed pole-protective barrier are specified for an additional body size to provide for a d.c. cable coupling device and adaptor.

**1.2 APPLICATION.** Cable coupling devices and adaptors shall comply with the general requirements of this Section and with the relevant requirements of Section 2.

**1.3 REFERENCED DOCUMENTS.** The following standards are referred to in this standard:

AS 1147	Plastics Insulating Materials of Mouldings for Cable Connecting Devices for Use in Coal Mines
AS 1567	Wrought Copper and Copper Alloy Rods, Bars and Sections for General Engineering Purposes
AS 1593	Electrical Protection for Explosive Atmospheres—Increased Safety Apparatus—Type of Protection e
AS 1802	Trailing Cables for Mining Purposes (Including Underground Coal Mines, Metalliferous Mines, Open-cut Mines, Quarries and Dredges)
AS 1828	Cable Glands for Explosive Gas Atmospheres
AS 1856	Electroplated Coatings of Silver for Engineering Applications
AS 1972	Cables for Use Below Ground in Coal Mines (Other Than Trailing Cables)

AS 2480 Electrical Equipment for Explosive Atmospheres—Flameproof Enclosure—Type of Protection d

AS K185 Colours for Specific Purposes

**1.4 DEFINITIONS.** For the purpose of this standard the following definitions apply:

**1.4.1 Adaptor**—a device designed to connect a cable coupling device to apparatus in such a manner as will form a flameproof enclosure. It may be either attached to or integral with the apparatus.

**1.4.2 Authority**—the relevant Statutory Authority responsible for the implementation of Government regulations applying to coal mines in each of the States of Australia.

**1.4.3 Cable coupling device** (sometimes referred to as a 'flit plug')—a device consisting of a body and cable gland, together with means for connecting the cable conductors to insulated contact sockets within the body.

NOTE: The body is designed to receive the cable; to provide room to spread and connect the cores; to protect the cores; to allow for the attachment of the cable gland; and to provide for sealing the conductors and the insulating material of the cable.

**1.4.4 Cable gland**—a device to secure the end of a cable, by means appropriate to the type of cable, including provision for making electrical connections to the metallic armour of the cable, and to the metallic screen if present.

**1.4.5 End cover**—a metal cover, which when bolted to the coupling face of a cable coupling device or adaptor completes the flameproof enclosure of the cable coupling device or adaptor and enables full working voltages to be applied.

**1.4.6 Main contact pin**—a rigid conducting member for electrical power circuits intended to be inserted in a main contact socket of suitable form so as to make electrical contact.

**1.4.7 Main contact socket**—a resilient conducting member for electrical power circuits intended to receive a suitable main contact pin so as to make electrical contact.

**1.4.8 Phase barrier**—a metallic barrier which is electrically connected to earth, and is situated in the contact insulation in both the cable coupling device and adaptor for the purpose of preventing an interphase fault.

**1.4.9 Pilot contact pin**—a rigid conducting member for other than electrical power circuits