

Australian/New Zealand Standard™

**Electrical equipment for coal and shale
mines—Electrical protection devices**

**Part 4: Lockout earth-fault protection
devices**

AS/NZS 2081.4:2002

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-023, Electrical Equipment in Coal Mines. It was approved on behalf of the Council of Standards Australia on 16 July 2002 and on behalf of the Council of Standards New Zealand on 27 June 2002. It was published on 12 August 2002.

The following are represented on Committee EL-023:

Australian Chamber of Commerce and Industry
Australian Coal Association
Australian Electrical and Electronic Manufacturers Association
Australian Industry Group
Department of Mineral Resources N.S.W.
Department of Natural Resources and Mines (QLD)
Electrical Apparatus Service Association
Mining Electrical and Mining Mechanical Engineering Society
New Zealand Hazardous Areas Electrical Coordinating Committee
Regulatory authorities (electrical)
Regulatory interests, New Zealand
University of Newcastle
WorkCover New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Electrical equipment for coal and shale mines—Electrical protection devices

Part 4: Lockout earth-fault protection devices

Originated as part of AS C318—1958.
Previous edition AS 2081.4—1988.
Jointly revised and designated AS/NZS 2081.4:2002.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 4750 7

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-023, Electrical Equipment in Coal Mines, to supersede AS 2081.4—1988, *Electrical equipment for coal and shale mines—Electrical protection devices, Part 4: Lockout earth-fault protection devices*.

The AS/NZS 2081 series comprises the following parts:

- Part 1: General requirements
- Part 2: Earth-continuity monitoring devices
- Part 3: Earth-leakage protection systems for use on earth-fault current limited systems (IT systems)
- Part 4: Lockout earth-fault protection devices (this Part)
- Part 5: Earth-fault current limiters

The key objectives of the AS/NZS 2081 series are as follows:

- (a) To ensure touch and step time/voltage levels are within acceptable limits.
- (b) To minimize the risk of explosion due to arcing.
- (c) To ensure earth return path(s).
- (d) To ensure reliable operation under operating conditions.
- (e) To ensure performance criteria are maintained under operating conditions.
- (f) To minimize the risk of fires initiated from electrical arcing.
- (g) To minimize exposure to electrical contact with live parts.

In the AS/NZS 2081 series, levels were established using data provided in AS 3007.2 *Electrical installations—Surface mines and associated processing plants, Part 2: General protection requirements*, with respect to the physiological effects of electricity on the human body. The preservation of the integrity of other equipment was an important consideration in the preparation of this series.

This Standard differs from the previous edition in the following significant ways:

- (a) The inclusion of a typical system electrical diagram showing the application of all of the above protection system and highlighting the particular protection system as detailed in this Standard.
- (b) This Standard has been published as a Joint Australian/New Zealand Standard.

The term ‘informative’ has been used in this Standard to define the application of the appendix to which it applies. An ‘informative’ appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
FOREWORD.....	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 OBJECTIVE.....	5
1.3 RELATIONSHIP TO REGULATIONS.....	5
1.4 REFERENCED DOCUMENTS.....	5
1.5 DEFINITIONS.....	6
SECTION 2 DESIGN AND CONSTRUCTION	
2.1 GENERAL.....	7
2.2 OPERATING VALUE.....	7
2.3 INDICATION.....	7
2.4 SUPPLY TRANSFORMERS	7
2.5 INTRINSIC SAFETY.....	7
2.6 NON EXTRA LOW VOLTAGE TESTS.....	7
SECTION 3 TESTS	
3.1 CATEGORIES OF TESTS	8
3.2 ROUTINE TESTS	8
3.3 TYPE TESTS.....	8
APPENDIX A INSTALLATION GUIDANCE.....	10

FOREWORD

The interrelationship of the 'techniques' described in the five Parts of this series strives to create as safe a working environment as possible. In this environment of surface and underground mines electrically powered equipment is often mobile and supplied by trailing or reeling cables.

These 'techniques' are as follows:

- (a) The continuous checking that the equipment is adequately earthed, by monitoring the pilot loop earth in the supply cable, its connection to the machine it is supplying and its termination at the substation supplying the machine (see AS/NZS 2081.2).

NOTE: This system may incorporate remote start/stop features.

- (b) The measurement of leakage current to earth in a circuit and the initiation of isolation of that circuit, when the value reaches or exceeds a predetermined safe value (see AS/NZS 2081.2).
- (c) The pre-energization testing of a circuit, to determine that the phase-to-earth insulation value of each and every phase conductor is above a present value, before the circuit can be energized (see this Standard).
- (d) The use of earth current limiting devices, to minimize the risk of touch and step potential reaching a level which would cause risk to personnel (see AS/NZS 2081.5).

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Electrical equipment for coal and shale mines—Electrical protection devices****Part 4: Lockout earth-fault protection devices**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out minimum performance requirements for lockout earth-fault protection devices intended primarily for use in conjunction with trailing cables supplying mobile and portable equipment used on a.c. power supply systems having an earth-fault current limitation system (IT system).

NOTES:

- 1 Whereas this Standard is based upon 50 Hz supply systems it is envisaged that equipment may be installed upon higher or low frequency supply systems.
Consideration of the effects of these installations upon current limitation and effects upon the human body need to be considered. IEC 60479-1 and IEC 60479-2 should be referenced for the effects upon the human body of other supply frequencies.
- 2 Installation guidelines are provided in Appendix A.

1.2 OBJECTIVE

The objective of this Standard is to establish requirements for lockout earth-fault protection devices, in order to ensure that the lockout earth-fault protection being provided to the equipment will—

- (a) minimize risk of explosion due to arcing;
- (b) ensure reliable operation under normal operating conditions;
- (c) ensure performance criteria are maintained under normal operating conditions;
- (d) minimize the risk of fires caused by electrical arcing; and
- (e) minimize exposure to electrical contact with live parts.

1.3 RELATIONSHIP TO REGULATIONS

The requirements of this Standard may be read in conjunction with, but do not take precedence over, regulations of a regulatory authority that may apply in a specific area.

1.4 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS	
2380	Electrical equipment for explosive atmospheres—Explosion-protection techniques
2380.7	Part 7: Intrinsic safety i