



Fire detection and alarm systems

Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor



This Australian Standard® was prepared by Committee FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 21 July 2016.

This Standard was published on 22 August 2016.

The following are represented on Committee FP-002:

- Association of Hydraulic Services Consultants Australia
 - Australasian Fire and Emergency Service Authorities Council
 - Australian Chamber of Commerce and Industry
 - Australian Industry Group
 - Australian Institute of Building Surveyors
 - CSIRO
 - Deafness Forum of Australia
 - Department of Human Services, Vic.
 - Engineers Australia
 - Fire Protection Association Australia
 - National Electrical and Communications Association
 - National Fire Industry Association
 - Property Council of Australia
 - Society of Fire Safety
-

This Standard was issued in draft form for comment as DR AS ISO 7240.27:2016.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Fire detection and alarm systems

Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor

First published as AS ISO 7240.27:2016.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76035 556 2

PREFACE

This Standard was prepared by Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems.

The objective of this Standard is to specify requirements, test methods and performance criteria for a point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor, for use in fire detection and alarm systems.

This Standard is identical with, and has been reproduced from ISO 7240-27:2009, *Fire detection and alarm systems, Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text ‘this part of ISO 7240’ should read ‘this Australian Standard’.
- (b) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian Standard</i>	
ISO		AS	
7240	Fire detection and alarm systems	7240	Fire detection and alarm systems
7240-1	Part 1: General and definitions	7240.1	Part 1: General and definitions
7240-5	Part 5: Point-type heat detectors	7240.5	Part 5: Point type heat detectors (ISO 7240-5:2003, MOD)
7240-6	Part 6: Carbon monoxide fire detectors using electro-chemical cells	7240.6	Part 6: Carbon monoxide fire detectors using electro-chemical cells
7240-7	Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization	7240.7	Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)
IEC			
60068	Environmental testing	60068	Environmental testing
60068-1	Part 1: General and guidance	60068.1	Part 1: General and guidance
60068-2-1	Part 2-1: Test—Test A: Cold	60068.2.1	Part 2.1: Tests—Tests A: Cold
60068-2-2	Part 2-2: Test—Test B: Dry heat	60068.2.2	Part 2.2: Tests—Tests B: Dry heat
60068-2-6	Part 2-6: Test—Test Fc: Vibration (sinusoidal)	60068.2.6	Part 2.6: Tests—Test Fc: Vibration (sinusoidal)
60068-2-27	Part 2-27: Tests—Test Ea and guidance: Shock	60068.2.27	Part 2.27: Tests—Test Ea and guidance: Shock
60068-2-30	Part 2-30: Tests—Test Db Damp heat, cyclic (12 h + 12 h cycle)	60068.2.30	Part 2.30: Tests—Test Db Damp heat, cyclic (12 h + 12 h cycle)
60068-2-42	Part 2-42: Tests—Test Kc: Sulphur dioxide test for contacts and connections	60068.2.42	Part 2.42: Tests—Test Kc: Sulphur dioxide test for contacts and connections
60068-2-78	Part 2-78: Tests—Test Cab: Damp heat, steady state	60068.2.78	Part 2.78: Tests—Test Cab: Damp heat, steady state

Only normative references that have been adopted as Australian Standards have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annexes to which they apply. A ‘normative’ annex is an integral part of a Standard, whereas an ‘informative’ annex is only for information and guidance.

CONTENTS

1	Scope	1
2	Normative references	1
3	Definitions	2
4	General requirements.....	2
4.1	Compliance.....	2
4.2	Individual alarm indication	2
4.3	Connection of ancillary devices.....	3
4.4	Monitoring of detachable detectors.....	3
4.5	Manufacturer's adjustments	3
4.6	On-site adjustment of response behaviour	3
4.7	Protection against the ingress of foreign bodies	3
4.8	Rate-sensitive CO response behaviour.....	3
4.9	Smoke response to slowly developing fires	4
4.10	Marking	4
4.11	Data	5
4.12	Requirements for software controlled detectors	5
5	Tests.....	6
5.1	General.....	6
5.2	Repeatability of smoke response.....	11
5.3	Repeatability of CO response.....	11
5.4	Directional dependence of smoke response	11
5.5	Directional dependence of CO response	12
5.6	Directional dependence of heat response (optional function).....	12
5.7	Lower limit of heat response (optional function)	13
5.8	Reproducibility of smoke response.....	13
5.9	Reproducibility of CO response.....	14
5.10	Reproducibility of heat response (optional function).....	14
5.11	Exposure to chemical agents at environmental concentrations	15
5.12	Long-term stability of CO response.....	16
5.13	Saturation	16
5.14	Exposure to chemical agents associated with a fire	17
5.15	Variation in supply parameters	18
5.16	Air movement	19
5.17	Dazzling	20
5.18	Dry heat (operational).....	20
5.19	Cold (operational), smoke.....	21
5.20	Cold (operational), CO.....	23
5.21	Damp heat cyclic (operational).....	24
5.22	Damp heat, steady state (endurance).....	25
5.23	Low humidity, steady state (endurance)	26
5.24	Sulfur dioxide SO ₂ corrosion (endurance).....	27
5.25	Shock (operational)	28
5.26	Impact (operational).....	29
5.27	Vibration, sinusoidal (operational).....	30
5.28	Vibration, sinusoidal (endurance).....	32
5.29	Electromagnetic compatibility (EMC) immunity tests (operational).....	33
5.30	Fire sensitivity.....	34
6	Test report	36

Annex A (normative) Gas test chamber for response threshold value and cross sensitivity measurements	37
Annex B (informative) Construction of the heat tunnel	38
Annex C (normative) Apparatus for impact test	41
Annex D (normative) Fire test room	43
Annex E (normative) Smouldering (pyrolysis) wood fire (TF2)	45
Annex F (normative) Glowing, smouldering cotton fire (TF3)	48
Annex G (normative) Open plastics (polyurethane) fire (TF4)	51
Annex H (normative) Liquid (heptane) fire (TF5)	53
Annex I (normative) Low-temperature, black-smoke (decalin) liquid fire (TF8)	55
Annex J (informative) Information concerning the construction of the gas test chamber	57

INTRODUCTION

A fire detection and fire alarm system is required to function satisfactorily not only in the event of fire, but also during and after exposure to conditions it can likely meet in practice, such as corrosion, vibration, direct impact, indirect shock and electromagnetic interference. Some tests specified are intended to assess the performance of fire detectors under such conditions.

The performance of fire detectors is assessed from results obtained in specific tests; this part of ISO 7240 is not intended to place any other restrictions on the design and construction of such detectors.

Smoke detectors using ionization or optical sensors, and complying with ISO 7240-7, are well established for the protection of life and property. Even so, they can respond to stimuli other than smoke and in some circumstances can be prone to false alarms. False alarm rates are usually minimized by careful application, giving some limitations in use, and occasionally with a reduction in protection provided.

It is generally accepted that fire detectors using carbon monoxide (CO) sensors alone, while suitable for the detection of smouldering fires involving carbonaceous fuels, can be relatively insensitive to free-burning fires supported by a plentiful supply of oxygen. This limitation can be largely overcome by the inclusion of a heat sensor whose output is combined in some way with that of the CO sensor. Performance requirements for CO fire detectors and for CO and heat detectors can be found in ISO 7240-6 and ISO 7240-8, respectively.

Although the CO-detector — heat-detector combination is capable of responding to free-burning fires, it can still be relatively insensitive to low-temperature fires that produce large amounts of visible smoke but low concentrations of CO and little heat. This limitation prevents the CO and heat detector from being a true replacement for a smoke detector in life-safety applications.

Many false-alarm sources that affect smoke detectors do not produce CO. It is possible, therefore, that by adding a CO sensor to a smoke detector, and combining its output in some way with that of the smoke sensor, the incidence of false alarms can be reduced. This reduction can be achieved while simultaneously providing the ability to respond to a broader range of fire types than is possible with either a smoke or CO detector alone.

It can be possible to improve the performance even further by adding a heat sensor to assist in the response to clean-burning, high-energy fires. This improvement is seen as secondary to the overall performance and for this reason the heat sensor is treated as optional for compliance with this part of ISO 7240.

AUSTRALIAN STANDARD

Fire detection and alarm systems

Part 27:

Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor

1 Scope

This part of ISO 7240 specifies requirements, test methods and performance criteria for multi-sensor point-type fire detectors that incorporate an optical or ionization smoke sensor, an electro-chemical cell for sensing carbon monoxide (CO) and, optionally, one or more heat sensors, for use in fire detection and alarm systems installed in buildings (see ISO 7240-1).

For the testing of other types of fire detectors using smoke, CO and, optionally, heat sensors working on different principles, this part of ISO 7240 can be used only for guidance. Fire detectors using smoke, CO and, optionally, heat sensors which have special characteristics and which have been developed for specific risks are not covered by this part of ISO 7240.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209-1, *Wrought aluminium and aluminium alloys — Chemical composition and forms of products — Part 1: Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

ISO 7240-5:2003, *Fire detection and alarm systems — Part 5: Point-type heat detectors*

ISO 7240-6, *Fire detection and alarm systems — Part 6: Carbon monoxide fire detectors using electro-chemical cells*

ISO 7240-7:2003, *Fire detection and alarm systems — Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*

ISO 7240-8, *Fire detection and alarm systems — Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2-1: Tests — Test A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2-2: Tests — Test B: Dry heat*