

Australian/New Zealand Standard™

**Bolted unrestrained mechanical
couplings for waterworks purposes**



AS/NZS 4998:2009

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee WS-016, Cast Iron Pressure Pipes and Fittings. It was approved on behalf of the Council of Standards Australia on 23 February 2009 and on behalf of the Council of Standards New Zealand on 9 March 2009.
This Standard was published on 31 March 2009.

The following are represented on Committee WS-016:

Australian Chamber of Commerce and Industry
Australian Industry Group
Certification Bodies, Australia
Plastics Industry Pipe Association of Australia
Plastics New Zealand
Water Industry Operators Group of New Zealand
Water Services Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

**Bolted unrestrained mechanical
couplings for waterworks purposes**

First published as AS/NZS 4998:2009.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 9061 5

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee WS-016, Cast Iron Pressure Pipes and Fittings.

The objective of this Standard is to provide performance requirements for manufacturers and purchasers of bolted unrestrained mechanical couplings.

This Standard is based on the water industry Standard WSA 105, which was published by the Water Services Association in July 2001.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes of tables and figures are deemed to be requirements of this Standard. Other notes are for information and guidance only.

Australian Standards generally do not—

- (a) restate the duties of employers, employees, designers and installers;
- (b) determine the applicability of regulatory limitations; or
- (c) determine appropriate health and safety practices.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	6
1.4 DESIGNATION OF SIZE	6
1.5 CLASSIFICATION	7
1.6 ALLOWABLE PRESSURES	7
SECTION 2 MATERIALS	
2.1 MATERIAL REQUIREMENTS.....	8
2.2 DEZINCIFICATION-RESISTANT COPPER ALLOYS.....	8
2.3 POLYMERIC SYSTEMS.....	8
2.4 ELASTOMERIC SEALS.....	8
2.5 EFFECT ON WATER.....	8
SECTION 3 DESIGN, MANUFACTURE AND OPERATIONAL LIMITATIONS	
3.1 DESIGN	10
3.2 DIMENSIONS.....	10
3.3 FREEDOM FROM DEFECTS	10
3.4 NOMINAL JOINT DEFLECTION.....	10
3.5 NOMINAL PIPE SETTING GAP	10
3.6 COMPONENT JOINTING.....	11
3.7 WELDING	12
SECTION 4 TESTING	
4.1 TYPE TESTS	13
4.2 POLYMERIC COATING TESTS	14
SECTION 5 MARKING AND PACKAGING	
5.1 MARKING	15
5.2 PACKAGING.....	15
5.3 INSTALLATION INSTRUCTIONS	15
APPENDICES	
A COMPLIANCE REQUIREMENTS	16
B TYPICAL COUPLING CONFIGURATIONS.....	20

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Bolted unrestrained mechanical couplings for waterworks purposes**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for unrestrained mechanical couplings for joining above or below ground water mains and wastewater mains, other than polyethylene (PE) piping, with pressure classifications of PN 16 and PN 35 and nominal sizes DN 80 to DN 750 and for a maximum working temperature of 40°C.

Means for demonstrating compliance with this Standard are given in Appendix A.

NOTES:

- 1 Requirements for couplings for use with polyethylene piping are specified in AS/NZS 4129.
- 2 Typical coupling arrangements are shown in Appendix B.

1.2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

1110	ISO metric hexagon bolts and screws—Product grades A and B
1110.1	Part 1: Bolts
1111	ISO metric hexagon bolts and screws — Product grade C
1111.1	Part 1: Bolts
1112	ISO metric hexagon nuts
1112.1	Part 1: Style 1—Product grades A and B
1112.3	Part 3: Product grade C
1199	Sampling procedures for inspection by attributes
1199.1	Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection
1214	Hot-dip galvanized coatings on threaded fasteners (ISO metric coarse thread series)
1565	Copper and copper alloys—Ingots and castings
1646	Elastomeric seals for waterworks purposes
1831	Ductile cast iron
2074	Cast steels
2205	Methods of destructive testing of welds in metal
2205.10.1	Part 10.1: Corrosion test for welded austenitic stainless steel
2345	Dezincification resistance of copper alloys
3518	Acrylonitrile butadiene styrene (ABS) pipes and fittings for pressure applications
4041	Pressure piping