

Australian Standard® 1845—1985

PORTABLE FIRE EXTINGUISHERS— FOAM (STORED PRESSURE) TYPE



STANDARDS ASSOCIATION OF AUSTRALIA
Incorporated by Royal Charter



This Australian standard was prepared by Committee FP/3, Fire Extinguishers. It was approved on behalf of the Council of the Standards Association of Australia on 8 October 1985 and published on 4 November 1985.

The following interests are represented on Committee FP/3:

Board of Fire Commissioners of New South Wales
Building Owners and Managers Association of Australia
Commonwealth Fire Board
Department of Consumer Affairs, N.S.W.
Department of Defence
Department of Home Affairs and Environment
Department of Industrial Relations, N.S.W.
Experimental Building Station
Fire Protection Industry Association of Australia
Insurance Council of Australia
Metropolitan Fire Brigades Board, Melbourne
Ministry of Consumer Affairs, Vic.
Telecom Australia
Trade Practices Commission
Western Australian Fire Brigades Board

Review of Australian Standards. To keep abreast of progress in industry, Australian standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn standards.

Suggestions for improvements to Australian standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AUSTRALIAN STANDARD

**PORTABLE FIRE EXTINGUISHERS—
FOAM (STORED PRESSURE)
TYPE**

AS 1845—1985

First published (incl. in AS A32)	1937
Revised	1963
Revised	1969
AS 1845 first published	1976
Second edition	1983
Third edition	1985

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 3964 X



PREFACE

This edition of this standard was prepared by the Association's Committee on Fire Extinguishers, to supersede AS 1845—1983.

The changes in this edition include allowance for trace gas detection, new design and pulsation test requirements for the extinguisher body construction, the inclusion of a test requirement for siphon tubes, clarification of the warning attached to extinguishers shipped empty, a revision of the requirements for Appendix D, and changes of an editorial nature.

Some purchasers may require evidence from manufacturers or suppliers that their product complies with the provisions of the relevant standard. The Standards Mark of the Association (see Note to Marking clause) on an extinguisher is an independent assurance of such compliance.

Other Australian standards dealing with portable fire extinguishers are as follows:

- AS 1841 Portable Fire Extinguishers—Water (Gas Container) Type
- AS 1842 Portable Fire Extinguishers—Water (Stored Pressure) Type
- AS 1844 Portable Fire Extinguishers—Foam (Gas Container) Type
- AS 1846 Portable Fire Extinguishers—Powder Type
- AS 1847 Portable Fire Extinguishers—Carbon Dioxide Type
- AS 1848 Portable Fire Extinguishers—Halon Type
- AS 1850 Portable Fire Extinguishers—Classification, Rating and Fire Testing
- AS 1851.1 Maintenance of Fire Protection Equipment, Part 1—Portable Fire Extinguishers
- AS 2444 Portable Fire Extinguishers—Selection and Location

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1985

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 Scope	4
1.2 Referenced Documents	4
1.3 Definitions	4
SECTION 2. DESIGN AND CONSTRUCTION	
2.1 Size	5
2.2 Method of Operation	5
2.3 Charge	5
2.4 Basis for Design	5
2.5 Materials and Construction	5
2.6 Circumferential and Longitudinal Joints	5
2.7 Protective Finishes	5
2.8 Neck Ring	6
2.9 Operating Head	6
2.10 Actuating Mechanism	6
2.11 Handle and Supporting Fitting	6
2.12 Support Fixture	6
2.13 Liquid Level Indicator	6
2.14 Pressure Indicating Device	6
2.15 Discharge Fittings	6
2.16 Performance Requirements	6
SECTION 3. TESTING	
3.1 Pressure Tests	7
3.2 Test for Continuity of Organic Lining	7
3.3 Test for Leakage of Gas	7
3.4 Pulsation Test (Type Test Only)	7
SECTION 4. MARKING, IDENTIFICATION, AND PACKING	
4.1 Marking of Extinguishers	8
4.2 Colour Identification	8
4.3 Packing for Shipment	8
APPENDICES	
A Materials Suitable for Welding or Brazing	9
B Welding or Brazing of Extinguishers—Permissible Methods	10
C Additional Requirements for Resistance (Seam or Spot) Welding	10
D Fusion Welding	11
E Type Approval Test	11

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

for

PORTABLE FIRE EXTINGUISHERS—FOAM (STORED PRESSURE) TYPE

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard specifies requirements for metal-bodied portable fire extinguishers of the foam type in which the foam is expelled by gas stored under pressure in the body of the extinguisher. It refers to materials, methods of manufacture, and performance of the extinguisher.

1.2 REFERENCED DOCUMENTS. The following standards are referred to in this standard:

- AS 1849 Identification Colours for Portable Fire Extinguishers
 - AS 1850 Portable Fire Extinguishers—Classification, Rating and Fire Testing
 - AS 2700 Colour Standards for General Purposes
- Standards for materials and for welding or brazing methods are listed in Appendix A and in Appendices B and D, respectively.

1.3 DEFINITIONS. For the purpose of this standard, the following definitions apply:

1.3.1 Portable fire extinguisher—a first-aid fire-fighting appliance which is designed to be carried and operated by hand, and which in working order has a mass not greater than 23 kg.

NOTE: This limit of 23 kg may be reconsidered internationally and could be reduced to 20 kg.

1.3.2 Foam (stored pressure) type portable fire extinguisher—a portable fire extinguisher in which the foam is expelled by means of an inert gas or air stored with or dissolved in the charge under pressure.

NOTE: The foam (stored pressure) type portable fire extinguisher is generally referred to in this standard as 'an extinguisher' or 'the extinguisher'.