

Australian Standard™

**Water supply—Valves for the control of
hot water supply temperatures**

**Part 1: Thermostatic mixing valves—
Materials design and performance
requirements**



This Australian Standard was prepared by Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems. It was approved on behalf of the Council of Standards Australia on 26 October 2001 and published on 8 February 2002.

The following interests are represented on Committee WS-026:

AUSTAP

Australian Industry Group

Business New Zealand

Consumers Federation of Australia

Gas Appliance Manufacturers Association of Australia

Housing Industry Association

Institute of Hospital Engineering Australia

Master Plumbers and Mechanical Contractors Association of NSW

Master Plumbers, Gasfitters and Drainlayers New Zealand

NSW Health Department

New Zealand Engineering Federation

South Australian Department of Human Services

Water Corporation Western Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 01022.

Australian Standard™

**Water supply—Valves for the control of
hot water supply temperatures**

**Part 1: Thermostatic mixing valves—
Materials design and performance
requirements**

Originated as AS 4032—1992.
Previous edition AS 4032—1998.
Revised and redesignated as AS 4032.1—2002.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 4192 4

PREFACE

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems, to supersede AS 4032—1998, *Thermostatic mixing valves*. After consultation with stakeholders in both countries, Standards Australia/Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide manufacturers with requirements for thermostatic mixing valves that give reasonable protection to users against exposure to high or excessive fluctuations in mixed-water temperatures caused by variations, including shut-off, in the cold water supply.

This Standard is Part 1 of a suite of Standards that covers valves for the control of hot water temperatures as follows:

AS

- 4032 Water supply—Valves for the control of hot water supply temperatures
- 4032.1 Part 1: Thermostatic mixing valves—Materials, design and performance requirements (this Standard)
- 4032.2 Part 2: Tempering valves and end-of-line temperature-activated devices

Upon completion, the suite will include the following:

- Part 3: Mandatory field testing, maintenance and replacement of thermostatic Elements

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

This Standard necessarily deals with existing conditions, but is not intended to discourage innovation or to exclude material, equipment and methods that may be developed in the future. Revisions will be made from time to time in view of such developments, and amendments to this edition will be made only when absolutely necessary.

CONTENTS

	<i>Page</i>
FOREWORD	5
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	6
1.2 APPLICATION	6
1.3 REFERENCED DOCUMENTS.....	6
1.4 DEFINITIONS.....	7
1.5 DESIGNATION	7
1.6 INSTRUCTIONS.....	8
1.7 PRODUCT DATA	8
1.8 MARKING	8
SECTION 2 MATERIALS	
2.1 SCOPE OF SECTION	9
2.2 COPPER ALLOY MATERIAL	9
2.3 CONTAMINATION OF WATER	9
SECTION 3 DESIGN AND CONSTRUCTION	
3.1 GENERAL.....	10
3.2 END CONNECTORS	10
3.3 LIMITATION OF TEMPERATURE ADJUSTMENT	10
3.4 CROSS-FLOW PREVENTION DEVICES	10
3.5 ISOLATING VALVES.....	10
SECTION 4 PERFORMANCE REQUIREMENTS	
4.1 GENERAL.....	11
4.2 TORQUE TESTS.....	11
4.3 WATERTIGHTNESS AT AMBIENT TEMPERATURE.....	11
4.4 ENDURANCE OF THERMOSTATIC ELEMENT AND OPERATING MECHANISM INCLUDING THERMAL SHUT-OFF	11
4.5 SENSITIVITY OF TEMPERATURE CONTROL.....	11
4.6 TEMPERATURE STABILITY OF MIXED WATER	12
4.7 WATERTIGHTNESS AT OPERATING TEMPERATURE.....	12
4.8 FINAL TESTS	12
SECTION 5 PERFORMANCE TESTS	
5.1 SEQUENCE	13
5.2 PARAMETERS	13
5.3 APPARATUS	13
5.4 THERMOSTATIC ELEMENT/SENSOR AND OPERATING MECHANISM	13
5.5 ISOLATION VALVES, CROSS-FLOW PREVENTION DEVICES AND CONTROL VALVES	13

APPENDICES

A	COMMISSIONING, MAINTENANCE AND INSTALLATION INSTRUCTIONS .	16
B	MEASUREMENT OF NOISE EMISSION.....	18
C	WATER VOLUME CONTROL TORQUE TEST	19
D	TEMPERATURE STOP/OVERRIDE CONTROL TORQUE TEST	21
E	WATERTIGHTNESS TEST.....	23
F	ENDURANCE TESTING OF THERMOSTATIC ELEMENT/SENSOR AND OPERATING MECHANISM TEST.....	25
G	SENSITIVITY OF TEMPERATURE CONTROL TEST	29
H	TEMPERATURE STABILITY OF MIXED WATER TEST	31
I	APPARATUS FOR TEST RIGS	36
J	PIPEWORK FOR TEST RIGS	37
K	TYPICAL TEST RIG FOR PERFORMANCE TESTS.....	38

FOREWORD

The type and nominal size of thermostatic mixing valves and ancillary equipment (if any) are selected with the consideration of factors that include the following:

- (a) General information that includes—
 - (i) nominal size (DN), number and type of water inlets, outlet(s) and connections;
 - (ii) minimum and maximum dynamic pressures and operating temperatures for hot and cold water;
 - (iii) for one or more water outlets, the minimum and maximum flow rates; and
 - (iv) whether provided with integral isolating valves or cross-flow prevention devices, or both.
- (b) Ancillary equipment for pressure control devices with respect to—
 - (i) maximum dynamic pressure ratio (hot to cold or cold to hot); and
 - (ii) maximum continuous working pressures for hot and cold water.

STANDARDS AUSTRALIA

Australian Standard

Water supply—Valves for the control of hot water supply temperatures

Part 1: Thermostatic mixing valves—Materials design and performance requirements

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for the design, construction, testing and performance of thermostatic mixing valves of nominal sizes not larger than DN 32, for use with hot water at a supply temperature not exceeding 90°C, and hot and cold water with continuous working pressures not exceeding 1400 kPa.

The principal element of the testing procedures is that the thermostatic mixing valve under test does not permit the discharge of water from the outlet with a temperature more than 2°C in excess of the nominated discharge temperature. Discharges of water with a temperature in excess of 2°C, which comply with the cumulative time/temperature factors given in Table 4.1, are acceptable.

NOTE: Manufacturers may negotiate with the certifying body on hot water supply temperatures up to 99°C, or hot and cold water continuous working pressures greater than 1400 kPa or both, if considered desirable, to assess temperature stability of the mixed water (see Clauses 1.7 and 5.2).

1.2 APPLICATION

This Standard is established to provide manufacturers, system designers, relevant authorities and others with performance requirements for thermostatic mixing valves. When used for ablutionary purposes, thermostatic mixing valves complying with this Standard provide the user with reasonable protection against scalding or excessive temperature fluctuations due to variations of pressures and temperatures of the hot and cold water supplies, including partial and total shut-off of the cold water supply.

The performance criteria and operating range of the valve shall be nominated by the manufacturer (see Clauses 1.7 and 5.2).

NOTE: Diagrams in this Standard are typical and chosen without prejudice.

1.3 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

2345 Dezincification resistance of copper alloys

3688 Water supply—Copper and copper alloy body compression and capillary fittings and threaded-end connectors

AS/NZS

4020 Products for use in contact with drinking water