

Australian Standard™

High-voltage switches

**Part 2: High-voltage switches for rated
voltages of 52 kV and above
(IEC 60265-2, Ed.1.0(1988) MOD)**

This Australian Standard was prepared by Committee EL-007, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 16 March 2005. This Standard was published on 18 May 2005.

The following are represented on Committee EL-007:

Australian British Chamber of Commerce
Australian Electrical and Electronic Manufacturers Association
Energy Networks Association
Engineers Australia
Testing interests (Australia)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 04511.

Australian Standard™

High-voltage switches

Part 2: High-voltage switches for rated voltages of 52 kV and above (IEC 60265-2, Ed.1.0(1988) MOD)

Originated as part of AS C339—1967.
Previous edition AS 1025.2—1989.
Revised and redesignated AS 60265.2—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6630 7

PREFACE

This Standard was prepared by the Standards Australia Committee EL-007 Power Switchgear, to supersede AS 1025.2—1989.

The objective of this Standard is to establish requirements for a.c. switches and switch-disconnectors having, making and breaking current ratings at rated voltages of 52 kV and above, for in-door and outdoor installations.

This Standard is Part 2 of a two-Part Standard consisting of the following:

AS

60265	High-voltage switches
60265-1	Part 1: Switches for rated voltages above 1 kV and less than 52 kV
60265-2	Part 2: High-voltage switches for rated voltages of 52 kV and above (this Standard)

This Standard is an adoption with national modifications and has been reproduced from IEC 60265-2, Ed.1.0(1988), *High-voltage switches Part 2 High-voltage switches for rated voltages of 52 kV and above*, incorporating its Corrigendum 1:1990, Amendment 1:1994 and Amendment 2:1998. It has been varied as indicated to take account of Australian conditions and it has been brought into line with the latest edition of AS 2650—2005, *Common specifications for high voltage switchgear and controlgear standards*.

Australian variations include the introduction of type testing, upon agreement between the manufacturer and user, for partial discharge, dielectric dissipation factor and radio interference voltage; routine testing, upon agreement between manufacturer and user, for partial discharge and dielectric dissipation factor, and an Australian annex listing items to be agreed between the purchaser and the user.

This Standard differs from the Standard it supersedes in the following major areas:

- (a) ‘Terminals’ (clause 5.10) has been deleted.
- (b) ‘Independent Manual Operation’ (clause 5.7) has been added and following clauses 5.7 to 5.9 are renumbered.
- (c) Clauses 5.11 to 5.18 have been added.
- (d) Clauses 6.7 to 6.10 have been added.
- (e) Table IX ‘Suggested maximum permissible switching overvoltages when switching capacitive and inductive currents’ has been deleted.
- (f) Condition of switch after breaking tests (subclause 6.101.15) has been updated.
- (g) Condition of switch during and after short-circuit making test (subclause 6.101.16) item c) has been updated.
- (h) Tests for limited-purpose and special-purpose switches (subclause 6.102.3), requirements for mechanical endurance tests for frequently operated switches have been added.
- (i) ‘Quality control during manufacture’ has been replaced by (Clause 11) ‘Safety’.
- (j) Annex ZA ‘Items subject to agreement between the manufacturer and user’ has been added.
- (k) References have been updated.
- (l) IEC 60265-2, Ed.1.0 (1988) Corrigendum 1: 1990, Amendment 1:1994 and Amendment 2: 1998 have been incorporated.

Variations to IEC 60265-2, Ed.1.0(1988) are indicated at the appropriate places throughout this standard. Strikethrough (~~example~~) identifies IEC text, tables and figures which, for the purposes of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this international standard' should read 'this Australian Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 Scope	1
2 Normal and special service conditions	2
3 Definitions	3
4 Rating	5
4.1 Rated voltage	5
4.2 Rated insulation level	5
4.3 Rated frequency	5
4.4 Rated normal current and temperature rise	5
4.5 Rated short-time withstand current	5
4.6 Rated peak withstand current	5
4.7 Rated duration of short-circuit	6
4.8 Rated supply voltage of closing and opening devices and auxiliary circuits	6
4.9 Rated supply frequency of operating devices and auxiliary circuits	6
4.10 Rated pressure of compressed gas supply for operation	6
5 Design and construction	8
5.1 Requirements for liquids in high-voltage switches	8
5.2 Requirements for gases in high-voltage switches	8
5.3 Earthing of high-voltage switches	8
5.4 Auxiliary equipment	8
5.5 Dependent power closing	8
5.6 Stored energy closing	8
5.7 Independent manual operation	8
5.8 Operation of releases	8
5.9 Low-and high-pressure interlocking and monitoring devices	9
5.10 Nameplates	9
5.11 Interlocking devices	9
5.12 Position indication	9
5.13 Degrees of protection by enclosures	9
5.14 Creepage distances	9
5.15 Gas and vacuum tightness	9
5.16 Liquid tightness	9
5.17 Flammability	9
5.18 Electromagnetic compatibility (EMC)	9
6 Type tests	10
6.1 General	10
6.2 Dielectric tests	11
6.3 Radio interference voltage (RIV) tests	12
6.4 Measurement of the resistance of the main circuit	12
6.5 Temperature rise tests	12
6.6 Short-time withstand current and peak withstand current tests	12
6.7 Verification of the protection	12
6.8 Tightness tests	12
6.9 Electromagnetic compatibility (EMC) tests	12
6.10 Additional tests on auxiliary and control circuits	12

	<i>Page</i>
6.102 Mechanical operation tests	25
6.200 Dielectric dissipation factor	27
7 Routine tests.....	27
7.1 Power frequency voltage withstand dry tests on the main circuit	27
7.200 Dielectric dissipation factor	27
7.201 Partial discharge test	27
8 Guide to the selection of high-voltage switches for service.....	28
9 Information to be given with enquiries, tenders and orders.....	29
10 Rules for transport, storage, installation, operation and maintenance.....	30
11 Safety	31
Annex ZA (informative) Items subject to agreement between the manufacturer and user.....	45
Annex ZZ (normative) Variations to IEC 60265-2, Ed.1.0(1988) for application in Australia	47

STANDARDS AUSTRALIA

Australian Standard

High-voltage switches

**Part 2: High-voltage switches for rated voltages of 52 kV and above
(IEC 60265-2, Ed.1.0(1988) MOD)**

Any table, figure or text of the international standard that is struck through is not part of this standard. Any Australian table, figure or text that is added (and identified by shading) is part of this standard.

1 Scope

This standard is applicable to three-phase alternating-current switches, having making and breaking current ratings, for indoor and outdoor installations, for rated voltages 52 kV and above; and for rated frequencies up to and including 60 Hz.

This standard is also applicable to the operating devices of these switches and to their auxiliary equipment.

Note 1 - Switches for gas insulated switchgear are covered by this standard.

Note 2 - Switches having a disconnecting function and called switch-disconnectors are also covered by IEC 62271-102.

Note 3 - Earthing switches are not covered by this standard. Earthing switches forming an integral part of a switch are covered by IEC 62271-102.

1.101 Object

The main object of this standard is to establish requirements for switches used in transmission and distribution systems. General-purpose switches for this application shall comply with the following service applications:

- carrying rated normal current continuously;
- carrying short-circuit currents for a specified time;
- switching of mainly active loads;
- switching of no-load transformers;
- switching of the charging current of unloaded cables, overhead lines or busbars;
- switching of closed-loop circuits;
- making short-circuit currents.

A further object of this standard is to establish requirements for limited-purpose and special-purpose switches used in transmission and distribution systems.

Limited-purpose switches shall comply with one or more of the service applications indicated above.

Special-purpose switches may comply with one or more of the service applications indicated above and, in addition, shall be suitable for one or more of the following applications:

- switching single capacitor banks;
- switching back-to-back capacitor banks;
- switching shunt reactors including secondary or tertiary reactors switched from the primary side of the transformer;