

AS 1828—1984

Australian Standard[®]

**Electrical equipment for explosive
atmospheres—Cable glands**

This Australian standard was prepared by Committee EL/14, Electrical Equipment in Hazardous Locations. It was approved on behalf of the Council of the Standards Association of Australia on 1 August 1984 and published on 5 October 1984.

The following interests are represented on Committee EL/14:

Australian Coal Association
Australian Electrical and Electronic Manufacturers Association
Australian Institute of Petroleum
Confederation of Australian Industry
Department of Industrial Relations, N.S.W.
Department of Defence Support
Department of Minerals and Energy, Vic.
Department of Mines, Qld
Electrical Contractors Associations of Australia
Electricity Supply Association of Australia
Independent Testing Interests
Insurance Council of Australia
State electricity regulatory authorities

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 1828—1984

Australian Standard[®]

Electrical equipment for explosive atmospheres—Cable glands

First published (as AS C357)	1966
AS 1828 first published	1976
Second edition	1980
Third edition	1984

Incorporating:
Amdt 1—1985

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 1835 9

PREFACE

This edition of this standard was prepared by the Association's Committee on Electrical Equipment in Hazardous Locations to supersede AS 1828—1980, Cable Glands for Explosive Atmospheres. It is intended for the guidance of manufacturers, users and Regulatory Authorities, and for use with the SAA Wiring Rules (AS 3000) and relevant mining regulations. It prescribes requirements in respect of design, construction and marking of the equipment specified, and includes a section on testing.

In its terminology, definitions and general treatment of the subject, this standard has taken into account the following standards:

BS 542	Cable Glands and Sealing Boxes for Association with Apparatus for Use at Mines and Quarries
IEC 79-1	Electrical Apparatus for Explosive Gas Atmospheres Part 1—Construction and Test of Flameproof Enclosures of Electrical Apparatus.

Acknowledgement is made of the assistance received from these sources.

The major changes in this edition are:

- (a) Reference is made to AS 2380, Part 1 for grouping of apparatus, temperature classification, requirements for enclosures and marking.
- (b) Group II glands are now required to be of a sealed type (spigot joints are not permitted). In practice, this will mean that all Group II glands will be suitable for use in dust areas without the need for complying with AS 2236.
- (c) Glands intended for Group I applications are now required to have a wall thickness of at least 3 mm at any point or pass the impact test with an impact energy of 30 J.
- (d) The addition of requirements to cover the use of a hard-setting compound in place of a sealing bush.
- (e) All references to 'weatherproofness' have been deleted and instead, reference is made to AS 1939.
- (f) Reference is made to AS 2380, Part 1 for the impact test.
- (g) A new requirement has been added for the fit between the gland and cable sheath.
- (h) The deletion of the requirement for positive means to be provided to prevent over-compression of the bush.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
FOREWORD	4
SECTION 1. SCOPE AND GENERAL	
1.1 Scope	5
1.2 Referenced Documents	5
1.3 Definitions	5
1.4 Grouping	5
SECTION 2. DESIGN, CONSTRUCTION AND MARKING	
2.1 Design	6
2.2 Materials	6
2.3 Wall Thickness	6
2.4 Fit of Cable Sheath	6
2.5 Glands with Sealing Bushes	6
2.6 Glands with Compound Sealing	6
2.7 Joints in the Structure of the Gland	6
2.8 Attachment of Cables and Flexible Cords	7
2.9 Gland Assembly	8
2.10 Marking	8
SECTION 3. TESTS	
3.1 General	9
3.2 Dimensional Tests	9
3.3 Torque Test	9
3.4 Tension Force Test	9
3.5 Degree of Protection Test	9
3.6 Mechanical Pressure Test	10
3.7 Impact Test	10
APPENDICES	
A Typical Construction Methods for Cable Glands	11
B Tension Force Test	15
C Proof Torque Test	15
D Information to be Contained in Drawings of Gland Submitted with an Application for Examination and Test	15

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard**for****ELECTRICAL EQUIPMENT FOR EXPLOSIVE ATMOSPHERES—CABLE GLANDS**

FOREWORD

The purpose of this standard is to establish requirements for cable glands which will enable their use in flammable or explosive atmospheres without risk of fire or explosion, i.e. for the termination of electrical cables and cords as required by mining regulations, and by the SAA Wiring Rules (AS 3000) for certain hazardous locations.

The standard acknowledges the practical difficulty of specifying standard dimensions for the bore of glands other than those intended for use with mineral-insulated metal-sheathed (MIMS) cable because of the relatively wide tolerances which apply to cable and cord diameters. Hence while special attention must be paid to cable diameter tolerances in respect of fit in the gland, provision is made for the use of a sealing bush of suitable type for the maintenance of the type of equipment protection for which the gland forms a component part. In such instances it is required that the cable be a close fit into the gland, ensuring adequate support of the cable on either side of the sealing bush and preserving mechanical soundness and strength.

The standard sets out requirements for adequate strength of the structure, and includes provisions for connecting screen wires and for effectively clamping armour where used, compliance with specified tension forces for attachment of cables and flexible cords, selection of material to minimize abrasive sparking; close attention is given to the treatment of joints.

The classification of hazardous areas is dealt with in AS 2430, Parts 1 and 2. Part 1 applies to explosive gas atmospheres and recognizes the following zones:

- Zone 0— an area in which an explosive gas atmosphere is present continuously, or is expected to be present for long periods or for short periods which occur with high frequency.
- Zone 1— an area in which an explosive gas atmosphere can be expected to occur periodically or occasionally during normal operation.
- Zone 2— an area in which an explosive gas atmosphere is not expected to occur in normal operation and if it occurs is likely to be present only infrequently and for short duration.

Glands marked Group I and complying with this standard will normally be suitable for use in underground coal mines.

Glands marked Group II and complying with this standard will normally be suitable for use in a Zone 1 or Zone 2 area and in areas classified as Class II in AS 3000.