

Australian Standard™

**Electronic flame safeguards and flame
detectors**

This Australian Standard was prepared by Committee AG-011, Gas Components and Industrial Equipment. It was approved on behalf of the Council of Standards Australia on 14 April 2005. This Standard was published on 1 June 2005.

The following are represented on Committee AG-011:

AGA Certification Services
Appliance and Component Testing
Energy Networks Association
Engineers Australia
Gas Appliance Manufacturers Association of Australia
Gas Appliances and Services Association
Gas Technical Regulators Committee
LPG Australia
Major Industrial Gas Installations

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Electronic flame safeguards and flame detectors

Originated as AG 210—1976.
Previous edition 1998.
Republished and designated AS 4625—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6730 3

PREFACE

This Standard was reviewed by the Standards Australia Committee, AG-011, Gas Components and Industrial Equipment, to supersede AG 210—1998, *Approval requirements for electronic flame safeguards and flame detectors*. The Standard is republished without technical alterations.

The objective of this Standard is to provide manufacturers, designers, regulatory authorities, testing laboratories and similar organizations with uniform minimum requirements for the safety, performance and use of combination controls for electronic flame safeguards and flame detectors.

This Standard should not be regarded as a design specification or as an instruction manual.

In its preparation, consideration has been given to—

- (a) continuity of satisfactory operation;
- (b) the prevention of fire hazards, and explosions;
- (c) the prevention of injury to persons or property;
- (d) gas rules and regulations now in force; and
- (e) relevant International Standards.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE, CLASSIFICATION AND DEFINITIONS	
1.1 SCOPE	4
1.2 CLASSIFICATION	4
1.3 DEFINITIONS	6
SECTION 2 CONSTRUCTION AND DESIGN	
2.1 MATERIALS	9
2.2 CONSTRUCTION.....	9
2.3 DESIGN	10
2.4 MARKINGS.....	11
2.5 INSTRUCTIONS	11
SECTION 3 PERFORMANCE REQUIREMENTS	
3.1 GENERAL	13
3.2 ELECTRICAL.....	13
3.3 FLAME DETECTORS.....	13
3.4 FLAME FAILURE RESPONSE.....	14
3.5 SAFE START CHECK.....	14
3.6 CONTINUAL SELF-CHECK	14
3.7 PROGRAMMING FUNCTION	15
3.8 DURABILITY	16
APPENDICES	
A METHODS OF TEST.....	17
B SUPPLEMENT TO M.O.T. 3.8.1 DURABILITY	30
C AS 4625 CLASS AND EN 298 CLASSIFICATION EQUIVALENCE GUIDE.....	32
D LIST OF REFERENCED DOCUMENTS	33

STANDARDS AUSTRALIA

Australian Standard**Electronic flame safeguards and flame detectors**

SECTION 1 SCOPE, CLASSIFICATION AND DEFINITIONS

1.1 SCOPE

These requirements apply to electronic flame safeguards and flame detectors for use on gas or multi-fuel burners.

They do not cover complete burner management systems except insofar as the flame safeguard has provision to be interlocked into the burner management system.

Compliance with these requirements does not imply acceptability for use without supplemental tests in an intended application.

A flame safeguard and flame detector shall comply with the requirements of the appropriate electrical authority.

Where a programmable electronic system (PES) is employed for safety related functions of burner management systems, the PES shall:

- (a) be certified to the requirements of this Standard and conform to the relevant requirements of EN 298 (or equivalent); or
- (b) be certified by a body recognized by the Certifying Body to the requirements of EN 298 (or equivalent).

Requirements for thermoelectric flame safeguards and electronic igniters are published in AS 4620 and AS 4622.

Flame safeguards incorporating electronic igniters shall meet the requirements of both this Standard and all the appropriate requirements of AS 4622.

European Standard, EN 298, has been identified as an appropriate Standard for the evaluation of electronic flame safeguards and flame detectors. Compliance with EN 298 will also be deemed to comply with the requirements of this Standard, however, specific local requirements as specified in this Standard shall take precedence.

NOTES:

- (a) Compliance will be subject to the provision of relevant documentation submitted to the Certifying Body.
- (b) Refer to Appendix C, which details equivalent European classification codes.

1.2 CLASSIFICATION**1.2.1 Class**

The flame safeguard may be one of three classes:

- (a) Class 1 Has a safe start check and a continual self-check of the flame safeguard and flame detector.
- (b) Class 2 Has a safe start check of the flame safeguard and flame detector.