

Australian Standard[®]

**SEPARABLE INSULATED
CONNECTORS FOR POWER
DISTRIBUTION SYSTEMS
ABOVE 1 kV**

[Title allocated by the Defence Cataloguing Authority:
CONNECTORS, PLUG AND RECEPTACLE, ELECTRICAL
(Separable; Power Distribution, above 1 kV)]

This Australian standard was prepared by Committee EL/7, Power Switchgear. It was approved on behalf of the Council of the Standards Association of Australia on 11 April 1983 and published on 4 July 1983.

The following interests are represented on Committee EL/7:

Australian-British Trade Association
Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Electricity Supply Association of Australia
Institution of Engineers, Australia
Railways of Australia Committee
Testing Authorities

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This standard was issued in draft form for comment as DR 82061.

Australian Standard[®]

**SEPARABLE INSULATED
CONNECTORS FOR POWER
DISTRIBUTION SYSTEMS
ABOVE 1 kV**

First published 1983

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 3004 9

PREFACE

This standard was prepared by a special Working Group of the Association's Committee on Power Switchgear, following a request from the Electricity Supply Association of Australia.

It applies to a simple and relatively inexpensive method of connection and switching of transformers and other electrical equipment in distribution systems using special flexible cable connectors.

The separable connectors covered by this standard are intended for use only as a part of a fully protected distribution system.

This standard illustrates a number of suitable connection interfaces, and users and manufacturers are encouraged to adopt the interface designs shown. However, connectors with interfaces different from those shown in this standard may be in the course of development.

A recent revision document for ANSI/IEEE Standard 386—1977 was used as the basis for this standard and acknowledgement is made of the assistance received therefrom.

Owing to the fact that separable insulated connectors imported into Australia are manufactured to comply with requirements specified in the country of manufacture and may not be available in a form to comply with all the requirements of AS 1824, Insulation Coordination, certain exemptions are permitted in this standard subject to the agreement of the purchaser.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 Scope	4
1.2 Referenced Documents	4
1.3 Service Conditions	4
SECTION 2. DEFINITIONS	
2.1 Application of Section	5
2.2 General Terms	5
2.3 Hardware Items	5
2.4 Electrical Characteristics	5
SECTION 3. RATINGS	
3.1 Voltage Ratings	10
3.2 Rated Frequency	10
3.3 Current Ratings	10
SECTION 4. DESIGN, CONSTRUCTION AND MARKING	
4.1 Design	11
4.2 Interchangeability	11
4.3 Operating Means	11
4.4 Shielding	11
4.5 Test Points	11
4.6 Hold-down Bails	11
4.7 Marking	11
SECTION 5. PERFORMANCE	
5.1 Behaviour on Test and in Service	23
5.2 Operating Temperature of Materials	23
SECTION 6. CLASSIFICATION OF TESTS	
6.1 Type Tests	24
6.2 Routine Tests	24
6.3 Tests at Site	24
SECTION 7. DETAILS OF TYPE TESTS	
7.1 Dielectric Tests	26
7.2 Short-circuit Current-carrying Capability Test	26
7.3 Switching-current Tests	26
7.4 Short-circuit Making Current Test	27
7.5 Connector Elbow Distortion Test for Off-axis Force	27
7.6 Current-cycling Test	30
7.7 Cable Pull-out Test	31
7.8 Operating Force Test	31
7.9 Operating Eye Test	31
7.10 Test-point Cap Mechanical Test	31
7.11 Test-point Electrical Tests	31
7.12 Shielding Test	31
7.13 Accelerated Sealing Life Test	31

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
SEPARABLE INSULATED CONNECTORS FOR POWER DISTRIBUTION SYSTEMS
ABOVE 1 kV

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard specifies requirements for load-break and dead-break separable insulated connectors and ancillary equipment for use on power distribution systems at alternating voltages above 1 kV.

The standard applies to separable insulated connectors rated at not more than 1250 A.

NOTE: Load-break connectors are available only for the lower current ratings. The purchaser should obtain information from manufacturers on available current ratings.

1.2 REFERENCED DOCUMENTS. The following documents are referred to in this standard:

- AS 1018 Recommendations for Partial Discharge Measurements
- AS 1429 Polymeric Insulated Cables for Electricity Supply at Working Voltages 1.9/3.3 kV Up to and Including 19/33 kV
Part 1— Cables Having Individual Screened Cores
- AS 1931 High Voltage Testing Techniques
Part 1— General Definitions, Test Requirements, Test Procedures and Measuring Devices
- IEEE 592 Exposed Semiconducting Shields on Premoulded High Voltage Cable Joints and Separable Insulated Connectors

1.3 SERVICE CONDITIONS.

1.3.1 Normal Service Conditions. Connectors complying with this standard are suitable for use in clean air and exposure to direct sunlight, under the following conditions:

- (a) The ambient air temperature does not exceed 40°C, and its average value measured over a period of 24 h does not exceed 35°C.
- (b) The ambient air temperature is not less than -10°C.
- (c) The maximum temperature due to sunlight does not exceed an equivalent black body temperature of 80°C.

NOTE: For practical purposes this is equivalent to 1.1 kW/m².

- (d) The altitude does not exceed 1000 m.

- (e) The ambient air is not materially polluted by dust, smoke, corrosive or flammable gases and vapours or salt.

NOTE: Sudden drops of temperature of up to 20°C in a period of 20 min and the presence of rain and condensation should be taken into account.

1.3.2 Special Service Conditions.

1.3.2.1 General. The use of connectors under special service conditions shall be subject to agreement between the purchaser and manufacturer.

1.3.2.2 Unusual environments. Connectors may become buried in earth or immersed in water. For this reason, an accelerated sealing life test is specified in Clause 7.13.

NOTE: This Clause does not imply that connectors may be opened or closed under conditions where the interfaces could become wet or contaminated.

1.3.2.3 Altitudes above 1000 m. Where connectors are required for use at altitudes above 1000 m, one or other of the following procedures shall be adopted:

- (a) The test voltages for such installations shall be determined by multiplying the rated withstand voltages given in Table 3.1 by the appropriate factor given in column 2 of Table 1.1.
- (b) Connectors may be selected having a rated voltage which, when multiplied by the appropriate correction factor given in column 3 of Table 1.1, is not lower than the system voltage.

TABLE 1.1
ALTITUDE CORRECTION FACTOR

1	2	3
Maximum altitude m	Correction factor for test voltages referred to sea level	Correction factor for rated voltages
1000	1.0	1.0
1500	1.05	0.95
3000	1.25	0.80

NOTE: For altitudes between 1000 m and 1500 m, and between 1500 m and 3000 m, the correction factors may be obtained by linear interpolation.