

Australian Standard[®]

PLASTICS PIPELAYING DESIGN

This Australian standard was prepared by Committee PL/21, Rigid PVC Pipe. It was approved on behalf of the Council of the Standards Association of Australia on 3 May 1982, and published on 13 September 1982.

The following interests were represented on the committee responsible for the preparation of this standard:

Department of Public Works, New South Wales
Engineering and Water Supply Department, South Australia
Federated Master Plumbers of Australia
Hunter District Water Board
Melbourne and Metropolitan Board of Works
Metropolitan Water Sewerage and Drainage Board, New South Wales
Plastics Institute of Australia Incorporated
Queensland Water Resources Commission
State Rivers and Water Supply Commission, Victoria

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 80244.

Australian Standard[®]

PLASTICS PIPELAYING DESIGN

First published (as AS CA68)	1972
Revised and issued as AS 2566	1982

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 2679 3

PREFACE

This standard was prepared by the Association's Committee on Rigid PVC Pipe under the authority of the Plastics Standards Board. It constitutes the revision and metrication of AS CA68—1972, with editorial updating, and which it accordingly supersedes. The ISO system of nomenclature with respect to pipe diameter has been adopted in conformity with changes made in recently published Australian standards.

The general design principles in this standard are based on Marston and Spangler's work at the Iowa Engineering Experiment Station on underground conduits. The general format and much of the data incorporated in AS CA33* have been used in the preparation of this standard. The committee considered the feasibility of presenting safe burial depths for pipes in tabular or graphical form. This approach was not possible because of the large variations of design factors to be incorporated in each calculation. The standard, however, enables calculation of the safe burial depth of all plastics pipes. The method of calculation is illustrated in Appendix C.

Only one formula for calculating the total vertical load acting on the pipe has been used in the standard, on the assumption that there is little difference in the load-sharing between the pipe and the side fill for the three types of laying conditions specified. Soil box tests have supported the calculations in the standard and long-term field testing has confirmed them.

Temperature derating factors have been given for E_c and Y , but it will be seen by calculation (and has been confirmed experimentally in soil box tests) that within the range of deflection (up to 5 percent), material temperature (up to 40°C) and values for modulus of soil reaction (up to 7 MPa) covered by this standard, the effect of temperature does not have a very great effect on deformation performance.

By using criteria and values set out in this standard, it is possible to design for the wide range of conditions likely to be met in practical situations. The design sequence for two such installations is illustrated in Appendix C.

* AS CA33, Code of Recommended Practice for Concrete Pipe Laying Design.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

STANDARD	<i>Page</i>
1 Scope	4
2 Application	4
3 Referenced Documents	4
4 Definitions	4
5 Notation and Values of Variables	4
6 Design Parameters	7
7 Pipeline Design	8
8 Loads on Pipes	8
9 Combined External Loading and Internal Pressure	9
10 Calculation of External Load Capacity of Pipe	9
APPENDICES	
A Formulas for Calculation of Vertical Loads on Pipes Due to Fill Material	15
B Standard Installation Conditions	17
C Sample Calculations	24

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
PLASTICS PIPELAYING DESIGN

1 SCOPE. This standard sets out design practice for calculating loads, safe bedding depths, and vertical deflections for plastics pipes laid under a number of specified standard underground installation conditions. It applies to pipes with outside diameter 75 mm and above and vertical deflection not greater than 5 percent of the outside diameter. For pipe sizes below this, the safe burial calculated by this standard for the 75 mm outside diameter pipe size may be used.

This standard applies to the use of smooth circular pipes made from UPVC or polyethylene. It can also apply to pipes of other plastics materials by the substitution of appropriate values in Tables 1, 2, 3, 5, and 6 for the particular pipe material.

2 APPLICATION. This standard provides a basis for assessing the loads on plastics pipes under various installation conditions and for selecting the appropriate pipe class for the particular installation from the standards applicable to the installation for a maximum allowable vertical deflection of 5 percent of the pipe outside diameter.

3 REFERENCED DOCUMENTS. The following standards are referred to in this standard:

- AS 1159 Polyethylene (Polythene) Pipe for Pressure Applications
- AS 1289 Methods of Testing Soils for Engineering Purposes
1289.E1.1 — Part E — Soil Compaction and Density Tests — Determination of the Dry Density/Moisture Content Relation of a Soil Using Standard Compaction — Standard Method
- AS 1477 Unplasticized PVC (UPVC) Pipes and Fittings for Pressure Applications
Part 1 — UPVC Pipes for Pressure Applications

4 DEFINITIONS. For the purpose of this standard, the following definitions apply:

- Pipe* — a single length of pipe.
- Superimposed load* — a load, concentrated or distribute, static or dynamic, applied at the surface of the fill material.
- Diametral deflection* — the change in diameter of the pipe.
- Earth* — all natural material other than rock.
- Rock* — an unyielding natural foundation.

Bedding material — soil of $K\mu$ value not less than that assumed in the laying conditions design (see Tables 1, 2 and 3) with moisture content as appropriate to the degree of compaction required, substantially free from rock or other hard particles that would be retained on a 13.2 mm sieve and free from lumps of soil having any dimension greater than 75 mm. The bedding material may comprise selected fill material or may require to be imported, should the excavation material be unsuitable.

Compaction — consolidation of fill material. (See Clause 6.1.)

5 NOTATION AND VALUES OF VARIABLES.

The following notation shall apply in this standard:

B = width of trench, measured at the level of the top of the pipe, in metres

NOTE: For trench of unknown width, see Clause 6.6.

C_t = a coefficient used in the calculation of the vertical load on a pipe due to the weight of fill material when the pipe is installed under trench conditions (see Fig. 2).

C_e = a coefficient used in the calculation of the vertical load on a pipe due to the weight of fill material when the pipe is installed under positive projection embankment conditions (see Fig. 3)

NOTE: The original reference article for methods of calculating C_e is Bulletin 170, IOWA Engineering Experiment Station (1950).

C_n = a coefficient used in the calculation of the vertical load on a pipe due to the weight of fill material when the pipe is installed under negative projection embankment conditions (see Figure. 4)

NOTE: The original reference article for methods of calculating C_n is by M.G. Spangler in Highway Research Board (U.S.) Proceedings (1950).

C_u = a coefficient used in the calculation of the vertical load on a pipe due to a uniformly distributed superimposed load when the pipe is installed under trench conditions (see Fig. 5)

C_p = a coefficient used in the calculation of the vertical load on a pipe due to concentrated superimposed loads when the pipe is installed under any of the conditions (see Fig. 6)

D_e = the nominal diameter of the pipe, in metres

D_m = the mean outside diameter of the pipe, in metres

D = mean diameter of the pipe, in metres
= $D_m - T$